PNL D2

CIRCUIT DIRECTORY

IF DOOR DIRECTORY IS USED, IDENTIFY THE CIRCUIT BREAKERS WITH THE DIRECTORY CIRCUIT NUMBER

1	Compressor & Floor Hoist
3	Compressor & Floor Hoist
5	Compressor & Floor Hoist
7	Motorized Roll up Door
9	Motorized Roll up Door & Floor Hoist
11	Brake Lathe
13	Tire Balancer
15	3B - KASEY KAHNE
17	5B - KASEY KAHNE
2	7B - KASEY KAHNE
4	Fire Alarm [illegible]
6	Damp Relay
8	Damper Relay
10	Electr Room Recpt
12	E/G RMS
14	Service E/G
16	Service Dist. Panel
18	FACP
20	Detail outside
22	
24	

1 3 5 7 9 11 13 15 17

2 [DAMPER RELAY] 4 [DAMPER RELAY] 6 8 10 12 14 FACP 16 18

60 20 SWD ON OFF

Cutler-Hammer

125 AMPS MAX.

1-PHASE PANELS; TABLE/TIPOS 1 FASE

120/240 VAC/VCA 1PH - 3W; 1 FASE - 3 HILOS

208Y/120 VAC/VCA 3W; 3 HILOS

3-PHASE PANELS; TABLE/TIPOS 3 FASE

240 VAC/VCA 3PH-3W; 3 FASE - 3 HILOS | SEE (1); VER (1)

208Y/120 VAC/VCA 3 PH - 4W; 3 FASE - 4 HILOS

240Y/120 VAC/VCA 3 PH - 4W DELTA; 3 FASE - 4 HILOS

SEE (2); VER (2)

(1) USE ONLY 240 VOLTS CIRCUIT BREAKER.

(2) 240 VOLT CIRCUIT BREAKERS MAY BE USED FOR LIGHTING AND APPLIANCE BRANCH CIRCUIT PANEL BOARD. ALL RATINGS. USE 120/240 VOLT CIRCUIT BREAKERS ONLY. THIS PANEL IS NOT TO BE USED WITH A 240 VOLT DELTA SYSTEM WHERE THE HIGH LEG EXCEED 120 VOLTS TO GROUND VOLTAGE DOES NOT DISCONNECTING MEANS ARE PROVIDED AND WHEN NOT USED AS A SERVICE EQUIPMENT.

SEE CASE SIDE WALL FOR FURTHER INFORMATION

PUB 29544

MADE IN USA; HECHO EN EUA

REV A

STORAGE 825-4143

Do not remove or conceal

WASTE WATER PUMP

Electrical Approval

Permit No. 3238131P

Date 2/2/24

Approved by

Dept. of Labor & Industries

F500-005-000 (5-93)

PNL C1
CKT 1,3,5
208v

UN3266

HIGH SUDS

WESMAR

MARKLEEN

SELECT

PNL C1
CKT 1,3,5
208v

RIAGE 82

DEWALT
DEWALT

DEWALT
DEWALT

NO PARKING

BOEING

Liberty Pumps

ELECTRICAL ROOM

PROTECTION PRODUCTS

We take pride in your vehicle.

Mopar

CHRYSLER CORPORATION PARTS

BEST SELECTION & BEST PRICE

BUY 3 TIRES GET THE 4TH FOR $1

CAUTION

YOU MAY SILENCE THE ALARM WHEN EVACUATION IS COMPLETE OR ALARM IS FOUND TO BE FALSE.

DO NOT RESET PANEL UNTIL THE FIRE DEPARTMENT HAS REVIEWED ALARM CAUSE AND GIVEN PERMISSION TO RESET.

DO NOT REMOVE
By Order of the
Fire Department

Year:	Month:	Next Due Date:
2016	08	08-2017

Firm: Alarmguard Security Systems Inc
Address: PO Box 98 Puyallup 98371
Phone: 253-926-0000
Inspected By: Jeremey Shaffer 8/29/16
City of Tacoma Fire Protection License Number: 500001941

Description of work: Annual Fire Inspection RED YELLOW (GREEN)

Circle the System Status

ALARMGUARD
253-926-0000
Alarm Center 1-800-752-2490
63-2530

NO DEFICIENCIES

DO NOT REMOVE By Order of Fire Chief	Year	Month	Next Due Date
	2020	12	6/2021

AAA FIRE PROTECTION SINCE 1954
www.aaafire.com
3013 3rd Ave. North
Seattle, WA 98109-1602
(206) 284-1721
(206) 284-2176 fax

Serviced by: T. Duh Certificate NO: 149990

Description of work:
- Replaced Power supply
- System Normal at this time



MODEL 5207 FIRE CONTROL/COMMUNICATOR
WITH EXCLUSIVE Accu-Zone® FEATURE

SILENT KNIGHT®

CIRCUIT (ZONE) NUMBER	CIRCUIT (ZONE) TYPE FIRE, SUPERVISORY OR OTHER	LOCATION
	ZONE-1-PULL STATIONS/HEAT DETECTOR	
	ZONE-2-DRY FLOW	
	ZONE-3-WET FLOW	
	ZONE-4-DUCT DETECTOR	
	ZONE-5-LOW AIR	
	ZONE-6-TAMPER DRY	
	ZONE-7-TAMPER WET	
	ZONE-8-PIV	

INSPECTED
DATE 9/6/7 INITIALS LMC

INDICATOR DESCRIPTION

ALARM:	FLASHING = FIRE ALARM ON = SUPERVISORY ALARM
TROUBLE:	ON = TROUBLE CONDITION
AC/DC:	ON = NORMAL POWER CONDITION FLASHING = BATTERY POWER ONLY OFF = NO AC AND LOW BATTERY
MEMORY:	ON = BELLS HAVE BEEN SILENCED
SILENCED:	ON = TROUBLE HAS BEEN SILENCED BUT TROUBLE STILL EXISTS
SET MODE REPORT:	ON = SET MODE FLASHING = REPORTING

SEVEN SEGMENT DISPLAY

0	= FIRE DRILL
1-15	= ZONE #
E0	= DIALER TROUBLE
E1	= PRINTER TROUBLE
E2	= EEPROM TROUBLE
F0	= KEYSTATION POWER TROUBLE
F1-F7	= KEYSTATION TROUBLE
A1-A4	= BELL TROUBLE
P1	= SMOKE POWER TROUBLE
P2	= ACCESSORY POWER TROUBLE
P3	= EARTH GROUND FAULT TO GROUND
P4	= EARTH GROUND FAULT TO POWER
PA	= PRINTER OUT OF PAPER
dL	= DATA LOST
dF	= FAILED TO REPORT
dc	= LOW BATTERY
AC	= LOW AC POWER
L1	= PHONE LINE # 1 FAULT
L2	= PHONE LINE # 2 FAULT
-4	= DOWNLOADING
-8	= SET DATE
-9	= SET TIME

WARNING

THIS UNIT INCLUDES A PROGRAMMABLE ALARM VERIFICATION FEATURE THAT WILL RESULT IN A DELAY OF THE SYSTEM ALARM SIGNAL FROM THE INDICATED CIRCUITS. THE TOTAL DELAY (CONTROL UNIT & SMOKE DETECTOR) SHALL NOT EXCEED 60 SECONDS. NO OTHER INITIATING DEVICES SHALL BE CONNECTED TO THESE CIRCUITS UNLESS APPROVED BY THE LOCAL AUTHORITY HAVING JURISDICTION. (Delay not to exceed 30 sec. if installed in accordance with the California State Fire Marshals Office)

CIRCUIT (ZONE) NUMBER	CONTROL UNIT DELAY - SEC.	SMOKE DETECTOR * MODEL DELAY - SEC.

* USE DELAY (POWER UP) TIME MARKED ON THE INSTALLED SMOKE DETECTOR(S) FOR THIS COLUMN.

WARNING
HIGH VOLTAGE PRESENT INSIDE!
DISCONNECT CIRCUITS PRIOR TO SERVICING

S-2766 UL UNDERWRITERS LABORATORIES

SIGNAL SYSTEM CONTROL UNIT
1 OF 1
ISSUE NO. AH-6188

TEST AT LEAST ONCE A WEEK

ELECTRICAL RATINGS
INPUT VOLTAGE - 120 VAC
INPUT CURRENT - 2 AMPS
INPUT FREQUENCY - 60 HZ
STANDBY BATTERY CAPACITY 24 HR.

SEE INSTALLATION MANUAL FOR TEST & MAINTENANCE NOTES

COMPLIES WITH PART 68 FCC RULES
FCC REGISTRATION NO. AC6USA-65475-AL-E
RINGER EQUIVALENCE - 0.9B
TELEPHONE JACK NO. RJ31X

P/N 122289 MADE IN U.S.A.

Factory Mutual System Approved

H.V.A.C.
TIMER

HC Bracken
D2 - 2

C & G ELECTRONICS CO.
WHOLESALE DISTRIBUTORS

FIRE ALARM INSPECTION

INSPECTED BY	DATE
DW	1-10-00
Silence Enter	
Reset Enter X	

ZONE-1-PULL STATION/HEAT DETECTOR
ZONE-2-DRY FLOW
ZONE-3-WET FLOW
ZONE-4-DUCT DETECTOR
ZONE-5-LOW AIR
ZONE-6-TAMPER DRY
ZONE-7-TAMPER WET
ZONE-8-PIV

ALARMGUARD

ALARM
SILENCED
AC / DC
MEMORY
TROUBLE
SET MODE REPORT
CLEAR
ENTER
SILENCE
DISAB

ZONE 1
ZONE 2
ZONE 3 W
ZONE 4 DU
ZONE 5 LO
ZONE 6 DRY
ZONE 7 WET
ZONE 8 POST

Contractor:
Pnl D-2
CIR 4 - Fire
CIR 6 - Fire

ECJDR → Fire System Provided
802-0400
253-759-7316

Enter
Display Trouble
Enter
253-759-7316
936-6000
1-800-752-2490

Power Limiting

Keypad Operation

Two-Wire Smoke Requirements

Agency Listings/Requirements

Model 5207 Wiring Diagram
P/N 122327 Rev. E

Door Holder
Roll Down Door
Damper

F.C.C. Information

New York City Board of Standards and Appeals

This product is to be installed in accordance with Installation Manual P/N 150865 Dated

24811

HIGH VOLTAGE
DISCONNECT AC/BATTERY BEFORE SERVICING
BLACK
GROUND
WHITE

120VAC 60HZ
200 WATTS

DURACELL
ULTRA
SEALED NON-SPILLABLE BATTERY
BATERIA DE PLOMO-ACIDO SELLADOS
DURA12-12F3 12V 12Ah AGM

DANGER/POISON
PELIGRO/VENENO
SHIELD EYES. EXPLOSIVE GASES CAN CAUSE BLINDNESS OR INJURY.
PROTEJA LOS OJOS. LOS GASES EXPLOSIVOS PUEDEN CAUSAR DAÑOS O CEGUERA.
SULFURIC ACID CAN CAUSE BLINDNESS OR SEVERE BURNS.
EL ACIDO SULFURICO PUEDE CAUSAR CEGUERA O QUEMADURAS FUERTES.
KEEP OUT OF THE REACH OF CHILDREN.
ALEJESE DEL ALCANCE DE LOS NIÑOS.
FLUSH EYES IMMEDIATELY WITH WATER. GET MEDICAL HELP FAST.
ENJUAGUE LOS OJOS INMEDIATAMENTE CON AGUA. ACUDA RAPIDO CON EL MEDICO.
NO • SPARKS • FLAMES • SMOKING
NO *CHISPAS *LLAMAS *CIGARROS
DO NOT OPEN BATTERY!
¡NO ABRA LA BATERIA!

PNL B

Do not remove or conceal

Electrical Approval

Dept. of Labor & Industries

McMullen ELECTRIC, INC.

Date 2-7-00

Inspected by

Final by

1-800-332-2342

PCI

Lighting Control Systems

Lighting Control Systems

PNL A

MAIN

BRYANT® LOAD CENTER
225 A. 120/208V. 3 PH. 4W

Do not remove or conceal
Electrical Approval
Dept. of Labor & Industries
Permit No. 2000[illegible]
Date 2/2/00
Approved by

Do not remove or conceal
Electrical Approval
Dept. of Labor & Industries
Permit No. 2000[illegible]
Date 2/2/00
Approved by

McMullen ELECTRIC, INC.
Date 2-7-00
Inspected by
Final by
1-800-332-2342

Do not remove or conceal
Electrical Approval
Dept. of Labor & Industries
Permit No. 2543[illegible]
Date 7/8/14
Approved by

Do not remove or conceal
Electrical Approval
Dept. of Labor & Industries
Permit No. 2543[illegible]
Date 11/17/15
Approved by

McMullen ELECTRIC, INC.
845-7593
203 Stewart West - Puyallup, WA 98371-4395 1-800-332-2342

PANEL A DATE

1	Entrance Canopy Cans	2	Show Room Lts
3	Entrance Canopy Cans	4	Show Room Lts
5	Entrance Canopy Cans	6	Show Room Lts
7	Bld Sign	8	Lunch Room / office Lts
9	Bld Sign	10	Bath 107/111 + Hall Lts
11	Bld Sign	12	New Car Delivery Lts
13	Bld Sign	14	Show Room Lts
15	Bld Sign	16	Ret wall Pk
17	Flag Pole Lts	18	1 1 1
19	Service Canopy	20	Bath/office 133/ Lts
21	Service Canopy Sign	22	Hall/waiting Lts
23	Lighting Control Pnl	24	Coffee Maker
25	New Front Sign	26	Vending Mach.
27	Parts Lts under ECP	28	Vending Mach.
29	Parts Lts	30	Vending Mach.
31	Parts Lts	32	J/S Business 133
33	Parts Lts	34	Ret wall Pk 114
35	Roof unit HVAC	36	S S S
37	HVAC	38	Exhaust Fan Booth
39	HVAC	40	
41	Lts Switch/Gas	42	PRINTER/COPIER

Class B Basic Electrical Work Label
B 001603608

Use permanent marker and write clearly. Clean and dry surface before adhering.

This label is only valid after user enters information for this jobsite into Electronic Permit & Inspection System (EPIS) using Secure Access Washington (SAW).

Validation Date 10-10-18
Date of work 10-10-18
Elec Contractor Name [illegible]
Elec Contractor License # [illegible]
Installing Electrician [illegible]
Certificate # [illegible]
Site Address 726 ROOSEVELT AVE.
City [illegible] County [illegible]
Job site owner name and phone #(to arrange inspection) [illegible]
Description of work [illegible]

Work Label 03-2013

Enumclaw Chrysler Jeep Dodge
726 Roosevelt Ave
Enumclaw 98022

PNL B

BRYANT LOAD CENTER
225 A. 120/208V. 3 PH. 4W

MAIN

BRYANT
CAT. BR42-42-225S
CAT. BR42-42-225F
MAINS RATING
225 A. WITH 4/0 CU. TYPE RH CONDUCTOR
225 A. WITH 350 MCM AL. TYPE RH CONDUCTOR
LINE CONNECTORS SUITABLE FOR USE WITH COPPER OR ALUMINUM CONDUCTORS 350 MCM MAX.

Do not remove or conceal
Electrical Approval
Permit No. 153 11 38
Date 9/13/07
Approved By
Dept. of Labor & Industries

McMullen ELECTRIC, INC.
845-7593
1-800-332-2342

PANEL B

1	Lts Tracks/Ice Cav Det	2	Lts Step Head
3	Hoist Bay 3	4	Lts Step Head
5	" "	6	Lts Step Head
7	Hoist Bay 4	8	Lts Step Rear
9	" "	10	Lts Step Rear
11	Hoist Bay 4	12	Lts Step Rear
13	" "	14	Parking Lot Lt
15	Hoist Bay 5	16	" "
17	" "	18	
19	Hoist Bay 5	20	
21	" "	22	
23	Hoist Bay 6	24	Hoist Bay 1
25	" "	26	" "
27	Hoist Bay 6	28	Hoist Bay 1
29	" "	30	" "
31	Hoist Bay 7	32	Hoist Bay 2
33	" "	34	" "
35	Hoist Bay 7	36	Hoist Bay 2
37	" "	38	" "
39	Alignment Deck	40	Hoist Bay 3
41	S S S S	42	" "

DO NOT REMOVE
Department of Labor & Industries
Electrical Section
The corrections listed below are hereby ordered and must be made within 15 days.
Refer to National Electrical Code or State Rules for Safety
Name of Contractor
Address
SAFETY DEFECTS NEED
NOT APPROVED FOR COVER
NOTIFY INSPECTION OFFICE WHEN READY FOR REINSPECTION

PCI Lighting Control Systems

PNL C2

Do not remove or conceal
OK to Use
Electrical Approval
Dept. of Labor & Industries
Permit No. 1799870KH
Date 5-15-19
Approved by

DANGER: Hazard of Electrical Shock or Burn. TURN OFF POWER Supplying This Equipment Before Working Inside.

WARNING: This Equipment is Designed and Tested by Square D to Underwriters Laboratories Standards. Use of Other Than Square D Circuit Breakers May Adversely Affect User Safety, Impair Reliability and Will Void the Warranty.

90 LOAD CENTER COVER
CAT. NO. QOC442L
TYPE 1 ENCLOSURE SERIES G2

SQUARE D COMPANY

McMullen ELECTRIC, INC.
845-7593
1-800-332-2342
PANEL C-2

EM PUD

Do not remove or conceal
OK to Use Vern
Electrical Approval
Dept. of Labor & Industries
Permit No. 1337137
Date 5/13/19

PNL C1

WASTEWATER PUMP

Electrical Approval

323913P

2-12-21

Dept. of Labor & Industries

PNL C2

SQUARE D LOAD CENTER

TO DISCONNECT ENTIRE SERVICE, SWITCH OFF THE HANDLE MARKED MAIN OR MAIN DISCONNECT.

Underwriters Laboratories Inc. LISTED ELECTRIC CABINET FRONT ISSUE NO. 3-444

SERVICE RATING ____ AMPS.

ELECTRICAL INSPECTION BY

CAT. QOAC 40MG225 SERIES L4

ON

OFF

TRIPPED

McMullen ELECTRIC, INC.

CONTRACTOR #MCMULEI 926 BF

203 Stewart West • Puyallup, WA 98371-4395

845-7593

1-800-332-2342

PANEL C-1

DATE

1	~~[illegible]~~	2	Sm 4 Post Hoist
3	~~[illegible]~~	4	Sm 4 Post Hoist
5		6	Fluorescent wh N.
7	Row 1 High Bay	8	Fluorescent wh S
9	" " "	10	Fluorescent wh S
11	Row 2 Hi Bay	12	I/a Reception
13	" " "	14	I/a office 101,103,104
15	Row 3 Hi Bay	16	Duty Recept 103,105/04
17	" " "	18	Contactor Hi Bay wh
19	Row 4 Hi Bay	20	
21	" " "	22	Duty Recept Chng Room
23	Row 5 Hi Bay	24	Business Lts
25	" " "	26	CAR charger
27	L 4 Post Hoist	28	(Service Shop)
29	L 4 Post Hoist	30	Outlet by Tire machine
31	spare	32	Duty office 135,136
33	spare	34	I/a office 133,136
35	I/a Computer Room	36	Pnl C-2
37	I/a Computer Room	38	Pnl C-2
39	I/a Computer Room	40	Pnl C-2
41		42	

PNL D1

ON
125
MAIN
OFF

McMullen ELECTRIC, INC.
CONTRACTOR #MCMULEI 329 BP
203 Stewart West - Puyallup, WA 98371-4395
845-7593
1-800-332-2342

PANEL D-1 DATE 4-8-90

1	Detail Shop Recpt ONLY	2	Detail Recpt Hoist 120V shop
3	TIRE MACHINE	4	Hoist 120V shop
5	Detail I/L Recpt	6	Hoist 120V shop
7	Detail Lts INSIDE RIGHT SIDE	8	Pony wall shop
9	Detail Lts INSIDE LEFT SIDE	10	Pony wall shop
11	Detail Recpt.	12	Pony wall shop
13	Detail Recpt	14	Pony wall shop I/L
15	Service Lobby Lts	16	Transfer Pump
17	Service office Lts	18	Evaporator
19	Heat unit Roof	20	Pressure wash.
21	Heat unit Roof	22	Pressure wash.
23	Heat unit Roof	24	Evap Room Lt.
25	Pull D-2	26	Car wash Lts
27	Pull D-2	28	Car wash Lts
29	Ant D-2	30	Insta Hot Detail
31		32	
33		34	
35		36	
37		38	
39		40	
41		42	

McMullen ELECTRIC, INC.
Date 3-1-00
Inspected by TW
Final by TW
1-800-332-2342

PNL D2

2 | 4 (DAMPER CLEAN) | 6 (DAMPER RELAY) | 8 | 10 | 12 | 14 | FACP 16 | 18

1 | 3 | 5 | 7 | 9 | 11 | 13 | 15 | 17

ON

OFF

20 SWD

Eaton | Cutler-Hammer

CIRCUIT DIRECTORY

FACP

DANGER

HAZARDOUS VOLTAGE. WILL CAUSE SEVERE INJURY OR DEATH. Turn Off power supplying this equipment before working inside.

PELIGRO

VOLTAJE PELIGROSO. CAUSA HERIDAS SEVERAS O MUERTE. Apague el poder que suministra este equipo antes de trabajar en el interior del mismo.