


PROJECT NUMBER P4-A60MWA2-00003
PUBLIC WATER SYSTEM ID 52200



[illegible]

GENERAL NOTES

1. SYMBOLS FOR STRUCTURES, PIPE ETC. USED FOR IDENTIFICATION ARE SHOWN IN LEGENDS AND SHALL BE FOLLOWED THROUGHOUT THE PLANS WHENEVER APPLICABLE. NOT ALL OF THE VARIOUS COMPONENTS SHOWN IN THESE LEGENDS ARE NECESSARILY USED IN THE PROJECT.
2. SCALE OF THE DRAWINGS OR DETAILS ARE SHOWN IN TITLE BLOCK OR DIRECTLY UNDER THE PLAN OR DETAIL. THE SIZE OF THE ORIGINAL PLOTTED DRAWINGS IS 22"x34". CARE SHOULD BE TAKEN TO VERIFY THE SCALE BAR TO DETERMINE THE SCALE OF REDUCED REPRODUCTIONS.
3. IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO PERFORM CONSTRUCTION ACTIVITIES PER THE CONTRACT DOCUMENTS. ANY ADDITIONS, DELETIONS, OR MODIFICATIONS SHALL FIRST MEET WITH THE WRITTEN APPROVAL OF THE CONTRACT OFFICER.
4. CONTRACTOR SHALL OBTAIN ALL NECESSARY PERMIT(S) AND COMPLY WITH ALL REQUIREMENTS OF GOVERNING AGENCIES. SEE AMERICAN WATER SPECIFICATIONS FOR ADDITIONAL CONTRACTOR REQUIREMENTS.
5. ALL CONSTRUCTION ACTIVITIES SHALL BE PERFORMED IN A WORKMANLIKE AND SAFE MANNER AND IN ACCORDANCE WITH ALL STATE AND LOCAL CODES AND JOB-SITE RELATED CONSTRUCTION CONDITIONS AND REQUIREMENTS. OBTAIN PERMITS, INSPECTIONS AND APPROVALS AS REQUIRED BY JURISDICTIONAL AGENCIES AND PAY ALL ASSOCIATED FEES. CONTRACTOR AND INSTALLERS SHALL BE LICENSED AS REQUIRED BY STATE AND LOCAL JURISDICTIONS, AND BONDED AS DETERMINED BY PROJECT REQUIREMENTS.
6. CONTRACTOR SHALL PROVIDE NAMES AND OTHER REQUIRED INFORMATION FOR INDIVIDUALS WORKING ON THE PROJECT SITE TO CONTRACT OFFICER FOR AN ENTRY AUTHORIZATION LIST (EAL).
7. CONTRACTOR SHALL BE RESPONSIBLE FOR MAINTAINING CONTROL OF DRAINAGE AND EROSION DURING CONSTRUCTION AT CONSTRUCTION SITE, STAGING, AND SPOILS AREA. CONTRACTOR SHALL SUBMIT STORM RUNOFF CONTROL PLAN FOR APPROVAL AND OBTAIN A STORM WATER POLLUTION PREVENTION PLAN (SWPPP) PERMIT PER JBLM AND STATE REQUIREMENTS PRIOR TO STARTING CONSTRUCTION. CONTRACTOR SHALL PROVIDE INLET PROTECTION FOR STORM DRAIN INLETS NEAR CONSTRUCTION AREAS.
8. CONTRACTOR SHALL OBTAIN A BASE EXCAVATION PERMIT PRIOR TO STARTING EXCAVATION WORK TO FIELD LOCATE EXISTING UTILITIES. LOCATIONS OF ALL EXISTING UTILITIES INCLUDING SERVICE LINES HAVE NOT BEEN IDENTIFIED AND ARE NOT NECESSARILY SHOWN ON THE DRAWINGS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR VERIFYING THE LOCATION OF AND PRESERVING ALL EXISTING UTILITIES.
9. CONTRACTOR SHALL VERIFY DEPTHS OF UTILITIES IN THE FIELD BY POT HOLING A MINIMUM OF 300 FEET AHEAD OF CONSTRUCTION TO AVOID CONFLICTS WITH DESIGNED GRADE AND ALIGNMENT.
10. THE CONTRACTOR SHALL TAKE ALL PRECAUTIONARY MEASURES NECESSARY TO PROTECT EXISTING IMPROVEMENTS FROM DAMAGE WHICH ARE TO REMAIN IN PLACE. ALL SUCH IMPROVEMENTS OR STRUCTURES DAMAGED BY THE CONTRACTORS OPERATIONS SHALL BE REPAIRED OR RECONSTRUCTED TO ORIGINAL OR BETTER CONDITION TO THE SATISFACTION OF THE OWNER AT THE EXPENSE OF THE CONTRACTOR.
11. CONTRACTOR IS SOLELY RESPONSIBLE FOR CONFORMANCE WITH LOCAL AND FEDERAL CODES GOVERNING SHORING AND BRACING OF EXCAVATIONS AND TRENCHES. CONTRACTOR IS RESPONSIBLE FOR THE SAFETY OF THE PUBLIC AND PROTECTION OF PERSONNEL AND WORKERS.
12. CONTRACTOR SHALL NOT DESTROY, REMOVE, OR DISTURB ANY EXISTING SURVEY MONUMENTS WITHOUT AUTHORIZATION OF CONTROLLING AGENCY. NO PAVEMENT CUTTING OR REMOVAL SHALL BEGIN UNTIL ALL SURVEY MARKERS OR MONUMENT POINTS THAT HAVE THE POTENTIAL OF BEING DISTURBED BY THE CONSTRUCTION OPERATIONS HAVE BEEN PROPERLY REFERENCED BY A REGISTERED LAND SURVEYOR. ALL SURVEY MONUMENTS OR POINTS DISTURBED BY THE CONTRACTOR SHALL BE ACCURATELY RESET BY A REGISTERED LAND SURVEYOR AFTER ALL RESTORATION AND RESURFACING HAS BEEN COMPLETED.
13. CONTRACTOR SHALL PREVENT ANY GROUND WATER OR DEBRIS FROM ENTERING NEW PIPES DURING CONSTRUCTION.
14. CONTRACTOR SHALL BE RESPONSIBLE FOR CORRECTING ANY SETTLEMENT OF EXCAVATIONS, AND ANY DAMAGE OF UTILITIES RESULTING FROM SETTLEMENT.
15. INSTALL ALL MATERIALS ACCORDING TO MANUFACTURER RECOMMENDATIONS AND STATE AND LOCAL REQUIREMENTS. USE ONLY NEW AND UNUSED MATERIALS. ALL MATERIALS SHALL BE PROVIDED BY MANUFACTURERS REGULARLY ENGAGED IN PRODUCING SAID ITEMS, AND WHICH SHALL BE FIRST QUALITY, HEAVY DUTY, COMMERCIAL/INDUSTRIAL GRADE, SUITABLE FOR THE INTENDED USE.
16. MINIMUM DEPTH OF NEW PIPE: 4.0 FEET TO TOP OF PIPE UNLESS OTHERWISE NOTED.

17. CONTRACTOR SHALL MAINTAIN A 10-FEET HORIZONTAL SEPARATION BETWEEN ALL WATER AND SEWER LINES. WHERE WATERLINES CROSS SEWER LINES, MAINTAIN AN 20-INCH VERTICAL SEPARATION FROM ALL SEWER LINES. WATERLINES SHALL BE ROUTED ABOVE SEWER LINES.
18. WARNING TAPE SHALL BE PROVIDED ON ALL UTILITY LINES. PROVIDE TRACER WIRE ON WATER LINES.
19. ALL PIPE, FITTINGS, VALVES, AND CHEMICAL STORAGE TANKS USED FOR POTABLE WATER TREATMENT SHALL BE NSF 61 COMPLIANT FOR DRINKING WATER USE.
20. COORDINATE CONNECTION OF EXISTING WATER MAINS WITH OWNER.
21. WORKING PRESSURE FOR ALL WATERLINES IS 150 PSI WITH A TEST PRESSURE OF 200 PSI. ALL FLANGES, VALVES, FITTINGS, THRUST BLOCKS, ETC., SHALL BE RATED ACCORDINGLY. LEAK TESTING PER AW 33 01 10.13.
22. IN THE CASE OF PIPELINES THAT FAIL TO PASS THE LEAKAGE TEST, THE CONTRACTOR SHALL DETERMINE THE CAUSE OF THE LEAKAGE, SHALL TAKE CORRECTIVE MEASURES NECESSARY TO REPAIR THE LEAKS, AND SHALL AGAIN TEST THE PIPELINES, ALL AT NO ADDITIONAL COST TO THE OWNER.
23. CONTRACTOR SHALL PERFORM CHLORINATION TEST, LEAK TEST, PRESSURE TEST, AND BACTERIA TEST. ALL WATERLINES INSTALLED SHALL BE TESTED AND DISINFECTED IN ACCORDANCE WITH THE AMERICAN WATER WORKS ASSOCIATION STANDARDS AWWA C600 AND AWWA C651. ALL CHLORINATED WATER SHALL BE DISPOSED OF IN ACCORDANCE WITH JBLM AND STATE RULES AND REQUIREMENTS FOR SURFACE DISCHARGE AND COORDINATED WITH OWNER.
24. CONTRACTOR SHALL REMOVE AND STOCKPILE TOPSOIL FROM DISTURBED AREAS OF THE PROJECT. WHEN EXCAVATION AND BACKFILL ARE COMPLETE, THE TOPSOIL SHALL BE REPLACED OVER THE DISTURBED AREAS TO FACILITATE REVEGETATION.
25. CONTRACTOR SHALL PROVIDE ALL IMPORT FILL AND PIPE BEDDING MATERIALS AS REQUIRED. BORROW AREA WILL NOT BE AVAILABLE ON BASE.
26. WATER FOR CONSTRUCTION WILL BE AVAILABLE TO CONTRACTOR. COORDINATE WATER REQUIREMENTS WITH OWNER.
27. ALL WORK SHALL BE IN ACCORDANCE WITH AMERICAN WATER ENTERPRISES STANDARDS, AND APPLICABLE JBLM STANDARDS.
28. SURFACE RESTORATION:
ALL AREAS DISTURBED DURING CONSTRUCTION OUTSIDE OF ROADWAY SHALL BE RESEEDDED WITH NATIVE SEED MIX APPROVED BY HILL AFB. SEEDING SHALL BE EITHER DRILLED OR HYDROSEEDDED WITH HYDRO MULCH AND TACKIFIER. SEEDING SHALL OCCUR EITHER BETWEEN SEPTEMBER 15TH AND NOVEMBER 30TH, OR MARCH 15TH AND MAY 15TH, UNLESS OTHERWISE APPROVED BY OWNER.
29. WHERE CONTRACTOR ENCOUNTERS EXISTING ASPHALT ON TOP OF CONCRETE PAVEMENT, CONTRACTOR SHALL SAW CUT BOTH PAVEMENTS AND RESTORE SURFACE WITH CONCRETE AND ASPHALT PAVEMENT TO MATCH EXISTING.
30. ALL BURIED REBAR, FITTINGS, COUPLINGS, VALVES AND MECHANICAL JOINT NUTS AND BOLTS ARE TO BE COATED WITH NON OXIDE GREASE CHEVRON FM 2 OR APPROVED EQUAL, COVERED WITH 8 MIL POLYETHYLENE SHEETING, AND TAPE WRAPPED.
31. UNLESS NOTED OTHERWISE, ALL WATER MAIN SHALL BE 12-INCH PVC C900 CLASS 235 DR18 PIPE. SIZE OF FITTINGS SHOWN ON THE PLANS SHALL CORRESPOND TO ADJACENT STRAIGHT RUN OF PIPE, AND SHALL BE DUCTILE IRON FITTINGS.
32. CONTRACTOR SHALL PROTECT ADJACENT PRESSURE PIPELINES AND PROVIDE TEMPORARY THRUST RESTRAINT AS NECESSARY DURING CONSTRUCTION INCLUDING EXISTING VALVES, TEES, BENDS, ETC.. ALL NEW PRESSURE PIPE AND FITTINGS SHALL HAVE THRUST RESTRAINED JOINTS, THRUST BLOCKS, THRUST TIES OR OTHER APPROVED THRUST RESTRAINT. THRUST PROTECTION SHALL BE ADEQUATE FOR THE TEST PRESSURE SPECIFIED.
33. ALL FITTINGS REQUIRED FOR THE COMPLETION OF THE WORK ARE NOT SHOWN IN THE DRAWINGS. MAXIMUM PIPE JOINT DEFLECTION SHALL BE 2-DEGREES. ADDITIONAL FITTINGS REQUIRED TO MAINTAIN THE ALIGNMENT SHOWN IN THE PLANS SHALL BE PROVIDED BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE OWNER.
34. COORDINATE CONNECTION OF EXISTING WATER MAINS WITH OWNER.
 - OWNER DOES NOT GUARANTEE WATER SHUT-DOWNS. CONTRACTOR TO DEVISE PLANS TO AVOID WORK STOPPAGES IN THE EVENT A SHUT-DOWN DOES NOT GO AS PLANNED
 - CONTRACTOR SHALL SUBMIT FOR REVIEW A SEQUENTIAL PLAN FOR CONNECTION, TESTING, AND FLUSHING OF ALL NEW WATER MAINS, HYDRANTS, AND SERVICE CONNECTIONS.

35. ABANDONING EXISTING WATERLINE:
REMOVE ABANDONED PIPE WHERE UNCOVERED OR DISTURBED BY CONSTRUCTION. WHERE NOT DISTURBED, CONTRACTOR MAY ABANDON EXISTING WATER MAIN IN PLACE AFTER NEW MAIN IS IN FULL SERVICE UNLESS NOTED OTHERWISE. PLUG ENDS OF ABANDONED MAIN WITH CONCRETE. OLD WATER MAINS THAT ARE NO LONGER IN SERVICE ARE TO BE DISCONNECTED COMPLETELY FROM THE WORKING SYSTEM. UNLESS CONTRACTOR IS SPECIFICALLY DIRECTED TO REMOVE EXISTING VALVES, THE CONTRACTOR SHALL ABANDON EXISTING VALVES IN PLACE. OPEN VALVE, REMOVE BOTH THE TOP AND BOTTOM OF VALVE BOX AND FILL RESULTING HOLE WITH SAND. RESTORE SURFACE IN ACCORDANCE WITH SURFACE RESTORATION REQUIREMENTS OF THE GOVERNING AGENCY.
36. ALL ASBESTOS CEMENT WATERLINES REQUIRING REMOVAL SHALL BE DISPOSED OF IN ACCORDANCE WITH ALL FEDERAL, STATE, AND LOCAL REQUIREMENTS IN AN APPROVED LOCATION EQUIPPED TO HANDLE SUCH MATERIALS. ANY CUTTING REQUIRED SHALL BE PERFORMED IN ACCORDANCE WITH PROPER REGULATORY PROCEDURES. IN NO CASE SHALL THE PIPE AND FITTINGS BE BROKEN OR CRUSHED.
37. HYDROSEEDING:

37.1. HYDROSEEDING SHALL BE APPLIED TO ALL AREAS DISTURBED BY CONSTRUCTION ACTIVITIES UNLESS OTHERWISE NOTED.

37.2. SEED BEDS PLANTED BETWEEN MAY 1 AND OCTOBER 31 WILL REQUIRE IRRIGATION AND OTHER MAINTENANCE AS NECESSARY TO FOSTER AND PROTECT THE ROOT STRUCTURE.

37.3. FOR SEED BEDS PLANTED BETWEEN OCTOBER 31 AND APRIL 30, ARMORING OF THE SEED WILL BE NECESSARY (E.G., GEOTEXTILES, JUTE MAT, CLEAR PLASTIC COVERING.)

37.4. BEFORE SEEDING, INSTALL NEEDED SURFACE RUNOFF CONTROL MEASURES SUCH AS GRADIENT TERRACES, INTERCEPTOR DIKES, SWALES, LEVEL SPREADERS, AND SEDIMENT BANKS.

37.5. THE SEEDBED SHALL BE FIRM WITH A FAIRLY FINE SURFACE, FOLLOWING SURFACE ROUGHENING. PERFORM ALL OPERATIONS ACROSS OR AT RIGHT ANGLES TO THE SLOPE.

37.6. FERTILIZERS ARE TO BE USED ACCORDING TO SUPPLIERS RECOMMENDATIONS. AMOUNTS USED SHOULD BE MINIMIZED, ESPECIALLY ADJACENT TO WATER BODIES AND WETLANDS.

37.7. SEE SPECIFICATIONS FOR HYDROSEED MIXTURES, FERTILIZER, MULCH, AND APPLICATION RATES.

37.8. PROVIDE TOPSOIL FOR ALL DISTURBED AREAS MEETING THE SPECIFICATIONS.
38. MULCHING:

38.1. MULCH MATERIALS USED SHALL BE HAY OR STRAW, AND SHALL BE APPLIED AT THE RATE OF 2 TONS/ACRE.


38.2. MULCHES SHALL BE APPLIED IN ALL AREAS WITH EXPOSED SLOPES GREATER THAN 2:1.

38.3. MULCHING SHALL BE USED IMMEDIATELY AFTER SEEDING OR IN AREAS WHICH CANNOT BE SEEDED BECAUSE OF THE SEASON.

38.4. ALL AREAS NEEDING MULCH SHALL BE COVERED BY NOVEMBER 1.


COATING SCHEDULE						
LOCATION	DESCRIPTION	BURIED/EXPOSED/SUBMERGED	SIZE	COATING	SPECIFICATION	NOTES
SITE	DUCTILE IRON PIPE	BURIED	ALL	ASPHALT COATING AND POLYETHYLENE ENCASE	AW 33 11 00.15	CEMENT LINED AND ASPHALT SEALED
SITE	DUCTILE IRON PIPE	EXPOSED (INTERIOR)	ALL	SYSTEM 4	09 90 00	CEMENT LINED AND BARE PIPE WITH PRIMER

- NOTES:
1. COATING FOR VALVES, COUPLINGS, EQUIPMENT AND FITTINGS SHALL MATCH ADJACENT PIPE.
2. COATING SCHEDULE IS FOR GENERAL INFORMATION AND IS NOT INTENDED TO BE COMPREHENSIVE. SEE SPECIFICATIONS FOR ADDITIONAL DETAILS AND REQUIREMENTS.



AMERICAN WATER
Military Services

Joint Base Lewis-McChord



BOWEN COLLINS
ASSOCIATES

90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY				REVISIONS	
				DESCRIPTION	
				REV BY	
				DATE	
				NO	

AMERICAN WATER (P4-A60MVA2-00003)
JBLM WASHINGTON

SAGE WELL II REPLACEMENT

VERIFY SCALE
BAR IS ONE INCH ON ORIGINAL DRAWING

DESIGN
J. OLDHAM
R. GARCIA

REVIEW
R. ROCHA
J. OLDHAM


CHECKED
APPROVED

GENERAL

GENERAL NOTES

DATE: DECEMBER 2023

PROJECT NUMBER
427-22-03



GENERAL NOTES:

- 1. EROSION CONTROL MEASURE SHOWN ON THIS PLAN REPRESENT THE BEST MANAGEMENT PRACTICES (BMPs) AVAILABLE TO THE CONTRACTOR. ACTUAL ON SITE BMPs WILL BE DICTATED BY ON-SITE CONDITIONS. SPECIFIC EROSION CONTROL MEASURES IMPLEMENTS SHALL BE IDENTIFIED BY THE CERTIFIED EROSION AND SEDIMENT CONTROL LEAD (CESCL).
- 2. ALL WORK SHALL BE CONTAINED WITHIN THE CLEARING/WORK LIMITS SHOWN ON THIS PLAN. NO ADJOINING AREAS SHALL BE DISTURBED BY CONSTRUCTION ACTIVITIES.
- 3. CONTRACTOR TO PROVIDE ADEQUATE MEASURES TO PREVENT THE TRANSPORTATION OF SEDIMENT ONTO PAVED ROADS FROM MOTOR VEHICLES LEAVING THE PROJECT SITE. DEPOSITED SEDIMENT SHALL BE CLEANED DAILY BY SHOVELING OR SWEEPING. WATER CLEANING SHALL ONLY BE PERFORMED AFTER THE AREA HAS BEEN SHOVELED OR SWPT.
- 4. CONTRACTOR SHALL PROVIDE ADEQUATE MEASURES TO STABILIZE ON-SITE VEHICLES TRANSPORTATION ROUTES IMMEDIATELY AFTER GRADING TO PREVENT EROSION CAUSED BY TRAFFIC RUNOFF.
- 5. ALL DEMOLITION DEBRIS THAT IS NOT RECYCLABLE SHALL BE DISPOSED OF OFF-POST IN A LEGAL MANNER. DEMOLITION OF RECYCLABLE MATERIAL SHALL BE DISPOSED OF OFF-POST.
- 6. HYDROSEED/MULCH AND TOPSOIL ALL DISTURBED AREAS NOT RECEIVING SURFACING. SEE
- 7. CONTRACTOR SHALL DESIGNATE A WASHINGTON STATE CERTIFIED EROSION CONTROL AND SEDIMENT CONTROL LEAD (CESCL) WHO WILL BE ON-SITE OR ON CALL AT ALL TIMES THE EROSION CONTROL LEAD SHALL HAVE THE AUTHORITY TO IMPLEMENT THE STORMWATER POLLUTION PREVENTION PLAN (SWPPP) BASED ON SITE CONDITION WITHIN THEIR SCOPE. IF THE METHODS INDICATED FOR EROSION AND SEDIMENT CONTROL ARE NOT ADEQUATE, THE CESCL SHALL IMPLEMENT ADDITIONAL METHODS AS REQUIRED.
- 8. CONTRACTOR SHALL IMPLEMENT DRAINAGE EROSION CONTROL MEASURES AS NECESSITATED BY CONSTRUCTION ACTIVITIES.
- 9. CONTRACTOR SHALL COORDINATE HAUL ROUTES, DISPOSAL SITE, STAGING, AND STORAGE AREAS WITH CONTRACTING OFFICER.
- 10. CONTRACTOR SHALL SELECT AN ARE WITHIN CLEARING/WORK LIMITS TO STOCKPILE EXCAVATED SOIL.

CONSTRUCTION SEQUENCE:

- 1. ARRANGE FOR AND ATTEND PRE-CONSTRUCTION MEETING WITH AMERICAN WATER, JBLM, CONTRACTOR AND ENGINEER.
- 2. STAKE/FLAG CLEARING LIMITS.
- 3. INSTALL TEMPORARY EROSION CONTROL MEASURES.
- 4. CLEAR AND GRUB SITE WITHIN CLEARING LIMITS. REMOVE AND/OR CAP EXISTING UTILITIES WITHIN LIMITS AS SHOWN ON DEMOLITION PLAN. CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING WITH JBLM AND INDIVIDUAL UTILITY PURVEYOR PRIOR TO REMOVAL OR CAPPING ANY LIVE UTILITY LINE.
- 5. ROUGH GRADE SITE.
- 6. CONSTRUCT STORMWATER FACILITIES, SEWER, ELECTRIC AND DOMESTIC WATER SERVICES.
- 7. CONSTRUCT BUILDING.
- 8. CONSTRUCTION DRIVEWAY AND PARKING AREA.
- 9. APPLY T.E.S.C. COVER AND STABILIZATION MEASURES AS DESCRIBED ON THESE PLANS AND AS REQUIRED FOR STORMWATER RUNOFF COMPLIANCE.
- 10. T.E.S.C. MEASURES SHALL REMAIN UNTIL SITE CONSTRUCTION IS COMPLETED AND SITE IS STABILIZED AND APPROVAL IS OBTAINED FROM THE CONTRACTING OFFICER.

KEY NOTES:

- 1 DEMOLISH EXISTING WELL HOUSE, INCLUDING FOUNDATION, AND WELL HOUSE CONCRETE PADS AND APRONS. ABANDON EXISTING SAGE WELL II IN ACCORDANCE WITH DEPARTMENT OF HEALTH AND STATE OF WASHINGTON RULES (WAC 173-160-381). COORDINATE DEMOLITION WITH UTILITY OWNERS FOR WATER, ELECTRICAL AND COMMUNICATION. RESTORE SURFACE WITH NATIVE VEGETATION
- 2 ABANDON IN PLACE EXISTING UTILITIES. COORDINATE WITH UTILITY OWNER.
- 3 PROTECT AND PRESERVE EXISTING WATER LINE.
- 4 PROTECT EXISTING COMMUNICATION VAULTS. SEE DRAWING C-02.
- 5 PRESERVE AND PROTECT EXISTING TREES. IF ANY ROOT OR BRANCH PRUNING IS REQUIRED, COORDINATE WITH JBLM FORESTRY BRANCH FOR REQUIREMENTS BEFORE PROCEEDING.

AMERICAN WATER
Military Services

BOWEN COLLINS
ASSOCIATES


Joint Base Lewis-McChord



90% REVIEW


NOT FOR CONSTRUCTION
FOR REVIEW ONLY

VERIFY SCALE		REVIEW	
BAR IS ONE INCH ON ORIGINAL DRAWING		CHECKED	APPROVED
DESIGN J.O./R.G.		R. ROCHA	J. OLDHAM
DRAWN R. GARCIA			

DEMOLITION AND EROSION CONTROL - PLAN	
CIVIL	PROJECT NUMBER 427-22-03
DATE: DECEMBER 2023	




- KEY NOTES:
- 1. INSTALL BEND AS SHOWN OR GRADUALLY DEFLECT PIPE AT JOINTS TO MAINTAIN ALIGNMENT, SEE DRAWING NO. G-04 FOR NOTES.
 - 2. SEE DRAWINGS NO. M-01, M-02 AND M-03.
 - 3. INSTALL THRUST BLOCK PER  MSG-W-08
 - 4. WATER SERVICE AND CURB STOP FOR SHOWER AND WATER QUALITY SAMPLING. SEE PLUMBING DRAWINGS AND AND DETAIL  SIM.
 - 5. FUTURE WATER SERVICE CONNECTION BY OTHERS.
 - 6. LOCATE AS DIRECTED BY OWNER



AMERICAN WATER
Military Services

Joint Base Lewis-McChord



BOWEN COLLINS
ASSOCIATES

90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY			
NO.	DATE	REV. BY	DESCRIPTION

VERIFY SCALE
BAR IS ONE INCH ON ORIGINAL DRAWING

REVIEW
CHECKED R. ROCHA
APPROVED J. OLDHAM

DESIGN
DESIGN R. GARCIA
DRAWN R. GARCIA

CIVIL
SITE UTILITY
PROJECT NUMBER 427-22-03
DATE: DECEMBER 2023



DRAWING NO.
C-03
SHEET 08 OF 60

YARD PIPING COORDINATES			
POINT NO.	NORTHING	EASTING	DESCRIPTION
500	658492.46	1140082.31	PI 12-IN WATERLINE
501	658428.55	1140100.39	CL 12INX6IN TEE
502	658428.55	1140082.31	PI 12-IN WATERLINE
503	658428.55	1140147.41	PI 12-IN WATERLINE
504	658407.71	1140168.25	PI 12-IN WATERLINE
505	658407.71	1140187.74	PI 12-IN WATERLINE
506	658435.27	1140326.29	PI 12-IN WATERLINE
507	658435.27	1140475.75	PI 12-IN WATERLINE
508	658386.94	1140475.81	CONNECT TO EXISTING WATER LINE (FIELD VERIFY)

150TH STREET

PLAN

IMAGE: HEXAGON



- GRADING, TOPSOIL PLACEMENT AND COMPACTED SOILS NOTES:**
FINISH SUBGRADE AND TOPSOIL PLACEMENT AND GRADING SHALL CONSIST OF THE FOLLOWING:
- PREPARE SUBGRADE BY ROUGH GRADING AND REMOVING ALL IRREGULARITIES AND DEBRIS, THEN TILL AND SCARIFY SUBSOIL TO A DEPTH OF 6 INCHES BEFORE PLACING COMPOST MATERIAL AND TOPSOIL. SUBGRADE SURFACE SHALL NOT BE SMOOTH, BUT A ROUGH SURFACE SHALL EXIST FOR A TRANSITION ZONE OF TOPSOIL TO SUBSOIL. IF AREAS OF SUBGRADE BECOME COMPACTED BEFORE TOPSOIL IS PLACED, SUBGRADE SHALL BE TILLED AGAIN BEFORE TOPSOIL PLACEMENT.
 - PLACE 6.25-INCHES OF TOPSOIL OVER ALL AREAS TO BE SEEDED, THEN PLACE 1.75-INCHES OF COMPOSTED MATERIAL. ROTOTILL COMPOST MATERIAL AND TOPSOIL.
 - AFTER TILLING, BRING AREAS TO UNIFORM GRADES BY FLOATING AND/OR HAND RAKING. IT IS BEST IF SOIL IN SEEDED AREAS HAVE SMALL RUTS AND A ROUGH SURFACE TO HOLD THE SEED. IF SLOPED, THE LINES OF THE RAKE TRACKS SHALL BE PERPENDICULAR TO THE SLOPE TO MINIMIZE EROSION.
 - REMOVE WASTE MATERIALS OVER 1" IN SIZE SUCH AS STONES, ROOTS, OR OTHER UNDESIRABLE FOREIGN MATERIALS PRIOR TO FINISH RAKING, DISHING, DRAGGING, AND SMOOTHING SOIL READY FOR PLANTING.
 - THE FINAL SOIL MIXTURE SHOULD FOLLOW COMPOSITION AND HYDRAULIC CONDUCTIVITY STANDARDS DETERMINED BY THE STORMWATER MANAGEMENT MANUAL FOR WESTERN WASHINGTON.
 - COMPOST UTILIZED SHALL CONSIST OF COMPOSED LEAVES AND YARD GRASS. COMPOST SHALL MEET THE REQUIREMENTS IN THE SPECIFICATIONS.
 - AREAS TO BE SEEDED ARE DESIGNATED ON SHEET C-02 FOR COMPOST AMENDED VEGETATION STRIPS (CAVFS) AND WILL BE SEEDED WITH THE SEED MIX SHOWN ON SHEET C-05. SEED MIX SHALL BE SUPPLIED ON A PURE LIVE SEED (PLS) BASIS AND PROVIDE FULL COVERAGE OF DESIGNATED SEEDING AREA.
 - SEEDED AREAS SHALL ONLY BE HYDROSEED WITH TACKIFIER AND MULCH. CONTRACTOR TO REFERENCE LANDSCAPE SPECIFICATIONS FOR HYDROSEED METHODS.
 - NO GRADING OR SOIL PLACEMENT SHALL BE UNDERTAKEN WHEN SOILS ARE WET OR FROZEN. SEEDING, FERTILIZING, OR MULCHING WILL NOT BE PERMITTED WHEN WIND VELOCITIES EXCEED 5 MILES PER HOUR OR WHEN THE GROUND IS FROZEN, UNDULY WET, OR WHEN TEMPERATURES EXCEED 75°F.
 - AFTER THE SEEDING AREAS ARE ESTABLISHED THEY SHALL BE FERTILIZED WITH MILORGANITE FERTILIZER. SEEDING AREAS TO BE ESTABLISHED TO A UNIFORM COVERAGE OF 60 PERCENT AT THE END OF THE FIRST GROWING SEASON, BUT PRIOR TO FINAL RELEASE OF CONTRACTOR WARRANTY. AREAS THAT ARE BELOW 60 PERCENT COVERAGE SHALL BE RE-SEEDED.
- COMPOST AMENDED VEGETATION STRIP (CAVFS) NOTES:**
- CHANGES TO VEGETATION DESIGN OR METHODOLOGY MUST BE SUBMITTED TO THE ENGINEER FOR APPROVAL.
 - CONTRACTOR SHALL CONFORM TO ALL APPLICABLE STATE AND CITY/COUNTY CODES.
 - LANDSCAPE WORK, INCLUDING SEEDING, WEEDING, RE-SEEDED, AND FERTILIZATION SHALL BE UNDER WARRANTY AND MAINTAINED BY CONTRACTOR FOR ONE YEAR AFTER SUBSTANTIAL COMPLETION HAS BEEN ISSUED AND ALL PUNCH LIST ITEMS RELATED TO CAVFS WORK FROM SUBSTANTIAL COMPLETION HAVE BEEN COMPLETED.
 - SEE NOTES ON HYDROSEEDING ON SHEET G-05 FOR SEEDING WINDOWS.
 - TOPSOIL SHALL MEET STANDARDS REQUIRED BY THE STORMWATER MANAGEMENT MANUAL FOR WESTERN WASHINGTON AND BE IN CONFORMANCE WITH THE SPECIFICATIONS. ALL LABORATORY SOIL TESTING SHALL BE ORDERED AND PAID FOR BY THE CONTRACTOR.

Sage Well II Replacement - BC&A CAVFS Seed Mix						
SEED NO.	SPECIES NAME		Number of Seeds per Pound (LBS)	SEED		
	BOTANICAL NAME	COMMON NAME		Pounds (LBS) of Pure Live Seed (PLS)/Acre	Percentage of Seed mixture	Number of Seeds (PLS/Sq. Foot)
	Wetland Mix					
1	Bromus vulgaris	Columbia Brome	108,000	8.00	17.96%	20
2	Deschampsia cespitosa	Tufted Hairgrass	2,000,000	0.25	10.39%	11
3	Symphyotrichum chilense	Pacific Aster	2,668,000	1.00	55.44%	61
4	Triticum aestivum x Secale cereale	Triticale	13,000	60.00	16.21%	18
TOTALS =				69.25	100.00%	110

AMERICAN WATER
Military Services

Joint Base Lewis-McChord

BOWEN COLLINS
ASSOCIATES

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

90% REVIEW

VERIFICATION SCALE
BAR IS ONE INCH ON
ORIGINAL DRAWING



DESIGN
J. OLDHAM
DRAWN
R. GARCIA

REVIEW
R. ROCHA
CHECKED
J. OLDHAM
APPROVED
J. OLDHAM

DESIGN
J. OLDHAM
DRAWN
R. GARCIA








PROJECT
NUMBER
427-22-03
DATE
DECEMBER 2023

DRAWING NO.
C-05
SHEET 10 OF 60




- NOTES:**
1. FOR NON-SENSORED FENCES, DETAILS SHOWN ARE TO CLARIFY REQUIREMENTS AND ARE NOT INTENDED TO LIMIT OTHER TYPE OF FENCE SECTIONS AND METHODS OF INSTALLATION WHICH COMPLY WITH THE SPECIFICATIONS.
 2. SWING GATES SHALL BE CONSTRUCTED WITH DROP RODS, PADLOCKS, LATCH ASSEMBLY AND GATE KEEPERS EXCEPT AS NOTED.
 3. ALL GATE FRAMES SHALL MEET THE MINIMUM REQUIREMENTS OF ASTM F900 1.90" NOMINAL (ROUND) OR 2.00" NOMINAL (SQUARE). GATE FRAMES SHALL BE OF WELDED CONSTRUCTION OR SHALL BE ASSEMBLED USING HEAVY FITTINGS. — CONTRACTOR'S OPTION A WELDED HORIZONTAL BRACE MAY BE USED IN LIEU OF TRUSS RODS TO BRACE ALL-WELDED GATE FRAMES. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROPER RIGID CONSTRUCTION OF ALL GATES SUPPLIED.
 4. GATES SHALL BE DESIGNATED AS FOLLOWS:
 - FENCE TYPE — FE5, FE6, ETC.
 - FENCE HEIGHT — INCHES
 - TYPE OPENING — SO (SINGLE)
 - DO (DOUBLE)
 - HINGE — RA (STANDARD)
 - HO (OFFSET)
 - OPENING — FEET (CLEAR OPENING BETWEEN GATE POSTS)
- EXAMPLES: FE6-84-DO-RA-24
FE5-48-SO-HO-6

GATE POST SCHEDULE	
GATE LEAF WIDTH (NOMINAL)	OUTSIDE DIMENSION (NOMINAL)
6' OR LESS	2.875" OD 2.5" SQ
GREATER THAN 6' TO 12'	4.0" OD
GREATER THAN 12' TO 18'	6.625" OD
MORE THAN 18'	8.625" OD



FE6 CHAINLINK SECURITY GATE DETAILS




NOTES:

1. CENTER METER IN BOX, MIN 6" CLEARANCE ON ALL SIDES.
2. TRENCH, INSTALL, AND BACKFILL SERVICE LINE IN ACCORDANCE WITH AW SPECIFICATIONS.
3. POINT OF DEMARCATION FOR SERVICE LINE OWNERSHIP PER PRIME CONTRACT BETWEEN AW AND GOVERNMENT.
4. SERVICE LINE MATERIALS SHALL MEET AW SPECIFICATIONS.
5. PROVIDE TRACER WIRE ALONG WATER SERVICE LINE. TRACER WIRE SHALL EXTEND INTO THE CURB BOX AND METER PIT AND TERMINATE IN THE METER PIT.
6. IF WATER SERVICE BETWEEN MAIN AND WATER METER IS REPLACED WITH NON-METALLIC PIPING, THERE SHALL BE A MINIMUM LENGTH OF TEN (10) FT OF METALLIC PIPING BETWEEN THE BUILDING STRUCTURE AND METER PIT TO MAINTAIN PROPER GROUNDING OF BUILDING'S ELECTRICAL SYSTEM.

2" WATER SERVICE INSTALLATION


REVISIONS	AMERICAN WATER MILITARY SERVICES GROUP CIVIL 2" WATER SERVICE INSTALLATION DETAIL
5/10 - MSG EDITS	
1/12 - MSG EDITS	
6/13 - MSG EDITS	
7/14 - MSG EDITS	
1/16 - MSG EDITS	



GATE VALVE AND VALVE BOX

DEPTH COVER	LOCATION
36"	AL, IL, IN, MD, OK, KS, TX, CA & VA
42"	NJ
48"	UT

REVISIONS	AMERICAN WATER MILITARY SERVICES GROUP CIVIL GATE VALVE AND VALVE BOX DETAIL
6/13 - MSG EDITS	
7/14 - MSG EDITS	
1/16 - MSG EDITS	




CONCRETE VALVE BOX PAD DETAIL

NOTE:

1. IF PAD IS NOT TO BE POURED IMMEDIATELY AFTER VALVE BOX INSTALLATION, HOLE SHOULD BE BACKFILLED TO GRADE WITH 3/4" CLEAN CRUSHED STONE BACKFILL.

REVISIONS	AMERICAN WATER MILITARY SERVICES GROUP CIVIL CONCRETE VALVE BOX PAD DETAIL
REV 1 - 6/22/10	
6/13 - MSG EDITS	
7/14 - MSG EDITS	
1/16 - MSG EDITS	




TYPICAL TRACER WIRE VALVE BOX INSTALLATION

NOTES:

1. TRACER WIRE SHALL BE TIED INTO EVERY VALVE, BLOW-OFF, A/V, AND OTHER DEVICES OR CHANGES IN DIRECTION. PROVIDE ONE TRACER WIRE TEST STATION AT MINIMUM INTERVALS AS PRESCRIBED IN AMERICAN WATER'S DESIGN GUIDE.
2. TRACER LEADS SHALL BE INSTALLED IN APPROVED CURB BOXES OR TRACER WIRE ACCESS BOXES. ACCESS BOX STYLE (LIGHT DUTY, DRIVEWAY, OR ROADWAY) SHALL BE DETERMINED BY BOX LOCATION.
3. CURB BOXES SHALL BE INSTALLED FLUSH WITH GROUND AND LOCATED OVER PIPE LINE TO WHICH TRACER LEAD IS ATTACHED.
4. TRACER LEADS SHALL HAVE ADEQUATE SLACK THROUGHOUT THE INSTALLATION TO REDUCE BREAKAGE FROM PULLING.
5. TRACER WIRE THAT EXTENDS A MIN OF 2' ABOVE GRADE SHALL BE COILED IN THE VALVE BOX AND WIRES SHALL BE PROPERLY CONNECTED TO THE VALVE BOX PER MANUFACTURERS SPECIFICATIONS. ALL TRACER WIRES SHALL BE OF #12 TW SOLID COPPER WIRE.
6. EARTH AROUND VALVE BOXES SHALL BE THOROUGHLY COMPACTED AT THE TIME OF INSTALLATION. SUBCONTRACTOR SHALL MAKE ADJUSTMENTS FOR FINAL GRADING, SODDING, PAVING, AND RESTORATION AT THE COMPLETION OF EACH PROJECT. SUBCONTRACTOR SHALL PROTECT THE LEADS, BOXES, AND ALL TRACER WIRES THROUGHOUT THE PROJECT. SUBCONTRACTOR SHALL BE RESPONSIBLE FOR ALL WATER AND WASTEWATER UTILITY LOCATIONS THROUGHOUT THE PROJECT AND UNTIL APPROVED AND ACCEPTED BY AMERICAN WATER.
7. PROVIDE ONE TRACER LEAD IN EACH DIRECTION UNLESS OTHERWISE NOTED.
8. CONTRACTOR SHALL CONFIRM THE REQUIREMENT FOR CONCRETE COLLARS WITH AW PRIOR TO CONSTRUCTION.

TRACER WIRE INSTALLATION




TYPICAL TRACER WIRE ACCESS BOX INSTALLATION NON-VALVE LOCATIONS

NOTE:

1. FOR USE WITH THE SANITARY SEWER SYSTEM AND OTHER APPLICATIONS WHERE VALVE BOXES ARE NOT TYPICALLY PRESENT.

REVISIONS	AMERICAN WATER MILITARY SERVICES GROUP CIVIL TRACER WIRE INSTALLATION DETAIL
1/12 - MSG EDITS	
6/13 - MSG EDITS	
7/14 - MSG EDITS	
1/16 - MSG EDITS	




FIRE HYDRANT

NOTES:

1. ALL HYDRANTS SHALL STAND PLUMB AND SHALL HAVE THE PUMPER NOZZLE FACING THE CURB.
2. HYDRANT BOWNTIES SHALL BE PAINTED TO INDICATE AVAILABLE FIRE FLOW IN ACCORDANCE WITH AMERICAN WATER SPECIFICATIONS.
3. IF HYDRANT LATERAL IS NOT RESTRAINED, CONTRACTOR SHALL PROVIDE A THRUST BLOCK BEHIND HYDRANT SHOULDER.
4. RESTRAIN ALL JOINTS ON HYDRANT TEE, HYDRANT VALVE, AND HYDRANT LEAD.
5. AMERICAN WATER RESERVES THE RIGHT TO HAVE STRICT COMPLIANCE WITH THIS DETAIL IN THE EVENT THAT FIELD CONDITIONS OR ON-WORK REQUIRE A WAIVER.
6. THE DESIGN ENGINEER SHALL DETERMINE IF BOLLARDS ARE REQUIRED.

REVISIONS	AMERICAN WATER MILITARY SERVICES GROUP CIVIL FIRE HYDRANT DETAIL
1/16 - MSG EDITS	



THRUST BLOCK DETAIL

* SURFACE AREA OF BEARING SOIL IS PROVIDED FOR 200 PSI MAXIMUM PRESSURE (INCLUDING SURGE) AND 2000 PSF SOIL BEARING. IF PRESSURE IS HIGHER OR SOIL BEARING IS POTENTIALLY LOWER, CONSULT THE ENGINEER FOR ADJUSTMENTS.

NOTES:

1. COVER OVER TOP OF PIPE SHALL BE BELOW THE FROST LINE OR 30" MINIMUM, 72" MAXIMUM ACCORDING TO REGULATORY REQUIREMENTS. IF GRADING PLANS RECEIVED BY THE ENGINEER/OWNER WITH THE REQUEST FOR WATER MAIN LAYOUT INDICATE ADJUSTMENTS TO EXISTING GRADE, THEN PIPE SHALL BE INSTALLED TO MEET MINIMUM AND MAXIMUM COVER FROM PROPOSED GRADES SHOWN ON THE SAID PLANS.
2. THRUST BLOCKS SHALL BE BUILT AGAINST UNDISTURBED SOIL WITH ADEQUATE BACKING TO PREVENT MOVEMENT OF FITTING.
3. NO THRUST BLOCKS TO BE PLACED IN SEWER LATERAL DITCHES.
4. THRUST BLOCKING MUST FIT WITHIN THE EASEMENT.
5. IN SOME CASES, ADDITIONAL RESTRAINT MAY BE REQUIRED BASED ON 150 PSI STATIC PRESSURE, PLUS 50 PSI WATER HAMMER AND 2000 PSF SOIL BEARING.
6. POLYETHYLENE ENCASEMENT IS REQUIRED ON ALL D.J. PIPE AND FITTINGS.
7. THRUST BLOCKING SHALL BE PERFORMED SUCH THAT PIPE JOINTS AND BOLTS ARE ACCESSIBLE.
8. THRUST BLOCKING SHALL BE ALLOWED BETWEEN CONCRETE AND BOLTS FOR FUTURE MAINTENANCE.
9. ALL ANCHOR BOLTS SHALL BE STAINLESS STEEL, MINIMUM 3/4" DIAMETER.
10. ALL M.J. AND FLU. FITTINGS TO RECEIVE THRUST BLOCKS SHALL BE WRAPPED IN POLYWRAP. CONTRACTOR SHALL ENSURE THAT POLYWRAP EXTENDS FAR ENOUGH BEYOND THE FITTING TO ENCLOSE ALL BOLTS WITHIN THE POLYWRAP.
11. THRUST BLOCKING DETAILS ARE SHOWN HERE FOR TYPICAL INSTALLATIONS. IN SOME CASES, ADDITIONAL RESTRAINT MAY BE REQUIRED.
12. PORTLAND CEMENT CONCRETE USED FOR THRUST BLOCKS SHALL BE MIN 3000 PSI CONCRETE.
13. FOR UNSTABLE SOIL CONDITIONS, CHECK WITH ENGINEER FOR THRUST BLOCK DIMENSIONS.
14. FOR MAIN SIZES GREATER THAN 16", SEE ENGINEER FOR THRUST BLOCK DIMENSIONS.

REVISIONS	AMERICAN WATER MILITARY SERVICES GROUP CIVIL THRUST BLOCK DETAIL
1/16 - MSG EDITS	

90% REVIEW

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

VERIFY SCALE
SAGE WELL II REPLACEMENT
JBLM WASHINGTON


DESIGN
STD
DRAWN STD

REVIEW
R. ROCHA

APPROVED
J. OLDHAM



DRAWING NO.
C-08

SHEET 13 OF 60



CODE PLAN

SCALE: 1/4" = 1'-0"




1
A-01

CODE ANALYSIS 2021 IBC

OCCUPANCY: F-1 WITH ACCESSORY STORAGE	STORIES: 1	CONSTRUCTION TYPE: V-B	NON-SPRINKLERED												
BUILDING DESCRIPTION THE WELL BUILDING IS AN UNOCCUPIED EQUIPMENT BUILDING USED TO STORE PUMPS SUPPORTING EQUIPMENT, AND CHEMICALS FOR WATER TREATMENT.															
CODE REVIEW INFORMATION APPLICABLE CODES, INCLUDE BUT ARE NOT LIMITED TO: 2021 INTERNATIONAL BUILDING CODE 2021 INTERNATIONAL FUEL GAS CODE 2021 INTERNATIONAL MECHANICAL CODE 2021 UNIFORM PLUMBING CODE 2021 INTERNATIONAL ENERGY CONSERVATION CODE 2021 INTERNATIONAL FIRE CODE 2020 NATIONAL ELECTRICAL CODE 2024 NFPA 101, LIFE SAFETY CODE ARCHITECTURAL BARRIERS ACT (ABA) 2010 ADAAG GROSS BUILDING SQUARE FEET: 676 SF PER SECTION 311.1.1 - ACCESSORY STORAGE SPACES 1. A ROOM OR SPACE USED FOR STORAGE PURPOSES THAT IS ACCESSORY TO ANOTHER OCCUPANCY SHALL BE CLASSIFIED AS PART OF THAT OCCUPANCY. PER SECTION 414.2. CONTROL AREA 1. THE INTENT IS TO CONSIDER THE ENTIRE BUILDING AS A SINGLE CONTROL AREA FOR STORING HAZARDOUS MATERIALS IN A CLOSED-USE SYSTEM. THE HAZARDOUS MATERIAL QUANTITIES WILL NOT EXCEED THAN THE MAXIMUM QUANTITIES ALLOWED PER TABLES 307.1(1), 307.1(2) AND 414.2.2 FOR ONE STORY ABOVE GRADE. PER TABLE 504.3 - ALLOWABLE BUILDING HEIGHT IN FEET ABOVE GRADE PLANE ALLOWABLE BUILDING HEIGHT: 40' (15'-3" T.O. ROOF - COMPLIES) PER TABLE 504.4 - ALLOWABLE NUMBER OF STORIES ABOVE GRADE PLANE ALLOWABLE STORIES: 1 (1 STORY- COMPLIES) PER TABLE 506.2 - ALLOWABLE BUILDING AREA ALLOWABLE AREA F-1: 8,500 SF PER STORY (ACTUAL AREA = 676 SF - COMPLIES) PER SECTION 508.2.4 - SEPARATION OF OCCUPANCIES NO SEPARATION IS REQUIRED BETWEEN ACCESSORY OCCUPANCIES AND THE MAIN OCCUPANCY. (NOT REQUIRED, SEE SECTION 414.2.1 FOR CONTROL AREA SEPARATION REQUIREMENTS) PER SECTION 602 - CONSTRUCTION CLASSIFICATION TABLE 601 - TYPE V-B <table><tr><th>BUILDING ELEMENT</th><th>HOURS</th></tr><tr><td>PRIMARY STRUCTURAL FRAME</td><td>0</td></tr><tr><td>BEARING WALLS (INT/EXT)</td><td>0</td></tr><tr><td>NON-BEARING INT WALLS</td><td>0</td></tr><tr><td>FLOOR CONSTRUCTION</td><td>0</td></tr><tr><td>ROOF CONSTRUCTION</td><td>0</td></tr></table> PER SECTION 903.2.4 - F-1 GROUP AN AUTOMATIC SPRINKLER SYSTEM SHALL BE PROVIDED THROUGHOUT ALL BUILDINGS CONTAINING A GROUP F-1 OCCUPANCY WHERE ONE OF THE FOLLOWING CONDITIONS EXISTS: 1. FIRE AREA EXCEEDS 12,000 SF (676 SF < 12000 SF - NOT REQUIRED) PER TABLE 1004.5 - OCCUPANT LOAD FACTOR PER OCCUPANT ACCESSORY STORAGE AREAS, MECHANICAL EQUIPMENT ROOM - 300 GROSS TOTAL OCCUPANT LOAD = 676 SF / 300 = 3 OCCUPANTS PER SECTION 1005 - MEANS OF EGRESS SIZING 1005.3.2 - OTHER EGRESS COMPONENTS (3 OCCUPANTS) X (0.2") = 0.6" (REQUIRED); 152" (PROVIDED - COMPLIES) 3 EXITS PROVIDED PER TABLE 1006.2.1 - SPACES WITH ONE EXIT OR EXIT ACCESS DOORWAY F OCCUPANCY: 49 MAX. OCCS.; OL ≤ 30 = 75' MAX. COMMON PATH OF EGRESS TRAVEL DISTANCE PER TABLE 1017.2 - EXIT ACCESS TRAVEL DISTANCE = F-1 = 200' MAX. PER SECTION 1505 - FIRE CLASSIFICATION TABLE 1505.1 - MIN. ROOF COVERING CLASSIFICATION FOR TYPES OF CONSTRUCTION ROOF COVERING CLASSIFICATION: C PER SECTION 2902.1 MINIMUM NUMBER OF PLUMBING FIXTURES. PLUMBING FIXTURES NEED NOT BE PROVIDED FOR UNOCCUPIED BUILDINGS. THE BUILDING USE IS AN UNOCCUPIED EQUIPMENT BUILDING, NO PLUMBING FIXTURES ARE REQUIRED.				BUILDING ELEMENT	HOURS	PRIMARY STRUCTURAL FRAME	0	BEARING WALLS (INT/EXT)	0	NON-BEARING INT WALLS	0	FLOOR CONSTRUCTION	0	ROOF CONSTRUCTION	0
BUILDING ELEMENT	HOURS														
PRIMARY STRUCTURAL FRAME	0														
BEARING WALLS (INT/EXT)	0														
NON-BEARING INT WALLS	0														
FLOOR CONSTRUCTION	0														
ROOF CONSTRUCTION	0														

CODE PLAN LEGEND



FIRE EXTINGUISHER DETAIL

SCALE: 1" = 1'-0"


2
A-01

CODE ANALYSIS NFPA 101

OCCUPANCY: NEW INDUSTRIAL	STORIES: 1	CONSTRUCTION TYPE: V-000	NON-SPRINKLERED
PER 6.12.1 - INDUSTRIAL			
PER 6.2.2.3 - CLASSIFICATION OF HAZARD CONTENT - ORDINARY			
PER 40.1.2.1.2 - SPECIAL-PURPOSE INDUSTRIAL OCCUPANCY SHALL INCLUDE ALL OF THE FOLLOWING:			
1.INDUSTRIAL OCCUPANCIES THAT CONDUCT ORDINARY OR LOW HAZARD INDUSTRIAL OPERATIONS IN BUILDINGS INBUILDINGS OF CONVENTIONAL DESIGN THAT ARE USABLE FOR VARIOUS TYPES OF INDUSTRIAL PROCESSES.			
PER 40.1.6 - MINIMUM CONSTRUCTION REQUIREMENTS (NO REQUIREMENTS)			
PER 40.2.5.1 - ARRANGEMENT OF MEANS OF EGRESS:			
DEAD-END CORRIDOR = 50'			
COMMON PATH OF TRAVEL (NON-SPRINKLERED) = 50'			
PER 40.2.6.1 - MAXIMUM TRAVEL DISTANCE TO EXITS (NON-SPRINKLERED) = 300'			
PER NFPA 220, TABLE 4.1.1 - V-000			
BUILDING ELEMENT		HOURS	
PRIMARY STRUCTURAL FRAME		0	
BEARING WALLS (INT/EXT)		0	
NON-BEARING INT WALLS		0	
FLOOR CONSTRUCTION		0	
ROOF CONSTRUCTION		0	



Joint Base Lewis-McChord



NOT FOR CONSTRUCTION FOR REVIEW ONLY			
NO.	DATE	REV. BY	DESCRIPTION


VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING	

REVIEW	
CHECKED	SR
APPROVED	SR

DESIGN	
DESIGN	AR
DRAWN	AR

SAGE WELL II REPLACEMENT JBLM WASHINGTON	


DRAWING NO. A-01	
DATE: DECEMBER 2023	PROJECT NUMBER 427-22-03



- 1 FLOOR DRAIN, SEE PLUMBING AND STRUCTURAL
2. WALL LOUVER, SEE 4/A-05, COORDINATE WITH MECHANICAL
3. CONCRETE CURB, SEE STRUCTURAL

ARCHITECTURAL	FLOOR PLAN	DATE: DECEMBER 2023	PROJECT NUMBER 427-22-03
---------------	------------	---------------------	--------------------------

DRAWING NO.
A-02




UNDER NO CIRCUMSTANCES CAN THE PIPE PENETRATE OR COME WITHIN 4" OF THE STANDING SEAM METAL PANEL ROOF PANEL SEAM

PRE-MOLDED PIPE FLASHING W/ALUMINUM BASE SET IN CONT. BEAD OF URETHANE SEALANT - BOOT TO MATCH COLOR OF ROOFING

NOTE: USE METAL JACK SLEEVES AT ALL PIPE PENETRATION LOCATIONS

GASKETED FASTENER - INSTALL PER MANF. RECOMMENDATIONS AND INSTRUCTIONS




NOTES: APPLY LAP SEALANT BETWEEN PENETRATION AND PRE-MOLDED PIPE FLASHING PRIOR TO INSTALLATION OF CLAMPING RING.

PIPE SHOULD EXTEND 1'-0" MINIMUM ABOVE ROOF SURFACE


SEE ROOF PLAN AND PLUMBING DRAWINGS FOR PENETRATION LOCATIONS.

TYPICAL VENT PENETRATION DETAIL

SCALE: 3" = 1'-0"




2
A-03



TYPICAL RIDGE VENT DETAIL

SCALE: 3" = 1'-0"



3
A-03

GENERAL NOTES

- SEE STRUCTURAL DRAWINGS FOR ROOF MEMBERS DIMENSIONS AND LOCATIONS.
- COORDINATE WITH MECHANICAL, PLUMBING AND ELECTRICAL DRAWINGS FOR ADDITIONAL ROOF PENETRATIONS INFORMATION.

PLAN LEGEND


- KEYNOTE
- DIRECTION OF VIEW, IF APPLICABLE
- DRAWING NUMBER
- SHEET WHERE DRAWN
- DIMENSION TO FACE OF FRAMING

MATERIAL LEGEND

- STANDING SEAM METAL PANEL
- AEP SPAN - COOL WEATHERED COPPER


KEYNOTES

- OUTLINE OF WALL BELOW, SEE FLOOR PLAN FOR WALL LOCATIONS, SEE STRUCTURAL FRAMING PLAN FOR OVERHANG FRAMING MEMBERS DIMENSIONS.
- METAL GUTTERS AND DOWNSPOUT, SEE 4/A-03
- RIDGE CAP, SEE DETAIL 3/A03



ROOF PLAN

SCALE: 1/4" = 1'-0"



1
A-03

ROOF TYPE DETAIL

SCALE: 1" = 1'-0"


STANDING SEAM METAL ROOF PANEL, SEE SPECIFICATION 074113.16

BUILDING WRAP UNDERNEATH STANDING SEAM METAL ROOF PANEL, HI TEMP. SELF ADHERED UNDERLAYMENT AT EAVES AND VALLEYS AS REQUIRED BY CODE - SEE SPECIFICATION 074113.16

ROOF DECK, SEE STRUCTURAL

R-49 BATT INSULATION - SEE SPECIFICATION 072100

VAPOR BARRIER - SEE SPECIFICATION 072600




STANDING SEAM METAL PANEL ROOF ASSEMBLY

HEX HEAD STAINLESS STEEL THREADED FASTENER HEAD - COLOR TO MATCH METAL

GUTTER GUARD
GUTTER - PRE FINISHED 24 GA GALV STEEL

GUTTER DIMENSIONS
SMACNA GUTTER PROFILE 'B'



RE: ROOF PLAN FOR GUTTER LOCATIONS.
RE: EXTERIOR ELEVATIONS FOR DOWNSPOUT LOCATIONS.

GUTTER STRAP - PRE FINISHED 24 GA GALV STEEL 1" WIDE AT 24" O.C.


RIVETS AT 1" O.C. ALL SIDES - COLOR TO MATCH METAL

FULL BED OF NON CURING SEALANT IN JOINT - TYP ALL AROUND
DROP TUBE
PRE FINISHED 24 GA GALV STEEL DOWNSPOUT (4"x4")

STRAP AND DROP TUBE

GUTTER DIMENSIONS / STRAP AND DROP TUBE

SCALE: 1 1/2" = 1'-0"



4
A-03


NOT FOR CONSTRUCTION
FOR REVIEW ONLY

SAGE WELL II REPLACEMENT
JBLM WASHINGTON

ARCHITECTURAL
ROOF PLAN AND DETAILS

DRAWING NO.
A-03


SHEET 16 OF 60



SOUTH ELEVATION

SCALE: 1/4" = 1'-0"


1
A-04



WEST ELEVATION

SCALE: 1/4" = 1'-0"


2
A-04



NORTH ELEVATION

SCALE: 1/4" = 1'-0"

3
A-04



EAST ELEVATION

SCALE: 1/4" = 1'-0"

4
A-04

GENERAL NOTES

- A. SEE CIVIL, STRUCTURAL, MECHANICAL, PLUMBING AND ELECTRICAL DRAWINGS FOR ADDITIONAL REQUIREMENTS.
B. COORDINATE ALL PENETRATIONS WITH RESPECTIVE TRADES WHICH INCLUDE SLABS, WALLS AND ROOF.

MATERIAL LEGEND

- BRICK VENEER
MUTUAL MATERIALS - CHESTNUT
STANDING SEAM METAL PANEL
AEP SPAN - COOL WEATHERED COPPER

KEYNOTES

1. METAL GUTTER - SEE DETAIL 4/A03.
2. DOWNSPOUT TO DAYLIGHT ON GRADE.
3. LIGHT FIXTURE, SEE ELECTRICAL.
4. LOUVER, SEE 4/A-05 AND MECHANICAL.

90% REVIEW

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

SAGE WELL II REPLACEMENT

EXTERIOR ELEVATIONS

DRAWING NO.
A-04

SHEET 17 OF 60

VERIFY SCALE
BAR IS ONE INCH ON
ORIGINAL DRAWING

REVIEW
CHECKED SR
APPROVED SR

DESIGN
DESIGN AR
DRAWN AR

PROJECT
NUMBER 427-22-03
DATE: DECEMBER 2023

NOT FOR CONSTRUCTION FOR REVIEW ONLY			
NO.	DATE	REV. BY	DESCRIPTION





VERIFY SCALE
BAR IS ONE INCH ON ORIGINAL DRAWING

REVIEW
CHECKED SR
APPROVED SR

DESIGN
DESIGN AR
DRAWN AR


BUILDING SECTION & DETAILS
ARCHITECTURAL
PROJECT NUMBER 427-22-03
DATE: DECEMBER 2023

DRAWING NO.
A-05
SHEET 18 OF 60



GENERAL NOTES

- A. SEE CIVIL, STRUCTURAL, MECHANICAL, PLUMBING AND ELECTRICAL DRAWINGS FOR ADDITIONAL REQUIREMENTS.
- B. COORDINATE ALL PENETRATIONS WITH RESPECTIVE TRADES WHICH INCLUDE SLABS, WALLS AND ROOF.
- C. SEE STRUCTURAL DRAWINGS FOR SLAB CONSTRUCTION AND DETAILS.



ROOM FINISH SCHEDULE								
ROOM NUMBER	ROOM NAME	FLOOR	BASE	WALL				ADDITIONAL NOTES
				NORTH	EAST	SOUTH	WEST	
A101	MAIN ROOM	SC	—	—	—	—	—	1
A102	CHEMICAL ROOM	SC	—	—	—	—	—	1

ROOM FINISH ABBREVIATIONS

FLOORING

SC# SEALED CONCRETE

WALL

PT-1 BASIS OF DESIGN SHERWIN WILLIAMS SW CUSTOM, MATCH #8264-10961

PT-2 BASIS OF DESIGN: FEDERAL STANDARD 595B #20062, DARK BROWN

ADDITIONAL NOTES

1. PAINT GYPSUM CEILING BOARD, PT-1

DOOR, FRAME AND HARDWARE SCHEDULE											
DOOR NUMBER	ROOM NUMBER	ROOM NAME	DOOR				FRAME		HARDWARE GROUP		
			SIZE			MTL	TYPE	MTL	TYPE		
			W	H	T						
101-1	101	MAIN ROOM	6'-0"	7'-0"	1 3/4"	IHM	B	IHM	2		1
101-2	101	MAIN ROOM	3'-8"	7'-0"	1 3/4"	IHM	A	IHM	1		2
102-1	102	CHEMICAL AREA	3'-8"	7'-0"	1 3/4"	IHM	A	IHM	1		2

ABBREVIATIONS

IHM - INSULATED HOLLOW METAL

DOOR NOTES

1. PROVIDE LOCKSET PER JBLM STANDARDS FOR EMERGENCY SERVICE ACCESS

HARDWARE GROUPS

SET 1

-LOCKSET (ENTRANCE)
-HINGES
-RIM EXIT DEVICES
-REMOVABLE CENTER MULLION
-SURFACE CLOSER
-WEATHERSTRIP
-THRESHOLD
-SWEEP
-SILENCER
-FLOOR STOP

SET 2


-LOCKSET (ENTRANCE)
-HINGES
-RIM EXIT DEVICE
-SURFACE CLOSER
-WEATHERSTRIP
-THRESHOLD
-SWEEP
-SILENCER
-FLOOR STOP

GENERAL NOTES

- A. FIELD VERIFY ALL ROUGH OPENING DIMENSIONS PRIOR TO FABRICATION AND INSTALLATION.
B. FOR FRAME TYPE LOCATIONS, SEE FLOOR PLAN SHEET A-02
C. PAINT ALL HOLLOW METAL DOORS AND FRAMES PER SPECIFICATION DIVISION 9.



KEYNOTES

1. REMOVABLE MULLION.
2. PROVIDE HAZARD COMMUNICATION DOOR SIGN ON EXTERIOR SIDE, SEE SPECIFICATION 101423.
3. PAINT HOLLOW METAL DOORS AND FRAMES, PT-2
4. PROVIDE 5/16" CLEAR GLAZING REINFORCED WITH WIRE MESH.





HOLLOW METAL DOOR HEAD

SCALE: 1 1/2" = 1'-0"



HOLLOW METAL DOOR JAMB

SCALE: 1 1/2" = 1'-0"




HOLLOW METAL DOOR THRESHOLD

SCALE: 1 1/2" = 1'-0"




HOLLOW METAL DOOR TYPES

1/4" = 1'-0"



HOLLOW METAL FRAME TYPES

1/4" = 1'-0"



NOT FOR CONSTRUCTION
FOR REVIEW ONLY

SAGE WELL II REPLACEMENT
AMERICAN WATER
JBLM WASHINGTON

VERIFY SCALE
BAR IS ONE INCH ON
ORIGINAL DRAWING

REVIEW
CHECKED SR
APPROVED SR


DESIGN
DESIGN AR
DRAWN AR

DOOR SCHEDULE & DETAILS
ARCHITECTURAL


PROJECT
NUMBER 427-22-03
DATE: DECEMBER 2023

DRAWING NO.
A-06

SHEET 19 OF 60




ROOF PLAN
SCALE: 1/2"=1'-0"



SECTION

SCALE: 1"=1'-0"


A
S-01



SECTION

SCALE: 1"=1'-0"

B
S-01



SECTION

SCALE: 1"=1'-0"

C
S-01


90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY			
NO.	DATE	REV. BY	DESCRIPTION


VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING			
DESIGN	REVIEW	CHECKED	APPROVED
DESIGN S. COHEN			
DRAWN P. BAXTER			

STRUCTURAL SAGE WELL II SECTIONS	
DATE: DECEMBER 2023	PROJECT NUMBER 427-22-03

DRAWING NO. S-03
SHEET 22 OF 60



SECTION A
SCALE: 1-1/2"=1'-0"




SECTION B
SCALE: 1-1/2"=1'-0"

90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY				REVISIONS	
NO.	DATE	REV. BY	DESCRIPTION		

SAGE WELL II REPLACEMENT JBLM WASHINGTON			VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING	
DESIGN S. COHEN	CHECKED S. COHEN	REVIEW S. COHEN		

STRUCTURAL SAGE WELL II STRUCTURAL ROOF DETAILS		DRAWING NO. S-04	
DATE: DECEMBER 2023	PROJECT NUMBER: 427-22-03		



PLAN
SCALE: 1/2" = 1'-0"

VALVE, EQUIPMENT AND PIPING SCHEDULE			
TAG	SIZE	ENDS	DESCRIPTION
GLV-01	6"	FLG	GLOBE STYLE PUMP CONTROL VALVE WITH SOLENOID. FUSION BONDED EPOXY LINED AND COATED, ENERGIZE TO CLOSE; CLA-VAL 61-02, SST TRIM, ROUTE TO DRAIN HUB WITH 6" AIR GAP AND #14 SST SCREEN. CONNECT PRESSURE SUPPLY LINE TO SYSTEM SIDE PRESSURE. ANTI-CAVITATION TRIM, TWO LIMIT SWITCHES, SEE ELECTRICAL DRAWINGS.
GLV-02	6"	FLG	GLOBE STYLE PRESSURE RELIEF VALVE; CLA-VAL 52-03, FUSION BONDED EPOXY LINED AND COATED, SST TRIM, CRL PILOT CONTROL, CONNECT PRESSURE SENSING LINE TO SYSTEM SIDE PRESSURE, OPEN STATUS LIMIT SWITCH, SEE ELECTRICAL DRAWINGS. HIGH PRESSURE SET AT 95 PSI.
CV-01	10"	FLG	VALMATIC SERIES 7200 SURGEBUSTER CHECK VALVE WITH POSITION INDICATOR, FUSION BONDED EPOXY LINED AND COATED OR EQUAL.
FE-01	10"	FLG	MAGNETIC FLOW METER SIEMENS 5100W WITH 6580 CONFIGURATION AND WALL MOUNT TRANSMITTER, SEE DETAIL M/3149
AV-01	2"	NPT	WELL SERVICE AIR VALVE WITH THROTTLE DEVICE, VALMATIC 102ST OR EQUAL FUSION BONDED EPOXY LINED AND COATED, SEE DETAIL M/3143
AV-02	2"	NPT	COMBINATION AIR VALVE VALMATIC 202C.2, SEE DETAIL M/3143
GV-01	10"	FLG	WITH HAND WHEEL
GV-02	6"	FLG	WITH HAND WHEEL
GV-03	6"	FLG	WITH HAND WHEEL
①	1/2"	NPT	PRESSURE GAUGE AND PRESSURE SWITCH, SEE DETAIL M/3183
②	3/4"	NPT	HOSE BIB AND SMOOTH NOSE SAMPLE TAP, SEE DETAIL M/3138
③	1/2"	NPT	PRESSURE GAUGE AND PRESSURE TRANSMITTER, SEE DETAIL M/3183
④	10"	FLG	DISMANTLING JOINT ROMAC DJ400
⑤	1"	NPT	TAP FOR CHLORINE DOSING AND INJECTION ASSEMBLY, SEE DETAIL M/3167. ASSEMBLY SHALL INCLUDE CHECK VALVE, CORP STOP, INJECTION QUILL AND CHAIN.
⑥	6"	FLG	DISMANTLING JOINT ROMAC DJ400
⑦	---	---	CHLORINE ANALYZER S:CAN CHLORILYSE, FREE CHLORINE, REAGENTLESS WITH FLOWCELL, S:CAN TERMINAL AND SOFTWARE, CON: CUBE V3 D-315-OUT-MA; MOUNT ON NANO:STATION SYSTEM BACK PANEL. INCLUDE CALIBRATION FLUIDS AND REPLACEMENT COMPONENTS FOR 1 YEAR OF SERVICE. ROUTE DISCHARGE TO HUB DRAIN; SEE DRAWING P-03.
⑧	225 GAL	---	CHLORINE BULK TANK, SEE 2/M-04
⑨	20 GAL	---	CHLORINE DAY TANK, SEE 2/M-04
⑩	1"	NPT	TAP FOR POLYPHOSPHATE DOSING AND INJECTION ASSEMBLY, SEE DETAIL M/3167. ASSEMBLY SHALL INCLUDE CHECK VALVE, CORP STOP, INJECTION QUILL AND CHAIN.
⑪	1"	NPT	TAP FOR GLV-01 AND GLV-01 PRESSURE SUPPLY AND SENSING LINES, SEE DETAIL M/3167
⑫	100 GAL	---	POLYPHOSPHATE TANK AND PUMP, SEE 3/M-05

- BUILDING NOTES:
- KEY NOTES, VALVE, PIPING AND EQUIPMENT SCHEDULE ON DRAWING NO. M-01.
 - FOR CONTINUATION OF BURIED PIPING REFER TO DRAWING NO. C-03 AND C-04.
 - ALL PIPING UNDER FLOOR SLAB SHALL BE CONCRETE ENCASED, SEE STRUCTURAL DRAWINGS. DO NOT POLY-WRAP CONCRETE ENCASED PIPE.
 - ALL ABOVE GROUND MECHANICAL PIPING IS 6" OR 10" DIA. UNO. NOT ALL PIPING LESS THAN OR EQUAL TO 1" IS SHOWN.
 - ✕ - REPRESENTS LOCATION OF PIPE SUPPORTS, SEE DETAIL M/3389
 - ALL PIPING SHALL BE EPOXY COATED DUCTILE IRON UNO. COATING SYSTEM 4 PER SPECIFICATION 00 90 00.
 - CONTRACTOR SHALL COORDINATE WITH ELECTRICAL CONTRACTOR REGARDING FINAL LOCATION OF CONDUIT.
 - EXTEND CONCRETE ENCASEMENT FOR ALL PIPES BELOW THE STRUCTURE BEYOND BUILDING FOOTING. SEE STRUCTURAL DRAWINGS.
 - PIPE TAPS ON UNDERGROUND PIPES SHALL BE SADDLE TAPS. PIPE TAPS ON EXPOSED PIPING SHALL BE SADDLE TAPS UNLESS LOCATION DOES NOT ALLOW A SADDLE.
 - REFER TO CHEMICAL SCHEMATIC SHEETS FOR CHEMICAL SYSTEM PIPING REQUIREMENTS.
 - CLEARLY LABEL ALL CHEMICAL PIPING, SAMPLE LINES, AND OTHER PIPING 2" DIA AND SMALLER.
 - SUPPORT ALL PIPES AND CONDUITS PER M/3372 OR SIMILAR.

AMERICAN WATER
Military Services

BOWEN COLLINS
ASSOCIATES

Joint Base Lewis-McChord

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

AMERICAN WATER (P4-460MVA2-00003)
JBLM WASHINGTON

SAGE WELL II REPLACEMENT

DESIGN J.O./R.G.
DRAWN R. GARCIA

MECHANICAL

SAGE WELL II - PLAN

DRAWING NO.
M-01

DATE: DECEMBER 2023

PROJECT NUMBER 427-22-03


SHEET 24 OF 60

VERIFICATION SCALE
BAR IS ONE INCH ON ORIGINAL DRAWING

REVIEW R. ROCHA
CHECKED J. OLDHAM
APPROVED J. OLDHAM

REVISIONS

NO. DATE REV. BY DESCRIPTION



ITEM NO.	ITEM	SIZE	DESCRIPTION
①	METERING PUMP SYSTEM WITH MULTI-FUNCTION VALVE AND PIPING	---	STENNER DOSING PUMP, TUBING AND FOOT VALVE; MULTI-FUNCTION VALVE FOR BACK PRESSURE, PRESSURE RELIEF AND ANTI-SIPHON PROTECTION; INJECTION CHECK VALVE. SUPPORT ON FIBERGLASS OR PVC SHELF. SYSTEM PRESSURE AT INJECTION LOCATION IS APPROXIMATELY 80 PSI.
②	POLYPHOSPHATE STORAGE TANK SYSTEM	SEE MECHANICAL PLANS	SINGLE WALLED XLHDPE PVC FILL LINE ASSEMBLY.
③	TAP FOR POLYPHOSPHATE INJECTOR	1"	INJECTOR WITH CHECK VALVE, CORP STOP AND CHAIN ASSEMBLY. SEE MECHANICAL PLAN FOR LOCATION.
④	CONTINUOUS LEVEL PROBE	---	VEGAPULS21 WITH VEGAMET 841 OR APPROVED EQUAL.

- NOTES:

**Sage Well II Replacement
JBLM McChord Field PWS ID 52200
Polyphosphate System Calculations**

20.0% Solution			
9.84 lb/gal			
	Peak Hr	Peak D	
	MAX	MAX	
Req'd Dose =	2.00	1.00	mg/L
	1,200	1,200	gpm
Usage =	28.84	14.42	lbs/day
Feed Rate =	0.12	0.06	gal/hr
Recommended Storage =		100	gallons
Recommended Storage Time per T-2 3.2.D =		30	days
Calculated minimum storage time =		68.2	days
Selected Nominal Tank Size		100	gallons
Minimum Secondary Containment Volume			
@110% largest tank		110	gallons
		14.7	cubic ft
Available Containment in Sump = 9.33' x 2.5' x 2'		46.7	cubic ft
		348.9	gallons

POLYPHOSPHATE SYSTEM SCHEMATIC DETAIL

GENERAL NOTES

1. COORDINATE INSTALLATION OF PIPING AND DUCTWORK WITH STRUCTURAL COMPONENTS AND OTHER SYSTEM INSTALLATIONS. GENERAL CONTRACTOR TO SAW CUT AND CORE DRILL, PATCH AND REPAIR SURFACES AS REQUIRED.
2. DUCT PENETRATIONS THRU ROOF ARE TO BE COORDINATED WITH ROOF FRAMING. COORDINATE TO STRUCTURAL PLANS FOR EXACT LOCATIONS.
3. ALL DUCT DIMENSIONS SHOWN ARE INTERIOR DIMENSIONS.
4. VERIFY AND COORDINATE EXACT LOCATION OF T-STATS WITH ELECTRICAL CONTRACTOR PRIOR TO INSTALLATION FOR CONDUIT AND BACKBOX.
5. COORDINATE EXACT LOCATION OF PANEL WITH ELECTRICAL CONTRACTOR. COORDINATE ACCESS PANELS FOR HARD CEILINGS WITH GENERAL CONTRACTOR.
6. COORDINATE LOCATION OF HVAC EQUIPMENT WITH ALL OTHER TRADES TO MAINTAIN ACCESS AND SERVICE CLEARANCE.
7. SEE ARCHITECTURAL SHEETS FOR BUILDING CODE REQUIREMENTS AND WALL, FLOOR AND ROOF RATINGS.
8. ALL RATED WALL AND FLOOR PENETRATIONS SHALL BE SEALED AS REQUIRED IN SPECIFICATIONS.
9. REFERENCE CIVIL, PLUMBING, ELECTRICAL DRAWINGS. FIELD LOCATE UNDERGROUND LINES. MARK AND PROTECT AS NECESSARY. COORDINATE PROTECTION AND ANY AND ALL TEMPORARY DISRUPTIONS OF SERVICE WITH OWNER AS NECESSARY. PROVIDE ANY REQUIRED SHORING AND STRUCTURAL SUPPORTS OF PIPING AND CONDUITS AS REQUIRED. SCHEDULE WORK AND ANY REQUIRED INSPECTIONS TO MINIMIZE DISRUPTION OF SERVICE AS NECESSARY.
10. ALTHOUGH THE INTENT OF THE WORK IS SHOWN ON THE DRAWINGS, NOT EVERY FITTING OR ELBOW IS SHOWN & IT IS THE CONTRACTOR'S RESPONSIBILITY TO PROVIDE THE WORK NEEDED TO COMPLY WITH THE INTENT.
11. ALL DUCTWORK TO BE CROSS-BROKE OR BEADED. USE SMACNA STANDARDS AS MINIMUM REQUIREMENT FOR DUCTWORK.
12. EQUIPMENT SIZES AND SERVICE SPACE REQUIREMENTS MAY VARY BETWEEN DIFFERENT MANUFACTURES. CONSULT THE MANUFACTURER SUBMITTED AND APPROVED, AND COORDINATE WITH THESE DOCUMENTS.
13. INSTALL SEISMIC AND RESTRAINT BRACING FOR ALL PIPING, DUCTWORK, TANKS AND ALL OTHER EQUIPMENT SUBJECT TO STRUCTURAL DRAWINGS SEISMIC CRITERIA.

HVAC - MECHANICAL LEGEND

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	DRAIN		ELBOW UP		FIRE/SMOKE DAMPER
	REFRIGERANT SUCTION LINE		ELBOW DOWN		MOTORIZED DAMPER
	REFRIGERANT LIQUID LINE		PIPE SIZE CHANGE		TURNING VANE ELBOW
	REFRIGERANT HOT GAS LINE		MANUAL FLOW BALANCING VALVE (CIRCUIT SETTER)		45° LOW-LOSS TAKE-OFF FITTING W/ DAMPER & FLEX DUCT
	GATE VALVE		AUTOMATIC FLOW BALANCING VALVE		45° LOW-LOSS TAKE-OFF FITTING W/ DAMPER & RIGID ROUND DUCT
	BALL VALVE		PIPE GUIDE		RECTANGULAR/ROUND DUCT WITH 45° HIGH EFFICIENCY TAKE-OFF
	BUTTERFLY VALVE		PIPE ANCHOR		SUPPLY DIFFUSER W/ FLEX DUCT, THROW PATTERN SHOWN ON PLANS
	GLOBE VALVE		PRESSURE / TEMP. TEST PLUG		LAY-IN SUPPLY DIFFUSER W/ FLEX DUCT, THROW PATTERN SHOWN ON PLANS
	TRIPLE DUTY VALVE		DIAL THERMOMETER		RETURN GRILLE
	SWING CHECK VALVE		CONNECT NEW WORK TO EXISTING		EXHAUST GRILLE
	STRAINER		PRESSURE GAUGE W/ SNUBBER		DIFFUSER, REGISTER OR GRILLE
	FLEX CONNECTOR		THERMOSTAT/TEMPERATURE SENSOR		SD-1 (PLAN CODE) 200 (CFM)
	HOSE END DRAIN VALVE		THERMOSTAT/TEMPERATURE SENSOR W/ GUARD		SMOKE DETECTOR
	PRESSURE REDUCING VALVE		ACOUSTICALLY LINED SHEET METAL DUCT		COMMON
	SAFETY RELIEF VALVE		MANUAL BALANCING DAMPER		EXISTING
	UNION		FLEX CONNECTOR		BACKDRAFT DAMPER
	MOTORIZED T.C. VALVE / 2-WAY		ACCESS DOORS		
	MOTORIZED T.C. VALVE / 3-WAY		FIRE DAMPER		
	ECCENTRIC PLUG BALANCING VALVE				
	VALVE IN RISER				
	TEE UP				
	TEE DOWN				

HVAC ABBREVIATIONS

AFF	ABOVE FINISHED FLOOR	HZ	FREQUENCY	PSIA	PSI ABSOLUTE
ACFM	ACTUAL CFM	GA	GAGE OR GAUGE	PD	PRESSURE DROP
AHU	AIR HANDLING UNIT	GAL	GALLONS	PSIG	PSI GAUGE
ANSI	AMERICAN NATIONAL STANDARDS INSTITUTE	G.C.	GENERAL CONTRACTOR	R/O	RUN OUT
AMP	AMPERE (AMP, AMPS)	GPH	GALLONS PER HOUR	RA	RETURN AIR
APD	AIR PRESSURE DROP	GPM	GALLONS PER MINUTE	RPM	REVOLUTIONS PER MINUTE
APPROX	APPROXIMATE	GPD	GALLONS PER DAY	SH	SENSIBLE HEAT
BHP	BRAKE HORSEPOWER, BOILER HORSEPOWER	HD	HEAD	SPEC	SPECIFICATION
BTU	BRITISH THERMAL UNIT	HGT	HEIGHT	SP VOL	SPECIFIC VOLUME
BOD	BOTTOM OF DUCT	HP	HORSEPOWER	STD	STANDARD
MBH	BTU PER HOUR (THOUSAND)	RH	HUMIDITY, RELATIVE	SP	STATIC PRESSURE
C	COMMON	KW	KILOWATT	SUCT	SUCTION
CU FT	CUBIC FEET	KWH	KILOWATT HOUR	SA	SUPPLY AIR
CU IN	CUBIC INCH	LAT	LEAVING AIR TEMPERATURE	TEMP	TEMPERATURE
CFM	CUBIC FEET PER MINUTE	LWT	LEAVING WATER TEMPERATURE	TD	TEMPERATURE DIFFERENCE
COD	CENTER OF DUCT	LF	LINEAR FEET	T STAT	THERMOSTAT
SCFM	CFM, STANDARD CONDITIONS	MAX	MAXIMUM	TOD	TOP OF DUCT
DB	DECIBEL	MC	MECHANICAL CONTRACTOR	TONS	TONS OF REFRIGERATION
DIA	DIAMETER	MIN	MINIMUM	TC	TEMPERATURE CONTROL
ID	DIAMETER, INSIDE	NO	NORMALLY OPEN	VAC	VACUUM
OD	DIAMETER, OUTER	NC	NORMALLY CLOSED	VAV	VARIABLE AIR VOLUME
DBT	DRY-BULB TEMPERATURE	N/A	NOT APPLICABLE	VEL	VELOCITY
EAT	ENTERING AIR TEMPERATURE	NIC	NOT IN CONTRACT	V	VOLT
EC	ELECTRICAL CONTRACTOR	NTS	NOT TO SCALE	VOL	VOLUME
EDR	EQUIVALENT DIRECT RADIATION	NO	NUMBER	VFD	VARIABLE FREQUENCY DRIVE
EXP	EXPANSION	OBD	OPPOSED BLADE DAMPER	WPD	WATER PRESSURE DROP
EWT	ENTERING WATER TEMPERATURE	OA	OUTSIDE AIR	W/	WITH
F	FAHRENHEIT	%	PERCENT		
FPM	FEET PER MINUTE	PH	PHASE (ELECTRICAL)		
FPS	FEET PER SECOND	LBS	POUNDS		
FT	FOOT OR FEET	PSI	POUNDS PER SQUARE INCH		

AMERICAN WATER
Military Services
Joint Base Lewis-McChord

BOWEN COLLINS
ASSOCIATES

Cushing Terrell
cushingterrell.com
800.757.9522

90% REVIEW

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

AMERICAN WATER
JBLM WASHINGTON

SAGE WELL II REPLACEMENT

VERIFY SCALE
BAR IS ONE INCH ON
ORIGINAL DRAWING

DESIGN
L. RANKIN
J. WILSON

REVIEW
L. RANKIN
J. WILSON

DESIGNED
L. RANKIN
J. WILSON

DATE: DECEMBER 2023

PROJECT
NUMBER 427-22-03

DRAWING NO.
H-01

SHEET 29 OF 60

LOUVER SCHEDULE										
PLAN CODE	BASIS DESIGN	MODEL NO.	SERVICE	FRAME TYPE	W X H INCHES	CFM	BLADES	PRESSURE DROP (IN.W.C.)	MATERIAL	NOTES
LV-1	RUSKIN	ELF6375DX	INTAKE	BOX	32 x 16	460	DRAINABLE	0.05	ALUMINUM	1, 2
LV-2	RUSKIN	ELF6375DX	INTAKE	BOX	16 X 16	100	DRAINABLE	0.05	ALUMINUM	1, 2

SCHEDULE NOTES:

1. PROVIDE LOUVER WITH BIRDSCREEN.

2. FACTORY PRIMED AND PAINTED IN NEUTRAL COLOR, LOUVERS TO BE PAINTED ON SITE.

3. SEE PLANS FOR DAMPER/DAMPER ACTUATOR REQUIREMENTS.

EXHAUST FAN SCHEDULE											
PLAN CODE	BASIS OF DESIGN	MODEL NO.	DRIVE	CFM	RPM	E.S.P. (IN)	HP	ELEC POWER (V/PH/HZ)	FAN TYPE	WEIGHT(LBS)	NOTES
EF-1	GREENHECK	AER-20	DIRECT	460	860	0.30	1/4	115/1/60	WALL PROP FAN	219	1, 2, 3, 4

SCHEDULE NOTES:

1. FAN SELECTIONS ARE AT 325FT ABOVE SEA LEVEL.

2. PROVIDE WEATHERHOOD, GALVANIZED 45DEG WITH BIRD SCREEN.

3. PROVIDE GRAVITY BACKDRAFT DAMPER MOUNTED AT WALL, SEE DETAIL.


4. PROVIDE WALL COLLAR WITH MOTOR SIDE GUARD AND CLOSURE AND MOUNTING ANGLES AS NECESSARY.

ELECTRIC HEATER SCHEDULE										
PLAN CODE	LOCATION	BASIS OF DESIGN	MODEL	TYPE	WATTS/BTUH	CFM	POWER V/PH/HZ	TOTAL AMPS	WEIGHT	NOTES
EUH-1	MAIN ROOM	QMARK	MUH-03-81	UNIT HEATER	5000 / 17,000	350.0	208/1/60	14.5	30 LBS	1, 2


SCHEDULE NOTES:

1. PROVIDE DOUBLE POLE, SINGLE THROW ON OFF SWITCH ON BACK BOX FOR DISCONNECT OF POWER SUPPLY.

2. PROVIDE MOUNTING BRACKETS TO HANG UNIT HEATER WITH CEILING OR WALL MOUNTED, WALL MOUNTED LOW VOLTAGE THERMOSTAT THREE POLE BUILT IN DISCONNECT SWITCH, AND TRANSFORMER FOR 24VOLT CONTROL.



AMERICAN WATER
Military Services



BOWEN COLLINS
& ASSOCIATES

Joint Base Lewis-McChord



90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY				REVISIONS	
				NO.	DATE
				REV. BY	DESCRIPTION

AMERICAN WATER
JBLM WASHINGTON

SAGE WELL II REPLACEMENT

DESIGN
L. RANKIN

DRAWN
J. WILSON

REVIEW
L. RANKIN

CHECKED
L. RANKIN

APPROVED
L. RANKIN

VERIFY SCALE

BASIS ONE INCH ON ORIGINAL DRAWING



HVAC

HVAC SCHEDULES

DATE: DECEMBER 2023

PROJECT NUMBER 427-22-03

DRAWING NO.
H-02



HVAC PLAN


SCALE: 1/4"=1'-0"

SHEET NOTES: (#)

1. MOUNT BOTTOM OF UNIT HEATER AT 7 FT ABOVE FLOOR, SUPPORTED FROM THE WALL WITH SWIVEL BRACKET.
2. BLANK OFF INTERIOR SIDE OF LOUVER WITH BOARD INSULATION AND SHEET METAL.
3. INSTALL LOUVER ASSEMBLY, BOTTOM OF LOUVER AT 8 FT ABOVE FLOOR. PROVIDE OPEN/CLOSED MOTORIZED DAMPER WITH 120V-1PH ACTUATOR. DAMPER SHALL OPEN WHEN ASSOCIATED FAN IS OPERATING. SEE DETAIL 1/GH-01.
4. INSTALL WALL FAN AT 7'-0" TO BOTTOM OF FAN. SEE DETAIL 2/GH-01.
5. ALL DUCTWORK, PIPING AND COMPONENTS INSTALLED IN OR EXPOSED IN CHLORINE ROOM ENVIRONMENT SHALL BE RESISTANT TO CORROSION AND CAPABLE OF OPERATION IN CHLORINE CONCENTRATION WITHOUT DAMAGE.
6. WALL SWITCH TO TURN ON ROOM EXHAUST FAN, SEE ELECTRICAL DRAWINGS FOR WALL SWITCH.
7. PROVIDE THERMOSTAT ON WALL TO OPERATE EXHAUST FAN EF-1 WHEN TEMPERATURE RISES IN ROOM.



Joint Base Lewis-McChord



NOT FOR CONSTRUCTION FOR REVIEW ONLY				REVISIONS	
NO.	DATE	REV. BY	DESCRIPTION		

SAGE WELL II REPLACEMENT		VERIFY SCALE
AMERICAN WATER JBLM WASHINGTON		BAR IS ONE INCH ON ORIGINAL DRAWING

DESIGN	REVIEW
DESIGN L. RANKIN DRAWN J. WILSON	CHECKED L. RANKIN APPROVED L. RANKIN

HVAC	
HVAC PLAN	

DATE: DECEMBER 2023	PROJECT NUMBER 427-22-03
---------------------	-----------------------------

DRAWING NO. H-03
SHEET 31 OF 60

SYMBOL

LIGHTING

RECESSED TROFFER

WALL MOUNTED LINEAR FIXTURE

SURFACE MOUNTED LINEAR FIXTURE

SUSPENDED LINEAR FIXTURE

SHADED FIXTURE INDICATES EMERGENCY BALLAST

RECESSED DOWNLIGHT

WALL MOUNTED FIXTURE

POLE MOUNTED AREA LIGHT

WALL MOUNT EXIT LIGHT (W/ DIRECTIONAL ARROWS)

SURFACE MOUNTED DOWNLIGHT

EMERGENCY WALL LIGHT, SINGLE

EMERGENCY WALL LIGHT, DOUBLE

SYMBOL

DEVICES & POWER

SWITCH – SPST
3 THREE WAY
4 FOUR WAY
WP WEATHER PROOF
EXP EXPLOSION PROOF
M MANUAL MOTOR DISCONNECT/STARTER
T TIMER
MC MOMENTARY CONTACT
HC HANDICAPPED

RECEPTACLE – SIMPLEX

RECEPTACLE – DUPLEX
GFI GROUND FAULT INTERRUPT
WP WEATHER RESISTANT DEVICE W/ WHILE-IN-USE COVER

RECEPTACLE – DOUBLE DUPLEX SAME INDICATORS AS SHOWN FOR DUPLEX

J–BOX, J–BOX WALL MOUNTED, 4"x4"x2 1/8" DEEP UNLESS NOTED OTHERWISE
J–BOX, CONDUIT, PULL STRING BY EC
THERMOSTAT, SUPPLIED AND INSTALLED BY MC
POWER POLE

LCS (LOCAL CONTROL STATION)

EMERGENCY PUSHBUTTON

PHOTOCELL

SPECIAL PURPOSE CONNECTION, BOX INDICATES FLOOR MOUNTING, WORK AS NOTED
PANELBOARD, MOUNTING AS INDICATED ON PANEL SCHEDULE

COMBINATION STARTER

DISCONNECT SWITCH

CONTACTOR

CIRCUIT BREAKER

TRANSFORMER, DRY–TYPE
TRANSFORMER, PAD MOUNTED

SYMBOL

GROUNDING

GROUND ROD

GROUND ROD WITH GROUND TEST WELL

GROUND RISER FROM REBAR

MECHANICALLY CRIMPED OR WELDED GROUND CONNECTIONS

GROUND CABLE:
EMBEDDED IN CONCRETE
BURIED IN EARTH
EXPOSED

SYMBOL

SCHEMATIC

SELECTOR SWITCH 2 POSITION

NORMALLY OPEN TIME DELAY CLOSING AFTER COIL ENERGIZED

NORMALLY CLOSED TIME DELAY OPENING AFTER COIL ENERGIZED

INDICATOR LIGHT

REMOTE DEVICE CONNECTION

CLOSED RELAY CONTACT

OPEN RELAY CONTACT

TERMINAL TO EXTERNAL REMOTE DEVICE

WIRE TERMINAL OR CONNECTION POINT

LIMIT SWITCH

CONTROL RELAY

VT/PT CPT

SELECTOR SWITCH 3 POSITION MAINTAINED CONTACT

LEVEL SWITCH CLOSSES ON FALLING LEVEL

LEVEL SWITCH CLOSSES ON RISING LEVEL

CONTROL SWITCH PUSHBUTTON, MOMENTARY CONTACT N.C.

GROUND CONNECTION

SOLENOID

FLOW SWITCH CLOSSES ON LOW FLOW

PRESSURE SWITCH CLOSSES ON RISING PRESSURE

TRANSFORMER
W/ DELTA-Y
AND GROUND

UTILITY METER, UTILITY CT

CIRCUIT BREAKER

ELECTRICAL PANEL

FUSE

MOTOR STARTER NEMA SIZE AS NOTED

DISCONNECT SWITCH SIZE AS NOTED

ACTIVE HARMONIC FILTER

PASSIVE HARMONIC FILTER

MOTOR (10 HORSEPOWER NOTED)

SURGE PROTECTION DEVICE

POWER QUALITY METER

VARIABLE FREQUENCY DRIVE

PUMP MONITOR RELAY

REDUCED VOLTAGE SOFT STARTER

dV/dt FILTER

CIRCUITING SYMBOLS

INDICATES CONDUIT IN WALL OR ABOVE CEILING
CAPPED E
HOMERUN TO CIRCUITS 2,4,6 IN PANEL L1, 3/4"C, 2#12, 1#12(G) UNLESS OTHERWISE NOTED
RACEWAY
QUANTITY
CONDUIT CONCEALED IN FLOOR OR UNDER GROUND
2–1/2"C = ONE 2.5" CONDUIT
(3) 1/2"C = THREE 0.5" CONDUITS
(3) 2–1/2"C = THREE 2.5" CONDUITS

INTERIOR BOX MOUNTING HEIGHTS

FINISHED CEILING
BOD
TOD
COD
F COD
Hc COD
AC = ABOVE COUNTER, MINIMUM 4" ABOVE BACKSPLASH TO BOTTOM OF DEVICE.
FINISHED FLOOR
36"
44"
54"
74" TO TOP OF TRIM
80" MINIMUM TO BOTTOM
80" AFF TO BOTTOM OF DEVICE OR 6" BELOW CEILING TO TOP OF DEVICE, WHICHEVER IS LOWER

SYMBOL

ABBREVIATIONS AND MISCELLANEOUS

ATS
AUTOMATIC TRANSFER SWITCH

EC
ELECTRICAL CONTRACTOR

MC
MECHANICAL CONTRACTOR

GC
GENERAL CONTRACTOR

C
CONDUIT

GND, G
GROUND

BOD
BOTTOM OF DEVICE

COD
CENTER OF DEVICE

AFF
ABOVE FINISHED FLOOR

AFG
ABOVE FINISHED GRADE

BLG
BELOW GRADE

AC
ABOVE COUNTER, 4" ABOVE BACK SPLASH

BC
BELOW COUNTER, 4" BELOW COUNTER TOP

W/
a,b,c
WITH
SWITCH DESIGNATION

UON
UNLESS OTHERWISE NOTED

UG
UNDERGROUND

WP
WEATHER PROOF

FO
FIBER OPTIC

MD
MEDIUM VOLTAGE

INDICATES STANDARD DETAIL

EQUIPMENT TAG NUMBER

FAULT CURRENT VALUE

CONDUIT TAG

GENERAL NOTES:

1. VERIFY ALL EQUIPMENT DIMENSIONS AND LOCATIONS BEFORE BEGINNING ROUGH-IN. CONSULT ALL APPLICABLE CONTRACT DRAWINGS AND SHOP DRAWINGS TO ENSURE NEC CODE CLEARANCE REQUIRED AROUND ALL ELECTRICAL EQUIPMENT.

2. CONTRACTOR SHALL VERIFY ALL ELECTRICAL LOADS (VOLTAGE, PHASE, CONNECTION REQUIREMENTS, ETC.) OF EQUIPMENT FURNISHED BEFORE BEGINNING ROUGH-IN.

3. SEE APPLICABLE SHOP DRAWINGS FOR ROUGH-IN LOCATION OF ALL EQUIPMENT, WIRING DEVICES, ETC.

4. THE ELECTRICAL CONTRACTOR SHALL NOTIFY AND COOPERATE WITH THE MECHANICAL CONTRACTOR SUCH THAT NO PIPING, OR EQUIPMENT FOREIGN TO THE OPERATION OF THE ELECTRICAL EQUIPMENT SHALL BE PERMITTED TO BE INSTALLED IN, ENTER OR PASS THROUGH ELECTRICAL ROOMS OR SPACES; OR ABOVE OR BELOW ELECTRICAL EQUIPMENT IN THE OTHER AREAS.

5. ALL PENETRATIONS OF FLOORS, WALLS AND CEILINGS SHALL BE SEALED WITH APPROVED MATERIAL.

6. FOR PACKAGE EQUIPMENT PROVIDED ON THE PROJECT, SOME CONDUITS AND WIRES ARE SHOWN ON THE DRAWINGS, BUT IT IS EXPECTED THAT SOME ADDITIONAL CONDUITS AND WIRES MAY BE REQUIRED BY EQUIPMENT MANUFACTURERS TO COMPLETE INSTALLATION. IT IS INCUMBENT UPON THE GENERAL CONTRACTOR TO COORDINATE THIS REQUIREMENT WITH HIS SUBCONTRACTORS TO MAKE SURE THAT EQUIPMENT SUPPLIER PROVIDED ALL NECESSARY ELECTRICAL INFORMATION TO ELECTRICAL SUBCONTRACTOR FOR INCLUSION WHETHER SHOWN OR NOT SHOWN ON THE DRAWINGS.

7. IF OTHER THAN FIRST NAMED EQUIPMENT IS USED, IT SHALL BE CAREFULLY CHECKED FOR ELECTRICAL REQUIREMENTS AND CONTROL REQUIREMENTS OF ALTERNATE EQUIPMENT. SHOULD CHANGES OR ADDITIONS OCCUR IN ELECTRICAL WORK, OR THE WORK OF OTHER CONTRACTORS BE REVISED BY THE ALTERNATE EQUIPMENT, THE COST OF ALL CHANGES SHALL BE THE RESPONSIBILITY OF THE ELECTRICAL CONTRACTOR.

8. IT IS THE ELECTRICAL SUBCONTRACTOR'S RESPONSIBILITY TO RECEIVE THE COMPLETE SET OF PLANS IN ORDER TO ENSURE THAT ALL ITEMS RELATED TO ELECTRICAL POWER AND CONTROL SYSTEMS ARE COMPLETELY ACCOUNTED FOR.

9. ALL EQUIPMENT DIMENSIONS SHOWN ON PLANS AND ELEVATIONS ARE APPROXIMATE ONLY. THE CONTRACTOR SHALL USE THE SHOP DRAWINGS FOR PROPER LAYOUT, FOUNDATION AND PAD, ETC. FOR FINAL INSTALLATION WITHOUT ANY ADDITIONAL COST TO THE OWNER.

10. THE DRAWINGS GENERALLY ILLUSTRATE THE APPROXIMATE DESIRED LOCATION AND ARRANGEMENT OF OUTLETS, CONDUIT RUNS, EQUIPMENT AND OTHERS ITEMS. DETERMINE EXACT LOCATIONS IN THE FIELD BASED ON PHYSICAL SIZE AND ARRANGEMENT OF EQUIPMENT, FINISHED ELEVATIONS, EASEMENT LOCATIONS, AND OTHER OBSTRUCTIONS. LOCATIONS SHOWN ON THE DRAWINGS, HOWEVER, SHALL BE ADHERED TO AS CLOSELY AS POSSIBLE.

11. THE ELECTRICAL INSTALLATION SHALL COMPLY WITH THE CURRENT VERSION OF THE NEC, LOCAL, AND STATE CODES.

AMERICAN WATER

Military Services

Joint Base Lewis-McChord

BOWEN COLLINS ASSOCIATES

NOT FOR CONSTRUCTION FOR REVIEW ONLY

VERIFICATION SCALE

BAR IS ONE INCH ON ORIGINAL DRAWING

CHECKED D. YOUNGSTROM

APPROVED D. YOUNGSTROM

DESIGN J. LAKE

DRAW J. LAKE

ELECTRICAL

SAGE WELL II REPLACEMENT

AMERICAN WATER (P4-A60MWA2-00003)

JBLM WASHINGTON


ELECTRICAL LEGEND AND NOTES

DATE: DECEMBER 2023

PROJECT NUMBER 427-22-03

DRAWING NO. E-01

SHEET 32 OF 60



POWER PLAN
SCALE: 1/2" = 1'-0"

GENERAL NOTES:

- A. REFER TO POWER ONE-LINE DIAGRAM ON DRAWING E-06 AND LOAD SUMMARY ON DRAWING E-07 FOR CONDUIT, CONDUCTORS, AND ELECTRICAL EQUIPMENT INFORMATION.
- B. ALL OUTSIDE GFCI OUTLETS ARE WEATHER-RESISTANT WITH WHILE-IN-USE WEATHER PROOF COVER, HUBBELL, METALLIC WP26E OR WP26EH.
- C. 4/0 AWG BARE COPPER GROUND RING SHALL BE BURIED NOT LESS THAN 36" BELOW THE EARTH'S SURFACE. CONNECT REBAR TO THE GROUND RING VIA 4/0 AWG BARE COPPER GROUND CABLE (GROUND RISERS). EQUIPMENT AND MISCELLANEOUS METALWORK SHALL BE CONNECTED TO THE GROUND RING WITH 4/0 AWG BARE COPPER GROUND CABLE UNLESS OTHERWISE NOTED. THE GROUND RING SHALL BE A MINIMUM OF 6 FEET FROM BUILDING FOUNDATION. REFER TO GROUNDING PLAN SYMBOLS ON DRAWING E-01.
- D. DRAWING SHOWS TYPICAL LOCATIONS OF GROUNDING SYSTEM COMPONENTS.
- E. DRAWING SHOWS APPROXIMATE LOCATIONS AND MINIMUM NUMBER OF RISERS GROUNDING CONNECTIONS TO BE INSTALLED.
- F. INSTALL HOUSEKEEPING PAD UNDER ALL FLOOR MOUNTED ELECTRICAL EQUIPMENT. SEE STRUCTURAL DRAWINGS FOR DETAIL.
- G. ALL EXPOSED CONDUIT IN THE CHLORINE AND SODIUM HYPOCHLORITE AREAS SHALL BE SCHEDULE 80 PVC. CONDUIT SHALL BE SECURED TO THE WALL USING FIBERGLASS STRUT AND CLAMPS, NYLON BOLTS, AND STAINLESS STEEL WALL ANCHORS. ENCLOSURES IN THESE SPACES SHALL BE NON-METALLIC NEMA 4X. ALL INSTRUMENT AND EQUIPMENT LABELS IN THESE SPACES SHALL BE ENGRAVED ALUMINUM.
- H. FOR ALL CONDUIT PENETRATIONS THRU WALL, SEE E 5012 AND SPECIFICATIONS. SEE SPECIFICATIONS FOR ALL CONDUIT PENETRATIONS THRU SLAB.

KEY NOTES: #

- 1. CONNECT TO GROUND RING WITH #2 AWG BARE COPPER GROUND CABLE.
- 2. CONNECT TO GROUND RING WITH 4/0 BARE COPPER GROUND CABLE.
- 3. PROVIDE AND INSTALL MOTOR RATED SNAP SWITCH DISCONNECT MOUNTED UP HIGH NEAR EXHAUST FAN. SNAP SWITCH DISCONNECT SHALL BE PROVIDED WITH LOCKABLE, WEATHERPROOF COVER.
- 4. COORDINATE FINAL LOCATION OF RECEPTACLE IN FIELD.

AMERICAN WATER
Military Services

BOWEN COLLINS
ASSOCIATES

Joint Base Lewis-McChord

90% REVIEW

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

NO.	DATE	REV. BY	DESCRIPTION

AMERICAN WATER (P4-460MWA2-00003)
JBLM WASHINGTON

SAGE WELL II REPLACEMENT

DESIGN	REVIEW	VERIFY SCALE
DESIGN J. LAKE	CHECKED D. YOUNGSTROM	BAR IS ONE INCH ON ORIGINAL DRAWING
DRAWN J. LAKE	APPROVED D. YOUNGSTROM	


ELECTRICAL

POWER AND GROUNDING PLAN

DATE: DECEMBER 2023 PROJECT NUMBER: 427-22-03

DRAWING NO.
E-03

SHEET 34 OF 60




SCALE: 1/2" = 1'-0"

A. REFER TO CONTROL ONE-LINE DIAGRAM ON DRAWINGS E-08 AND E-09 FOR INFORMATION REGARDING CONDUIT AND CONDUCTORS/CABLING.

B. ALL EXPOSED CONDUIT IN THE CHLORINE AND SODIUM HYPOCHLORITE AREAS SHALL BE SCHEDULE 80 PVC. CONDUIT SHALL BE SECURED TO THE WALL USING FIBERGLASS STRUT AND CLAMPS, NYLON BOLTS, AND STAINLESS STEEL WALL ANCHORS. ENCLOSURES IN THESE SPACES SHALL BE NON-METALLIC NEMA 4X. ALL INSTRUMENT AND EQUIPMENT LABELS IN THESE SPACES SHALL BE ENGRAVED ALUMINUM.

C. FOR ALL CONDUIT PENETRATIONS THRU WALL, SEE E
5012 AND SPECIFICATIONS. SEE SPECIFICATIONS FOR ALL CONDUIT PENETRATIONS THRU SLAB.

1. PROVIDE AND INSTALL (1) 3/4" C W/ MANUFACTURER'S CABLE OR MANUFACTURER'S RECOMMENDED CABLE BETWEEN T-STAT AND ELECTRIC UNIT HEATER.
2. PROVIDE AND INSTALL DWYER BTT-N00-3 WALL MOUNT TEMPERATURE TRANSMITTER WITH 4-20mA OUTPUT OR APPROVED EQUAL.
3. PROVIDE AND INSTALL KELLER PRECISELINE HIGH ACCURACY DUEL OUTPUT PRESSURE TRANSMITTER OR APPROVED EQUAL. RANGE SHALL BE 0-150 PSI. CONFIRM RANGE WITH OWNER AND OPERATOR BEFORE PURCHASING.
4. PROVIDE AND INSTALL PRESSURE SWITCH. RANGE SHALL BE 0-150 PSI. SET TO TRIP ON RISING PRESSURE 95 PSI, AUTOMATIC RESET. CONFIRM RANGE AND TRIP VALUES WITH OWNER AND OPERATOR BEFORE PURCHASING.
5. PROVIDE AND INSTALL FLOWLINE SWITCH-TEK LU10 (P/N LU10-1305) OR APPROVED EQUAL.



GENERAL NOTES:

- A. FOR EQUIPMENT LOCATIONS, SEE ELECTRICAL SITE PLAN AND POWER PLAN ON DRAWINGS E-02 AND E-03.
- B. REFER TO LOAD SUMMARY AND PANEL SCHEDULE ON DRAWING E-07.
- C. CONTRACTOR RESPONSIBLE TO PROVIDE QUANTITIES AND SIZES OF LUGS FOR ALL EQUIPMENT MATCHING QUANTITIES AND SIZES OF CABLES SHOWN ON THE ONE-LINE DIAGRAM.
- D. DESIGN IS BASED ON MINIMUM WELL PUMP HORSEPOWER RATING SHOWN ON POWER ONE-LINE DIAGRAM. SHOULD CONTRACTOR SELECT HIGHER HORSEPOWER PUMP MOTOR, CONTRACTOR SHALL NOTIFY ENGINEER AND SHALL BE RESPONSIBLE FOR ALL REQUIRED CHANGES (INCLUDING UPSIZING WIRE, CONDUIT, VFD, DISTRIBUTION PANELBOARD, ETC.).
- E. ARC FLASH AND POWER SYSTEM STUDY SHALL BE PROVIDED, AND ARC FLASH LABELS SHALL BE APPLIED ONCE THE STUDY IS COMPLETED AND APPROVED.

KEY NOTES: #

- 1. PRIMARY SERVICE BY CITY LIGHT & POWER (CL&P). PRIMARY CONDUIT AND CABLING, TRANSFORMER, AND PADVAULT PROVIDED AND INSTALLED BY CL&P.
- 2. CONTRACTOR SHALL PROVIDE TRENCH, BACKFILL, AND COMPACTION. CONTRACTOR SHALL PROVIDE AND INSTALL SECONDARY CONDUIT AND CONDUCTORS. ALL WORK SHALL BE DONE IN ACCORDANCE WITH CL&P REQUIREMENTS.
- 3. CONTRACTOR SHALL PROVIDE AND INSTALL CT CABINET, METER BASE, CONDUIT BETWEEN THEM, AND GROUNDING AND BONDING OF ALL EQUIPMENT. COORDINATE ALL EQUIPMENT, CT'S, AND CT CABLING W/ OWNER.
- 4. PROVIDE AND INSTALL EXTERNAL SURGE PROTECTIVE DEVICE (SQUARE D P/N SSP04EMA24 OR APPROVED EQUAL). OCPD IN AND BRANCH CONDUCTORS FROM MDP SHALL BE SIZED PER MANUFACTURER'S RECOMMENDATIONS.
- 5. SEE PUMP MOTOR CONTROL DIAGRAM ON DRAWING E-10.
- 6. PROVIDE AND INSTALL 460V, 3-POLE, NEMA 3R, HEAVY DUTY, 250HP RATED DISCONNECT.
- 7. SHORT CIRCUIT CURRENT AVAILABLE IN AMPS. OVER CURRENT PROTECTIVE DEVICE SHALL BE FULLY RATED TO INTERRUPT SHORT CIRCUIT CURRENT. EQUIPMENT WITHSTAND RATING TO BE EQUAL TO OR GREATER THAN SHORT CIRCUIT CURRENT.
- 8. PROVIDE AND INSTALL 100% RATED CIRCUIT BREAKER.
- 9. CONTRACTOR SHALL PROVIDE GENERATOR SIZING REPORT AS PART OF EQUIPMENT SUBMITTAL. GENERATOR SHALL BE PROVIDED WITH 24-HR SUBBASE FUEL TANK.
- 10. PROVIDE AND INSTALL VFD CABLE (BELDEN 29531C OR ENGINEER-APPROVED EQUAL). SEPARATE 2 AWG EQUIPMENT GROUND CONDUCTOR SHALL BE RAN WITH EACH CABLE IN PARALLELED CONDUITS.
- 11. PROVIDE ATS COMPLETE WITH FULLY RATED ISOLATED BY-PASS SWITCH.
- 12. PROVIDE SQUARE D P/N EXN45T3HCU OR APPROVED EQUAL.
- 13. PROVIDE AND INSTALL EXTERNAL SURGE PROTECTIVE DEVICE (SQUARE D P/N SSP02EMA16 OR APPROVED EQUAL) (NOT SHOWN). OCPD IN AND BRANCH CONDUCTORS FROM LP-A SHALL BE SIZED PER MANUFACTURER'S RECOMMENDATIONS.

POWER ONE-LINE DIAGRAM

Joint Base Lewis-McChord

90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY		REVISIONS	
NO.	DATE	REV. BY	DESCRIPTION

AMERICAN WATER (P4-460MWV2-00003)

SAGE WELL II REPLACEMENT

JBLM WASHINGTON

DESIGN: J. LAKE
DRAWN: J. LAKE

REVIEW: D. YOUNGSTROM
CHECKED: D. YOUNGSTROM
APPROVED: D. YOUNGSTROM

VERIFY SCALE: 1" = 100'


BAR IS ONE INCH ON ORIGINAL DRAWING

ELECTRICAL

POWER ONE-LINE DIAGRAM

DATE: DECEMBER 2023

PROJECT NUMBER: 427-22-03



90% REVIEW

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

VERIFY SCALE
BAR IS ONE INCH ON
ORIGINAL DRAWING

DESIGN
J. LAKE

REVIEW
D. YOUNGSTROM

APPROVED
D. YOUNGSTROM

DATE: DECEMBER 2023

PROJECT
NUMBER

427-22-03

ELECTRICAL

CONTROL ONE-LINE
DIAGRAM - 2

DRAWING NO.
E-09

SHEET 40 OF 60

GENERAL NOTES:

A. FOR EQUIPMENT LOCATIONS, REFER TO THE ELECTRICAL SITE PLAN ON DRAWING E-02 AND THE CONTROLS PLAN ON DRAWING E-04.

KEY NOTES: #

1. INSTALL RTU PANEL. RTU PROVIDED BY A W SCHULTZ INC. PROVIDE AND INSTALL ALL INSTRUMENTATION, CONDUIT, CABLES, AND CONDUCTORS. LABEL ALL CABLES AND CONDUCTORS AT BOTH ENDS. TERMINATE CABLES AND CONDUCTORS ON NON-RTU END. PROVIDE SUFFICIENT LENGTH OF COILED CONDUCTORS AND CABLING IN ORDER FOR A W SCHULTZ INC. TO MAKE TERMINATIONS ON RTU-END. PROVIDE ASSISTANCE A W SCHULTZ INC. TO PERFORM POINT-TO-POINT CHECKOUT OF THE SYSTEM.
2. SIMPLEX RECEPTACLE FOR POWER.
3. SEE PANEL SCHEDULE ON DRAWING E-07 FOR CIRCUIT NUMBER AND CONDUIT AND CONDUCTOR INFORMATION.
4. PROVIDE AND INSTALL SUFFICIENT LENGTH OF MANUFACTURER'S CABLING TO MAKE TERMINATION WITHOUT SPLICING.

CONTROL ONE-LINE DIAGRAM CONT.



NOT FOR CONSTRUCTION
FOR REVIEW ONLY

AMERICAN WATER
JBLM WASHINGTON
SAGE WELL II REPLACEMENT

VERIFY SCALE
BARS ONE INCH ON
ORIGINAL DRAWING

REVIEW
CHECKED L. RANKIN
APPROVED L. RANKIN

DESIGN
L. RANKIN
DRAWN J. WILSON



























































PLUMBING
PLUMBING ABBREVIATIONS,
LEGEND, AND NOTES

PROJECT
NUMBER 427-22-03
DATE: DECEMBER 2023

DRAWING NO.
P-01

SHEET 42 OF 60

PLUMBING LEGEND


SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
 PW	POTABLE COLD WATER		GAS SHUT-OFF COCK
 TW	POTABLE TEPID WATER		SWING CHECK VALVE
 HWC	DOMESTIC HOT WATER RECIRC.		SPRING CHECK VALVE
 UW	UTILITY WATER		STRAINER
 SPW	SOFT COLD WATER		WATER OUTLET (TYPE INDICATED)
 SD	UNDERSLAB SANITARY DRAIN		BACKFLOW PREVENTER (TYPE INDICATED)
 SV	SANITARY VENT		SLEEVE (PIPE) THRU WALL OR FLOOR
 FCO	FLOOR CLEAN OUT		FLEX CONNECTOR (TYPE INDICATED)
 GCO	GRADE CLEAN OUT		HOSE END DRAIN VALVE
 WCO	WALL CLEAN OUT		PRESSURE REDUCING VA.
 CD	CONDENSATE DRAIN		TEMP. & PRESSURE RELIEF VALVE
 D	DRAIN		AUTOMATIC AIR VENT
 SS	UNDERSLAB SANITARY SEWER		DIELECTRIC UNION
 F	FIRE SERVICE		UNION
 CA	COMPRESSED AIR		MANUAL FLOW BALANCING VALVE
 CWV	UNDERGROUND COMBINATION WASTE VENT		AUTOMATIC FLOW BALANCING VALVE
 PCR	PUMPED CONDENSATE RETURN		DIAL THERMOMETER
 CR	CONDENSATE RETURN		PRESSURE GAUGE – PROVIDE WITH PIGTAIL FOR STEAM
 S=.XXX	SLOPE DOWN IN DIRECTION OF FLOW		PIPE ANCHOR
 NG	NATURAL GAS		SOLENOID VALVE
	SHUTOFF VALVE		L.P. VALVE
	GATE VALVE		ECCENTRIC PLUG BALANCING VALVE
	BALL VALVE		VALVE IN RISER
	BUTTERFLY VALVE		TEE UP
	GLOBE VALVE		TEE DOWN
 (US)	UNDERSLAB		ELBOW UP
 RWL	ROOF DRAIN		ELBOW DOWN
 OFL	OVERFLOW ROOF DRAIN		PIPE CAP
			PIPE DRAIN & CAP
			CONNECT TO EXISTING

PLUMBING ABBREVIATIONS

AB.C.	ABOVE CEILING	MAX	MAXIMUM
AFF	ABOVE FINISHED FLOOR	MIN	MINIMUM
AV	ACID VENT	NG	NATURAL GAS
AW	ACID WASTE	(N)	NEW
BFF	BELOW FINISHED FLOOR	NO	NORMALLY OPEN (VALVE)
BG	BELOW GRADE	NC	NORMALLY CLOSED (VALVE)
CA	COMPRESSED AIR	OH	OVER HEAD
CD	CONDENSATE DRAIN	OFL	OVERFLOW RAIN WATER LEADER
C.I.N.H.	CAST IRON NO HUB	PW	POTABLE WATER
CO	CLEANOUT	(R)	PIPE RISE
CKV	CHECK VALVE	RD	ROOF DRAIN
CW	COLD WATER	RIO	ROUGH-IN ONLY
CX	CONNECT TO EXISTING	RWL	RAIN WATER LEADER
(A)	PIPE DROP	SHT	SHEET
D	DRAIN	SCW	SOFT COLD WATER
DN	PIPE DROP TO NEXT LEVEL	SOV	SHUT OFF VALVE
DTL	DETAIL	TPL	TRAP PRIMER LINE
(E)	EXISTING	UG	UNDERGROUND
F	FIRE SERVICE	UP	PIPE RISE TO NEXT LEVEL
FCO	FLOOR CLEANOUT	US	UNDER SLAB
FND	FOUNDATION DRAIN	UTR	UP THRU ROOF
GCO	GRADE CLEANOUT	V	VENT
HW	HOT WATER	VA	VALVE
HWC	HOT WATER CIRCULATION	VTR	VENT THRU ROOF
IDW	INDIRECT WASTE	W	WASTE
I.E.	INVERT ELEVATION	WCO	WALL CLEANOUT
IRR	IRRIGATION		
LPG	LIQUEFIED PETROLEUM GAS		
LWCO	LOW WATER CUTOFF		


PLUMBING GENERAL NOTES:

- COORDINATE PLUMBING FIXTURES AND RELATED PIPING WITH ALL OTHER TRADES AS REQUIRED.
- REFER TO ARCHITECTURAL FLOOR PLANS AND INTERIOR ELEVATIONS FOR EXACT FIXTURE LOCATIONS AND MOUNTING HEIGHTS.
- LOCATE WATER PIPING IN HEATED AREAS ONLY. DO NOT LOCATE PIPING IN NON-INSULATED ATTIC, CEILING OR WALL SPACES. DO NOT LOCATE WATER PIPING IN ANY EXTERIOR WALL.
- ACCESS PANEL LOCATIONS MUST BE COORDINATED WITH EITHER ARCHITECT OR GENERAL CONTRACTOR.
- WALLS ARE SHOWN DASHED ON FOUNDATION PLAN FOR REFERENCE AND CLARITY ONLY. WASTE PIPING IS ROUTED UNDER FLOOR SLAB.
- SANITARY DRAIN AND WASTE PIPING SMALLER THAN 4" IS TO BE SLOPED AT 1/4" PER FOOT. ALL SANITARY DRAIN AND WASTE PIPING 4" AND LARGER IS TO BE INSTALLED AT 1/8" SLOPE PER FOOT, UNLESS GREATER SLOPE IS REQUIRED BY THE LOCAL AUTHORITY HAVING JURISDICTION.



SCALE: $1/4" = 1'-0"$

1. HUB DRAIN FOR ANALYZERS, SEE DETAIL 2/GP-01.
2. EMERGENCY FIXTURE, SEE DETAIL 1/GP-01 AND INSTALL MANUFACTURER INSTALLATION INSTRUCTIONS.
3. DISCHARGE WATER HEATER HEAT DUMP AND RELIEF VALVE TO EXTERIOR. NO THREADED CONNECTION ON DISCHARGE.
4. CONNECT 2" TO WATER MAIN, SEE CIVIL DRAWING C-03.
5. INSTALL 2" SHUT OFF VALVE AND REDUCE TO 1-1/4".




NOTES:

- STONE SIZE – USE 2'-4" STONE, OR RECLAIMED CONCRETE EQUIVALENT.
- LENGTH – AS REQUIRED, BUT NOT LESS THAN 50 FEET
- THICKNESS – NOT LESS THAN EIGHT (8) INCHES.
- WIDTH – 28 FOOT MINIMUM, BUT NOT LESS THAN THE FULL WIDTH AT POINTS WHERE INGRESS OR EGRESS OCCURS.
- STABILIZATION FABRIC – WILL BE PLACED OVER THE ENTIRE AREA PRIOR TO PLACING STONE.
- SURFACE WATER – ALL SURFACE WATER FLOWING OR DIVERTED TOWARD CONSTRUCTION ENTRANCES SHALL BE PIPED ACROSS THE ENTRANCE. IF PIPING IS IMPRACTICAL, A MOUNTABLE BERM WITH 5:1 SIDE SLOPES WILL BE PERMITTED.
- MAINTENANCE – THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION WHICH WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY. THIS MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE AS CONDITIONS DEMAND AND REPAIR AND/OR CLEANOUT OF ANY MEASURES USED TO TRAP SEDIMENT. ALL SEDIMENT SPILLED DROPPED, WASHED OR TRACKED ONTO PUBLIC RIGHTS-OF-WAY MUST BE REMOVED IMMEDIATELY.
- WASHING – WHEELS SHALL BE CLEANED TO REMOVE SEDIMENT PRIOR TO ENTRANCE ONTO PUBLIC RIGHTS-OF-WAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH STONE AND WHICH DRAINS TO AN APPROVED SEDIMENT TRAPPING DEVICE.
- PERIODIC INSPECTION AND NEEDED MAINTENANCE SHALL BE PROVIDED AFTER EACH RAIN.

STABILIZED CONSTRUCTION ENTRANCE
SCALE: NTS

C
2105




NOTES:

- COMPACT BASE AND BORROW MATERIAL TO AT LEAST 95% MAXIMUM DRY DENSITY PER ASTM D1557.
- SCARIFY AND RECOMPACT SUBGRADE TO 95% MAXIMUM DRY DENSITY.

GRAVEL PARKING
SCALE: NTS

C
2111



ALTERNATE TRENCH SECTIONS (A) (B) & (C)

- MAX UNSUPPORTED HEIGHT = 3.5 FT.
- FOR DEPTH OVER 3.5 FT SHORING OR SHEATHING REQUIRED.

- NOT TO BE USED WITHOUT APPROVAL OF ENGINEER.
- REQUIRES IMPROVED PIPE ZONE BACKFILL OR INCREASE IN PIPE CLASS


- TRENCH IN PIPE ZONE SHALL HAVE VERTICAL WALLS WHERE STABLE SOIL EXISTS

NOTES:

- TRENCH EXCAVATIONS TO BE IN ACCORDANCE WITH OSHA SAFETY AND HEALTH STANDARDS FOR CONSTRUCTION. (29 CFR 1926).
- CONTRACTOR TO PROVIDE SHORING OR TRENCH BOX IN ROADWAY AREAS TO MINIMIZE TRENCH WIDTH.
- CONTRACTOR TO PROVIDE ALL DEWATERING MEASURES AS REQUIRED. GROUNDWATER ELEVATION SHALL BE MAINTAINED AT LEAST 2' BELOW BOTTOM OF TRENCH UNTIL BACKFILL IS COMPLETE.
- SLIDE SLOPES SHALL MEET MINIMUM REQUIREMENTS OF THE GEOTECHNICAL INVESTIGATION.

TYPICAL TRENCH
EXCAVATION SECTION
NTS

C
2122




NOTES:

- ALL MATERIAL SHALL BE COMPACTED TO 95% MAXIMUM DRY DENSITY UNLESS NOTED OTHERWISE.
- IMPORT BACKFILL REQUIRED FOR TRENCH BACKFILL UNDER ROADWAY AREAS, UNLESS CONTRACTOR DEMONSTRATES THAT SUITABLE ON-SITE MATERIAL CAN BE PROCESSED TO MEET SPECIFIED BACKFILL REQUIREMENTS.
- SCREENED NATIVE MATERIAL MEETING SPECIFICATION REQUIREMENT FOR 'SUITABLE MATERIAL' MAY BE USED FOR TRENCH ZONE BACKFILL.
- IN UNIMPROVED AREAS, STRIP TOP 8" OF SOIL AND STOCKPILE PRIOR TO TRENCH EXCAVATION.
- IF NATIVE SOILS DO NOT PROVIDE A FIRM, STABLE FOUNDATION, AS DETERMINED BY ENGINEER, OVER EXCAVATE BELOW BOTTOM OF TRENCH AND BACKFILL WITH TRENCH STABILIZATION MATERIAL AS SHOWN.
- TOP 6" OF TRENCH BACKFILL BENEATH THE TOPSOIL LAYER SHOULD BE INSTALLED, SMOOTHED, BUT LEFT UN-COMPACTED.


TYPICAL TRENCH BACKFILL SECTION
NTS

C
2124



BOLLARD
SCALE: NTS

C
2205



NOTES:

- POSTS SPACED 6' O.C. MAX.
- FILTER CLOTH TO BE TIED TO MESH EVERY 24" AT TOP AND MIDDLE WITH 6" FOLDED OVERLAP AT VERTICAL SEAMS,
- FENCE SHALL BE MAINTAINED AND ACCUMULATED MATERIAL REMOVED.
- CONTRACTOR MAY SECURE SILT FENCE FILTER CLOTH TO CHAIN LINK CONSTRUCTION FENCE WHERE APPLICABLE, IN INSTANCES WHERE FILTER CLOTH IS SECURED TO CHAIN LINK FENCE, WIRE MESH IS NOT REQUIRED. IF FILTER CLOTH IS NOT SECURED TO CHAIN LINK FENCE, IT MUST BE ATTACHED TO WIRE MESH PER THE DETAIL.

SILT FENCE DETAIL
SCALE: NTS

C
2280

90% REVIEW

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

SAGE WELL II REPLACEMENT
JBLM WASHINGTON

GENERAL CIVIL
DETAILS - 1

DRAWING NO.
GC-01

SHEET 45 OF 60

GENERAL STRUCTURAL NOTES

GENERAL

- THE SPECIFICATIONS AND REQUIREMENTS INDICATED ON THIS SHEET ARE INTENDED AS A BASIC SUMMARY OF THE MATERIAL CONSTRUCTION AND INSPECTION REQUIREMENTS FOR THIS PROJECT. ADDITIONAL REQUIREMENTS ARE GIVEN IN THE PROJECT SPECIFICATIONS. IN THE EVENT OF A CONFLICT BETWEEN THESE GENERAL NOTES AND THE REQUIREMENTS GIVEN IN THE PROJECT SPECIFICATIONS, THE MORE RESTRICTIVE PROVISION SHALL GOVERN UNLESS OTHERWISE DIRECTED BY THE ENGINEER.
- FOR LOCATION AND DIMENSIONS OF SLEEVES, CURBS, OPENINGS, AND DEPRESSIONS NOT SHOWN ON THE STRUCTURAL DRAWINGS, SEE ARCHITECTURAL, CIVIL, MECHANICAL, AND ELECTRICAL DRAWINGS. THE CONTRACTOR SHALL VERIFY AND COORDINATE PENETRATIONS SHOWN ON THE OTHER PROJECT DRAWINGS, WHETHER THEY ARE SHOWN ON THE STRUCTURAL DRAWINGS OR NOT.
- EMBEDDED ITEMS, SUCH AS PIPE SLEEVES, CONDUITS, AND INSERTS SHALL ALL BE RIGIDLY INSTALLED IN PLACE BEFORE CONCRETE IS POURED. SEE ARCHITECTURAL, CIVIL, MECHANICAL, AND ELECTRICAL DRAWINGS FOR ITEMS REQUIRING SLEEVES AND EMBEDMENTS IN CONCRETE, WHICH ARE NOT SHOWN ON THE STRUCTURAL DRAWINGS.
- NO STRUCTURAL MEMBER SHALL BE CUT FOR PIPES, DUCTS, ETC. UNLESS SPECIFICALLY DETAILED OR APPROVED IN WRITING BY THE ENGINEER.
- DESIGN DETAILS AS SHOWN ON THE DRAWINGS ARE INTENDED TO BE TYPICAL AND APPLY TO ALL SIMILAR SITUATIONS OCCURRING ON THE PROJECT, WHETHER OR NOT THEY ARE SPECIFICALLY REFERENCED IN EACH LOCATION. CONSULT THE ENGINEER FOR CONCURRENCE PRIOR TO CONSTRUCTION.
- SUBMIT DRAWINGS AND RECEIVE REVIEW OF ALL STRUCTURAL RELATED SHOP DRAWINGS PRIOR TO ERECTION OR CONSTRUCTION.
- APPLICABLE BUILDING CODE FOR THE PROJECT IS UNIFIED FACILITIES CRITERIA, UFC 3-301-01 (2019-C1)(STRUCTURAL ENGINEERING) WHICH ADOPTS THE 2018 EDITION OF THE INTERNATIONAL BUILDING CODE (IBC).

SITE PREPARATION NOTES

- SITE PREPARATION NOTES FOR THIS PROJECT ARE BASED ON RECOMMENDATIONS CONTAINED IN A SOILS REPORT BY GEO ENGINEERS., DATED MARCH 31, 2023, ALONG WITH ANY ADDENDA THERETO, WHICH HAVE BEEN PREPARED FOR THIS PROJECT. A REFERENCE COPY IS AVAILABLE UPON REQUEST FROM THE ENGINEER (or IS INCLUDED IN THE APPENDIX CHAPTER OF THE SPECIFICATIONS)
- FOOTINGS AND FOUNDATIONS AS SHOWN ON DRAWINGS MAY VARY IF THE SUBSURFACE SOIL CONDITIONS VARY FROM THOSE FOUND IN THE SOILS REPORT.
- ALL SURFACE MATERIALS SUCH AS VEGETATION (INCLUDING THE ROOT ZONE), TOPSOIL, DEBRIS, NON-ENGINEERED FILL, BOULDERS LARGER THAN 6" AND ANY OTHER DELETERIOUS MATERIALS SHALL BE REMOVED FROM WITHIN THE BUILDING PAD AREA. THESE STRIPPED SOILS ARE CONSIDERED UNSUITABLE FOR STRUCTURAL FILL.
- THE SUBGRADE SHALL BE PROOF ROLLED WITH HEAVY RUBBER-TIRED EQUIPMENT. ALL SOFT SPOTS SHALL BE REMOVED AND REPLACED WITH SELECT GRANULAR STRUCTURAL FILL OR OTHERWISE STABILIZED. IN WET WEATHER, IF THE EXISTING SUBGRADE MATERIALS BECOME DIFFICULT TO WORK WITH, THE EXISTING SUBGRADE MATERIALS FOR A MINIMUM OF ONE FOOT BELOW THE FOOTINGS SHALL BE REMOVED AND REPLACED WITH A WASHED CRUSHED ROCK OR SELECT GRANULAR STRUCTURAL FILL.
- THE OWNER'S GEOTECHNICAL ENGINEER OR SPECIAL INSPECTOR SHALL OBSERVE THE NATURAL SOILS AT THE TIME OF FOOTING EXCAVATION TO DETERMINE THE SUITABILITY OF THE NATURAL SOILS FOR SUPPORTING THE FOOTINGS.
- SELECT GRANULAR STRUCTURAL FILL SHALL CONSIST OF WELL GRADED GRANULAR MATERIAL WITH A MAXIMUM SIZE OF 3 INCHES, AND LESS THAN 5 % FINES BASED ON THE MINUS ¾-INCH FRACTION.
- STRUCTURAL FILL BELOW FOOTINGS AND BELOW SLAB ON GRADE SHALL BE PLACED IN MAXIMUM 8 INCH LOOSE LIFTS AND COMPACTED TO AT LEAST 95% OF MAXIMUM DENSITY AS DETERMINED BY ASTM D-1557 AND SHALL BE COMPACTED AT A MOISTURE CONTENT WITHIN 2% OF THE OPTIMUM MOISTURE CONTENT.
- BACKFILL AROUND WALLS SHALL BE COMPACTED TO 90% OF MAXIMUM DENSTIY AS DETERMINED BY ASTM D-1557.
- SLABS ON GRADE SHALL BE UNDERLAIN BY A MINIMUM OF 6" OF FREE-DRAINING GRANULAR MATERIAL CONSISTING OF CLEAN SAND AND GRAVEL, CRUSHED ROCK OR WASHED ROCK WITH LESS THAN 3% FINES BASED ON THE MINUS ¾-INCH SIEVE SIZE FRACTION. GRANULAR MATERIAL SHALL BE PLACED UPON PROPERLY PREPARED SUBGRADE AS DESCRIBED ABOVE.
- COMPACTION OF STRUCTURAL FILL SHALL BE OBSERVED AND TESTED BY OWNER'S TESTING LABORATORY TO ENSURE THAT THE ABOVE REQUIREMENTS ARE ACHIEVED.

FOOTINGS

- EXTERIOR WALL FOOTINGS SHALL BEAR AT A MINIMUM DEPTH OF 1'-6" BELOW FINISHED EXTERIOR GRADE.
- NO FOOTINGS SHALL BE PLACED IN WATER OR ON FROZEN GROUND.
- WHERE A PIPE PASSES THROUGH AN INTERIOR OR EXTERIOR FOUNDATION WALL, STEP THE FOOTING DOWN TO PASS BELOW PIPE AND THEN STEP BACK UP TO INDICATED ELEVATION. PROVIDE PIPE SLEEVE THROUGH FOUNDATION WALL.

CONCRETE

- ALL CONCRETE CONSTRUCTION TO CONFORM TO ACI 318 "BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE," INCLUDING BAR BENDS AND HOOKS UNLESS SPECIFICALLY DETAILED OTHERWISE ON THESE DRAWINGS.
- THE MINIMUM COMPRESSIVE STRENGTH OF ALL STRUCTURAL CONCRETE AT 28 DAYS SHALL BE 4,000 PSI.
- A STATEMENT OF MIX DESIGN FOR ALL CONCRETE SHALL BE SUBMITTED TO AND REVIEWED BY THE STRUCTURAL ENGINEER PRIOR TO COMMENCING WORK.
- NON-STRUCTURAL ELEMENTS, SUCH AS ENCASEMENTS AND LEAN CONCRETE TO HAVE A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 3000 PSI.
- USE CEMENT CONFORMING TO ASTM C595, TYPE II (10) (MS).
- ALL CONSTRUCTION JOINTS, EXPANSION JOINTS, AND OTHER TYPES OF JOINTS, OTHER THAN THOSE SPECIFICALLY SHOWN ON THE DRAWINGS TO BE APPROVED BY THE ENGINEER PRIOR TO PLACING CONCRETE.
- INSTALL CONTINUOUS WATERSTOPS IN ALL EXPANSION, CONTRACTION, CONTROL AND CONSTRUCTION JOINTS OF WATER-HOLDING BASINS, CHANNELS, AND BELOW GRADE STRUCTURES UNLESS SPECIFICALLY NOTED OTHERWISE.
- PROVIDE 3/4-INCH CHAMFER AT ALL EXPOSED EDGES AND CORNERS UNLESS NOTED OTHERWISE.
- BEFORE PLACING THE SECOND POUR AT CONSTRUCTION JOINTS REMOVE LAITANCE, THOROUGHLY CLEAN AND ROUGHEN ALL JOINT SURFACES TO MINIMUM AMPLITUDE OF 1/4 INCH.
- UNLESS NOTED OTHERWISE ON THE DRAWINGS, REINFORCE CONCRETE WALLS AS FOLLOWS:

WIDTH	HORIZ REINF	VERT REINF
8" WALL	#5 @ 18"	#4 @ 18" CENTER OF WALL
12" WALL	#4 @ 12", EACH FACE	#4 @ 12", EACH FACE
16" WALL	#5 @ 16", EACH FACE	#5 @ 16", EACH FACE

REINFORCEMENT STEEL

- PROVIDE REINFORCEMENT STEEL CONFORMING TO ASTM A615, GRADE 60 EXCEPT WHERE WELDING IS PERMITTED BY THE ENGINEER. PROVIDE STEEL CONFORMING TO ASTM A706 WHEN WELDING IS PERMITTED.
- PROVIDE WELDED WIRE FABRIC CONFORMING TO ASTM A185 FOR PLAIN REINFORCEMENT AND ASTM A497 FOR DEFORMED.
- DIMENSIONS GIVEN FOR REINFORCING BARS ARE TO BAR CENTERS UNLESS NOTED OTHERWISE. BAR COVER IS THE CLEAR DISTANCE BETWEEN BAR AND CONCRETE SURFACE. CLEARANCE FOR REINFORCEMENT BARS PER THE FOLLOWING UNLESS SHOWN OTHERWISE:

WHEN PLACED AGAINST GROUND..... 3"

FORMED SURFACES IN CONTACT WITH THE GROUND..... 2"

OR EXPOSED TO THE WEATHER..... 2"

INTERIOR WALL SURFACES..... 1"

ALL OTHER CONCRETE SURFACES..... 2"
- CONTINUE WALL CORNER AND WALL INTERSECTION REINFORCEMENT BARS AROUND CORNERS AND THROUGH COLUMNS OR PILASTERS. EXTEND REINFORCEMENT INTO CONNECTING WALLS AND LAP ON THE OPPOSITE FACE OF THE CONNECTING WALLS.
- UNLESS OTHERWISE NOTED, ALL HOOKS SHOWN ARE 90° STANDARD HOOK AS DEFINED IN ACI 318-14.
- LAP VERTICAL WALL BARS WITH DOWELS FROM BELOW AND EXTEND THROUGH SLABS ABOVE TO TOP FACE. BEND AND/OR LAP TO TOP SLAB REINFORCEMENT AS INDICATED.
- UNLESS OTHERWISE INDICATED, CONTRACTOR MAY SPLICE CONTINUOUS SLAB OR LONGITUDINAL BEAM BARS AT LOCATIONS OF HIS CHOOSING, EXCEPT THAT TOP BAR SPLICES ARE TO BE LOCATED AT MIDSPAN AND BOTTOM BAR SPLICES ARE TO BE LOCATED AT SUPPORTS. MINIMUM LAP REQUIREMENTS ARE AS FOLLOWS UNLESS OTHERWISE INDICATED.

LAP LENGTHS* – CONCRETE								
BAR SIZE	#4	#5	#6	#7	#8	#9	#10	#11
CONCRETE DESIGN STRENGTH = 4000 PSI								
LAP LENGTH	1'-8"	2'-0"	2'-5"	3'-6"	4'-0"	5'-0"	6'-2"	7'-5"

*ASSUMES 2" MINIMUM CLEARANCE TO SURFACE

MASONRY

- CONCRETE MASONRY UNITS SHALL CONFORM TO ASTM C90 GRADE N AND SHALL HAVE A MINIMUM COMPRESSIVE STRENGTH OF 2,000 PSI BASED ON THE NET SECTION.
- PROVIDE MORTAR CONFORMING TO ASTM C270, TYPE S, HYDRATED. DO NOT USE MASONRY CEMENT.
- PROVIDE GROUT CONFORMING TO ASTM C476 WITH A MINIMUM 28-DAY COMPRESSIVE STRENGTH OF 2,000 PSI.
- DESIGN f_m FOR MASONRY ASSEMBLIES IS 2,000 PSI.
- GROUT ALL CMU WALLS SOLID.

- PLACE THE MASONRY UNITS IN RUNNING BOND UNLESS SPECIFICALLY NOTED OTHERWISE ON THE DRAWINGS.
- MASONRY WALL REINFORCEMENT SHALL BE PLACED IN GROUTED CELLS. UNLESS NOTED OTHERWISE ON THE DRAWINGS, REINFORCE MASONRY WALLS AS FOLLOWS:

WIDTH	HORIZ REINF	VERT REINF
8" CMU	(2) #4 @ 48"	#5 @ 32" (CENTER OF WALL)
12" CMU	(2) #4 @ 48"	2 #5 @ 24"

- ALL HORIZONTAL REINFORCING AT ENDS OF WALLS SHALL TERMINATE WITH A HOOK AROUND VERTICAL REINFORCING.
- IN ADDITION TO HORIZONTAL REINFORCING, LADDER-TYPE REINFORCING CONSISTING OF #9 WIRE FOR EACH FACE SHELL OF EACH WYTHE SHALL BE USED AT 16" OC HORIZONTALLY IN ALL MASONRY WALLS. REINFORCEMENT SHALL BE FOR TOTAL WIDTH OF CAVITY WALLS.
- REINFORCEMENT PROTECTION (COVER):

A. JOINT REINFORCEMENT SHALL HAVE NOT LESS THAN 5/8" MORTAR COVERAGE FROM THE EXPOSED FACE.

B. OTHER REINFORCEMENT SHALL HAVE A MINIMUM COVERAGE OF 2" FROM OUTSIDE FACE OF MASONRY. THERE SHALL BE A MINIMUM OF ½" GROUT BETWEEN REINFORCING STEEL AND MASONRY UNITS.
- ALL VERTICAL REINFORCING BARS SHALL BE DOWELED TO STRUCTURE BELOW WITH BARS OF SAME SIZE AND SPACING. LAP REINFORCING BARS AS FOLLOWS UNLESS OTHERWISE NOTED ON THE DRAWINGS:

LAP LENGTHS – MASONRY (f'm = 2,000 psi)							
BAR SIZE	#3	#4	#5	#6	#7	#8	#9
SINGLE MAT (CENTER IN WALL)							
LAP LENGTH	1'-0"	1'-0"	1'-7"	3'-1"	4'-3"	MECH	MECH
DOUBLE MAT (2" MIN CLEAR FROM OUTSIDE FACE)							
LAP LENGTH	1'-0"	1'-9"	2'-10"	4'-6"	5'-3"	MECH	MECH

MECH = MECHANICAL SPLICE REQUIRED

- AN ADDITIONAL VERTICAL BAR (MATCHING WALL REINFORCEMENT) SHALL BE PLACED AT EACH CORNER, AND ENDS OF WALLS.
- AT ALL OPENINGS GROUT WALL SOLID FOR FULL HEIGHT AT JAMBS OF OPENINGS, ONE CELL FOR EACH 4'-0" OF SPAN OR PORTION THEREOF (EXAMPLE: FOR 6'-0" SPAN, GROUT TWO CELLS AT EACH SIDE OF OPENING). REINFORCE EACH GROUTED CELL WITH STANDARD VERTICAL WALL REINFORCING BARS, TYPICAL, U.N.O.
- AT MASONRY BEAMS ABOVE OPENINGS HORIZONTAL REINFORCING BARS IN THE BOTTOM OF THE MASONRY BEAM SHALL EXTEND 2'-0" BEYOND THE EDGE OF THE OPENING OR SHALL BE HOOKED IF REQUIRED. DO NOT SPLICE HORIZONTAL TOP AND/OR BOTTOM REINFORCING BARS IN MASONRY BEAM, TYPICAL, U.N.O.
- MASONRY BEAMS SHALL BE BUILT AS AN INTEGRAL PART OF THE SUPPORT. NO TOOTHING OR DOWELLING ONLY WILL BE PERMITTED AT SUPPORTS.
- AT SMALL OPENINGS IN MASONRY WALLS (NOT SHOWN ON DRAWINGS) PROVIDE (1) #5 ON ALL SIDES OF OPENINGS WITH A MINIMUM PROJECTION OF 2'-0" BEYOND EDGES.
- STOP GROUT POURS 1/2" BELOW TOP OF BLOCK UNITS BETWEEN GROUT LIFTS.
- ALL ANCHOR BOLTS TO BE PLACED IN GROUTED CELLS.

STRUCTURAL STEEL

- UNLESS NOTED OTHERWISE, PROVIDE STRUCTURAL STEEL CONFORMING TO ASTM A36. ROLLED WIDE FLANGE SHAPES TO CONFORM TO ASTM A992. PIPE TO CONFORM TO ASTM A53, TYPE E OR S, GRADE B. STRUCTURAL TUBING TO CONFORM TO ASTM A1085. FABRICATE AND ERECT ALL STRUCTURAL STEEL IN CONFORMANCE WITH AISC SPECIFICATIONS.
- USE A325 OR F1852 BOLTS FOR STEEL TO STEEL CONNECTIONS, F1554 GR36 FOR ANCHOR BOLTS, AND A307 BOLTS FOR ALL OTHER CONNECTIONS (UNLESS SPECIFIED OTHERWISE ON DRAWINGS). USE 3/4" DIAMETER MINIMUM.
- ALL HIGH-STRENGTH BOLTS SHALL BE INSTALLED IN ACCORDANCE WITH AISC "SPECIFICATIONS FOR STRUCTURAL JOINTS USING ASTM A325 OR A490 BOLTS." THE TURN-OF-NUT METHOD MAY BE USED. PROVIDE CARBONIZED WASHERS UNDER THE TURNED ELEMENT.
- USE ONLY CERTIFIED WELDERS FOR ALL WELDING WORK. USE FILLER METAL HAVING A MINIMUM TENSILE STRENGTH OF 70 KSI AND PERFORM ALL WORK IN ACCORDANCE WITH THE CURRENT STRUCTURAL WELDING CODE (AWS D1.1).
- UNLESS OTHERWISE NOTED, COAT ALL STRUCTURAL STEEL COMPONENTS WITH PAINT OR OTHER PROTECTIVE COATINGS AS SPECIFIED IN THE PROJECT SPECIFICATIONS.
- MINIMUM THICKNESS FOR GUSSET PLATES IS 3/8 INCH.
- STRUCTURAL STEEL, WHICH IS TO BE EMBEDDED INTO CONCRETE TO BE CLEAN AND FREE OF PAINT, OIL, OR DIRT.

LUMBER

- SAWN FRAMING LUMBER SHALL COMPLY WITH THE LATEST EDITION OF THE GRADING RULES OF THE WESTERN WOOD PRODUCTS ASSOCIATION (WWPA) OR THE WEST COAST LUMBER INSPECTION BUREAU (WCLIB). ALL SAWN LUMBER SHALL BE STAMPED WITH THE GRADE MARK OF AN APPROVED LUMBER GRADING AGENCY. SAWN LUMBER SHALL HAVE THE FOLLOWING MINIMUM GRADE, UNLESS NOTED OTHERWISE IN CONSTRUCTION DOCUMENTS.

MEMBER	DESIGNATION
WALL STUDS	DF/L STUD OR #2
TIMBER BEAMS & HEADERS	DF/L #1 & BTR
WALL PLATES & OTHER STRUCTURAL SAWN MEMBERS NOT SPECIFIED ABOVE	DF/L CONSTRUCTION

- LUMBER RESTING ON CONCRETE AT GRADE SHALL BE TREATED WITH A PRESERVATIVE IN ACCORDANCE WITH AMERICAN WOOD PROTECTION ASSOCIATION (AWPA) REQUIREMENTS. FIELD TREATMENT OF END CUTS AND BORINGS IS REQUIRED ON MEMBERS OVER 2-IN THICK. FASTENERS IN PERSERVATIVE-TREATED WOOD SHALL BE STAINLESS STEEL OR HOT-DIPPED GALVANIZED IN ACCORDANCE WITH MANUFACTURE REQUIREMENTS OF TREATED LUMBER.
- WOOD CONNECTORS SHOWN ON THESE DRAWINGS SHALL BE PRODUCTS OF SIMPSON STRONG-TIE, INC. UNLESS NOTED OTHERWISE. HARDWARE BY OTHER MANUFACTUERES MAY BE USED PROVIDED THEY ARE OF EQUIVALENT CAPACITY AND HAVE CURRENT ICC-ES APPROVALS. SUBSTITUTIONS MUST BE APPROVED BY THE STRUCTURAL ENGINEER. INSTALL ALL CONNECTORS WITH ALL FASTENERS REQUIRED BY THE MANUFACTURER'S SPECIFICATIONS UNLESS NOTED OTHERWISE.
- ALL STRUCTURAL WOOD PANELS SHALL BE STRUCTURAL II APA RATED SHEATHING, AND SHALL BE THE FOLLOWING NOMINAL THICKNESS AND SPAN RATING, UNLESS NOTED OTHERWISE:

THICKNESS	SPAN RATING
19/32"	40 / 20

- FULL WIDTH SHEATHING PANELS SHALL BE USED WHENEVER POSSIBLE.

EPOXY ANCHORS

- EPOXY ANCHORS SHALL BE AN ADHESIVE ANCHOR SYSTEM AS LISTED BELOW:

A. HILTI HIT-HY 200 OR HIT-RE 500 V3

B. ITW RED HEAD C6+, A7+ OR G5

C. SIMPSON AT, SET OR SET-3G
- ANCHOR RODS SHALL BE ASTM A193 GRADE B7, DIAMETER AS INDICATED ON DRAWINGS, THREADED AND GALVANIZED.

DEFERRED SUBMITTALS

- DEFERRED SUBMITTALS ARE DEFINED AS THOSE PORTIONS OF THE DESIGN THAT ARE NOT SUBMITTED AT THE TIME OF THE APPLICATION AND THAT ARE TO BE SUBMITTED TO THE BUILDING OFFICIAL WITHIN A SPECIFIED PERIOD. FOR THIS PROJECT THE FOLLOWING ARE DEFERRED SUBMITTALS;

A. METAL PLATED WOOD TRUSSES

LOADING CRITERIA

- BUILDING RISK CATEGORYVI
- DEAD LOADCALCULATED FROM UNIT WEIGHT
- LIVE LOADS:

ALL FLOORS / SLABS NOT INDICATED100 PSF

ROOF LIVE LOAD20 PSF
- WIND LOAD:

BASIC WIND SPEED115 MPH

EXPOSUREC
- SNOW LOAD:

FLAT ROOF SNOW LOAD25 PSF
- SEISMIC LOAD:

PROCEDURE: EQUIVALENT LATERAL FORCE

SITE CLASS:D

IMPORTANCE FACTOR:1.5

SEISMIC DESIGN CATEGORY:D

SPECTRAL RESPONSE COEF:


S_{0s}0.888g

S₀₁0.855g

BASIC SEISMIC-FORCE-RESISTING SYSTEM:

SPECIAL REINFORCED MASONRY SHEAR WALLS

R = 5, OMEGA = 2.5, C_d = 3.5
- FROST DEPTH:18 INCHES
- ALLOWABLE SOIL BEARING CAPACITY3,000 PSF



NOT FOR CONSTRUCTION FOR REVIEW ONLY							
						NO	REVISIONS
						REV BY	DESCRIPTION
						DATE	

AMERICAN WATER (F4-A60MW42-00003) SAGE WELL II REPLACEMENT JBLM WASHINGTON		VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING		REVIEW	
		DESIGN DESIGN S. COHEN		CHECKED	
		DRAWN P. BAXTER		APPROVED	
				S. COHEN	

STRUCTURAL SAGE WELL II GENERAL STRUCTURAL NOTES - 1	PROJECT NUMBER 427-22-03

DRAWING NO. GS-01	
SHEET	46 OF 60

GENERAL STRUCTURAL NOTES

SPECIAL INSPECTIONS

1. SPECIAL INSPECTION IN ACCORDANCE WITH APPROPRIATE SECTIONS OF IBC 2018, CHAPTER 17 IS REQUIRED FOR THE PROJECT.
2. THE SPECIAL INSPECTOR SHALL SUBMIT A FINAL SIGNED REPORT STATING WHETHER THE WORK REQUIRING SPECIAL INSPECTION WAS, TO THE BEST OF THE INSPECTOR'S KNOWLEDGE, IN CONFORMANCE WITH THE APPROVED PLANS AND SPECIFICATIONS AND THE APPLICABLE WORKMANSHIP PROVISIONS OF THE CODE, TO THE BUILDING OFFICIAL AND THE ENGINEER.
3. A CERTIFICATE OF COMPLIANCE FOR OFF-SITE FABRICATION SHALL BE COMPLETED AND SUBMITTED TO THE BUILDING OFFICIAL FOR APPROVAL PRIOR TO ERECTION OF PREFABRICATED COMPONENTS. SPECIAL INSPECTION REQUIRED PER IBC SECTION 1704.2.
4. SPECIAL INSPECTION ITEMS REQUIRED PER LIST BELOW. CONTINUOUS OR PERIODIC INSPECTIONS IS DESIGNATED WITH A (C) OR (P).

CONCRETE: (TABLE 1705.3, 2018 IBC)

- A. PLACING REINFORCEMENT STEEL. ----- P
- B. WELDING REINFORCEMENT STEEL (IF APPROVED BY ENGINEER). ----- C
- C. PLACING ANCHOR BOLTS AND EMBEDDED PLATES. ----- P
- D. VERIFY APPLICABLE CONCRETE MIX BEING USED. ----- P
- E. SAMPLING CONCRETE FOR STRENGTH TESTS. ----- C
- F. CURING TECHNIQUES AND APPLICATION. ----- P

MASONRY (LEVEL B): (TMS 402/ACI 530/ASCE 5 AND TMS 602/ACI 530.1/ASCE 6)

- A. VERIFICATION OF APPROVED SUBMITTAL DOCUMENTS FOR MATERIALS. ----- P
- B. VERIFICATION OF PROPORTIONS OF SITE-PREPARED MORTAR AND GROUT. ----- P
- C. PREPARATION OF REQUIRED GROUT AND MORTAR SPECIMENS AND PRISMS. ----- P
- D. PLACEMENT OF MASONRY UNITS AND JOINTS. ----- P
- E. GROUT SPACE PRIOR TO GROUTING. ----- P
- F. PLACEMENT OF GROUT. ----- C
- G. VERIFY SIZE AND LOCATION OF STRUCTURAL ELEMENTS. ----- P
- H. VERIFY TYPE, SIZE, AND LOCATION OF ANCHORS. ----- P
- I. VERIFY SIZE, TYPE, AND LOCATION OF REINFORCEMENT. ----- P
- J. VERIFY PROTECTION OF MASONRY DURING COLD AND HOT WEATHER. ----- P

SOILS: (IBC TABLE 1705.6)

- A. VERIFY MATERIALS BELOW FOOTINGS ARE ADEQUATE FOR FOOTING SUPPORT. ----- P
- B. VERIFY EXCAVATIONS ARE TO PROPER DEPTH. ----- P
- C. VERIFY PROPERTIES OF COMPACTED FILL PRIOR TO PLACEMENT MEET REQUIREMENTS OF PROJECT. ----- P
- D. PRIOR TO PLACEMENT OF COMPACTED FILL OBSERVE SUBGRADE AND VERIFY THAT THE SITE HAS BEEN PREPARED PROPERLY. ----- P
- E. VERIFY PROPER USE OF COMPACTED FILL INCLUDING PROPER MATERIALS, COMPACTION DENSITIES AND LIFT THICKNESS. ----- C

STRUCTURAL OBSERVATION

BOWEN COLLINS & ASSOCIATES SHALL BE NOTIFIED BY THE CONTRACTOR 5 BUSINESS DAYS BEFORE THE COMPLETION OF THE ITEMS LISTED IN THIS SECTION SO THAT STRUCTURAL OBSERVATION MAY BE PERFORMED IN ACCORDANCE WITH IBC SECTION 1704.5. THE OBSERVATIONS WILL BE PERFORMED AT THE DISCRETION OF BOWEN COLLINS & ASSOCIATES. COMPLETED OBSERVATION REPORTS WILL BE SUBMITTED TO THE BUILDING OFFICIAL.

1. MASONRY REINFORCING BEFORE FIRST GOURT PLACEMENT.
2. WOOD ROOF FRAMING BEFORE PLACEMENT OF ROOFING MATERIALS.


PRE-MANUFACTURED ROOF TRUSS NOTES

1. PRE-MANUFACTURED METAL PLATED WOOD TRUSSES SHALL BE MANUFACTURED AS SPECIFIED IN ANSI/TPI 1. MANUFACTURER OF TRUSSES USING METAL PLATE CONNECTORS SHALL RETAIN AN APPROVED AGENCY TO MAKE NONSCHEDULED INSPECTIONS OF TRUSS MANUFACTURING AND DELIVERY OPERATIONS. THE INSPECTION SHALL COVER ALL PHASES OF TRUSS OPERATIONS, INCLUDING LUMBER STORAGE, HANDLING, CUTTING FIXTURES, PRESSES OR ROLLERS, MANUFACTURING, BUNDLING AND BANDING.
2. THE TRUSS FABRICATOR SHALL BE RESPONSIBLE FOR DETERMINING THE SIZE AND GRADE LUMBER REQUIRED FOR EACH TRUSS MEMBER. WHERE MEMBER SIZE IS INDICATED ON THE DRAWINGS THE FABRICATOR SHALL DETERMINE THE REQUIRED GRADE LUMBER. GRADES INDICATED ON DRAWINGS ARE MINIMUMS ONLY.
3. PRIOR TO FABRICATION, THE TRUSS FABRICATOR SHALL SUBMIT DESIGN CALCULATIONS AND SHOP DRAWINGS FOR EACH TRUSS TO THE ENGINEER FOR REVIEW. CALCULATIONS SHALL INCLUDE, MEMBER LOADS, FORCES AND CRITICAL STRESSES, AND MID-SPAN DEFLECTIONS. CALCULATIONS AND DRAWINGS SHALL ALSO INDICATE TYPE AND LOCATION OF BRACING REQUIRED BOTH DURING CONSTRUCTION AND PERMANENTLY. CALCULATIONS SHALL BEAR THE STAMP OF A LICENSED PROFESSIONAL ENGINEER IN THE STATE OF WASHINGTON.
4. MOMENT COEFFICIENTS USED IN THE TRUSS DESIGN SHALL BE 1/8 FOR ONE AND TWO SPAN CONDITIONS AND 1/10 FOR THREE OR MORE SPANS. THE EFFECTIVE LENGTH FACTOR USED FOR WEBS SHALL BE 1.0.
5. TOOTHED METAL PLATES AT CONNECTOR JOINTS SHALL BE DESIGNED FOR THE FULL-MEMBER DESIGN LOADS WITHOUT CONSIDERING WOOD TO WOOD BEARING. A STRESS INCREASE FOR THE VALUE OF A CONNECTOR WILL NOT BE ALLOWED IN ANY CIRCUMSTANCE. NET AREA OF METAL GUSSET PLATES SHALL BE LARGER BY 25% THAN THAT REQUIRED BY CALCULATED STRESSES. INCREASED PLATE SIZE SHALL BE MADE BY INCREASING THE PLATE DIMENSION IN EACH DIRECTION. THE AREA UNDERNEATH THE GUSSET PLATE FOR A DISTANCE OF 1/2" ON EITHER SIDE OF CONNECTORS SHALL BE BALANCED ON THE JOINT AS STRESSES REQUIRE AND DIMENSIONED AS TO THEIR LOCATION. ONLY ONE CONNECTION PER JOINT PER SIDE WILL BE ALLOWED.
6. MINIMUM SIZE OF ANY CONNECTOR SHALL BE 15 SQ. IN. MINIMUM BITE OF ANY GUSSET PLATE ON A TRUSSED MEMBER SHALL BE 2 1/2".
7. SPLICES IN TOP AND BOTTOM CHORDS SHALL OCCUR AT A JOINT OR WITHIN ONE-QUARTER OF THE SPAN OF A PANEL OF THE TRUSS. EACH SECTION OF THE CHORD MEMBER SHALL BE INVOLVED IN TWO JOINTS PRIOR TO BEING SPLICED.
8. ALL CONTINUOUS LATERAL BRACING SHALL BE Laterally SUPPORTED AT EACH END BY ANCHORING BRACING MEMBER TO END WALLS OR BY PROVIDING A DIAGONAL BRACE AT EACH END OF BRACING MEMBER AND AT 20'-0" INTERVALS.
9. THE FOLLOWING DESIGN CRITERIA SHALL BE USED:

TOP CHORD SNOW LOAD	= 25 PSF (DURATION FACTOR = 1.00)
TOP CHORD DEAD LOAD	= 12 PSF
BOT CHORD DEAD LOAD	= 8 PSF
BOT CHORD LIVE LOAD	= (10.0) PSF (W/O TOP CHORD SNOW LOAD)
TOTAL	= 45 PSF

10. THE TRUSSES SHALL BE DESIGNED FOR BOTH BALANCED AND UNBALANCED LOAD CASES. FOR THE UNBALANCED LOAD CASE THE WINDWARD SIDE SHALL HAVE NO SNOW LOAD AND THE LEEWARD SIDE SHALL USE 30 PSF.

MASONRY WALL SCHEDULE							
MARK	THICK	VERTICAL REINF			HORIZONTAL REINF		
		NO	SIZE	SPACING	NO	SIZE	SPACING
MW-1	8"	1	#5	32" OC	1	#5	48" OC
MW-2	12"	1	#5	24" OC	2	#4	48" OC



L	MAXIMUM BOND BEAM SPACING
0'-8" TO 3'-4"	8"
4'-0" TO 5'-4"	16"
6'-0" TO 7'-4"	24"
8'-0" TO 9'-4"	32"
10'-0" TO 11'-4"	40"
12'-0" OR LARGER	48"

MASONRY BOND BEAM NOTES:

1. BOND BEAM SPACING SHALL NOT EXCEED DISTANCE INDICATED BY TABLE INSIDE HATCHED AREAS. (EX: IF L=4'-8", BOND BEAMS SHALL NOT EXCEED 16" OC).
2. REGIONS OUTSIDE THE HATCHED ZONES MAY BE REINFORCED WITH REINFORCING INDICATED IN GENERAL NOTES OR SCHEDULE.
3. WHERE BOND BEAM REINFORCING SPACING IS 1/2" OR LESS THAN THAT REQUIRED BY THE WALL SCHEDULE, BOND BEAM REINFORCING MAY BE REDUCED BY 1/2.
4. ALL HORIZONTAL REINFORCING SHALL TERMINATE WITH A STANDARD HOOK AROUND VERTICAL REINFORCING.

MASONRY BOND BEAM SPACING



MASONRY WALL SCHEDULE

NOT TO SCALE

MASONRY BEAM SCHEDULE					
MARK	WIDTH	DEPTH	REINFORCEMENT		
			BOTTOM HORIZONTAL	TOP HORIZONTAL	VERTICAL
MB-1	12"	32"	2 #5	2 #5	WALL
MB-2	12"	16"	2 #5	-	WALL
MB-3	12"	24"	2 #5	2 #5	WALL
MB-4	8"	24"	1 #5	1 #5	WALL

MASONRY BEAM NOTES


1. VERTICAL WALL REINFORCEMENT (SIZE AND SPACING) SHALL BE USED FOR STIRRUPS, UNO. VERTICAL REINFORCEMENT SHALL END WITH A STANDARD ACI 180° HOOK AND SCHEDULED LAP WITH VERTICAL REINFORCEMENT ABOVE BEAM. WHERE NO WALL OCCURS ABOVE BEAM OR LAP IS NOT POSSIBLE, PROVIDE 180° STD HOOK AT TOP.
2. GROUT BEAMS SOLID FOR DEPTH SHOWN IN SCHEDULE.
3. TOP BARS SHALL EXTEND THE GREATER OF 24" OR A STANDARD LAP BEYOND FACE OF SUPPORTS (OR SHALL BE HOOKED IF REQUIRED). IF TOP BARS NEED TO BE SPLICED, SPLICE SHALL OCCUR AT MID-SPAN. BOTTOM BARS SHALL EXTEND A STANDARD LAP BEYOND THE FACE OF SUPPORTS AND BE SPLICED OVER SUPPORTS IF THERE IS AN ADJACENT MASONRY BEAM.
4. WHERE MORE THAN TWO HORIZONTAL BARS ARE REQUIRED IN EITHER THE TOP OR BOTTOM OF THE MASONRY BEAM THE ADDITIONAL BARS SHALL BE PLACED IN THE ADJACENT COURSES.
5. NO MECHANICAL, ELECTRICAL, PLUMBING OR OTHER OPENINGS SHALL BE PLACED IN OR THRU THE SOLID GROUTED MASONRY BEAM DEPTH.
6. REINFORCING INDICATED IN BEAM SCHEDULE IS IN ADDITION TO SCHEDULED HORIZONTAL AND VERTICAL WALL REINFORCING.
7. AT OPENINGS NOT SHOWN ON STRUCTURAL DRAWINGS (I.E. MECHANICAL OPENINGS) USE MASONRY BEAMS OF SIMILAR SIZE AND REINFORCING AS SHOWN IN THOSE WALLS FOR EQUIVALENT WIDTH OPENINGS. AS A MINIMUM USE:
- OPENINGS UP TO 4'-0", USE MB - 2
- OPENINGS UP TO 6'-8", USE MB - 3
- FOR CONDITIONS WHICH ARE OUTSIDE OF THESE GUIDELINES CONTACT THE ENGINEER.
8. WALLS ABOVE SCHEDULED BEAMS SHALL HAVE MINIMUM REINFORCING AS PER STRUCTURAL NOTES, TYPICAL, UNO.



MASONRY BEAM DETAILS

MASONRY BEAM DETAILS

NOT TO SCALE



NOT FOR CONSTRUCTION FOR REVIEW ONLY

AMERICAN WATER (P4-460MW2-00003) SAGE WELL II REPLACEMENT JBLM WASHINGTON

VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING

REVIEW CHECKED APPROVED S. COHEN


DESIGN DESIGN S. COHEN DRAWN P. BAXTER

STRUCTURAL SAGE WELL II GENERAL STRUCTURAL NOTES - 2



DATE: DECEMBER 2023 PROJECT NUMBER 427-22-03

DRAWING NO. GS-02


SHEET 47 OF 60



NOTE: WATERSTOP IS PREFORMED PLASTIC ADHESIVE TYPE.



NOTE:
1. AT CONTRACTOR'S OPTION, SEALANT GROOVES MAY CONTINUE STRAIGHT ACROSS CONSTRUCTION JOINT INTERSECTION OR BE STAGGERED UPON APPROVAL OF THE ENGINEER.
2. NO BOND BREAKER WHERE SEALANT GROVE IS CONSTRUCTED.



NOTE:
DISCONTINUE ALL REINFORCING AT JOINT. REINFORCING IS NOT SHOWN FOR CLARITY.

WATERSTOP

NOT TO SCALE

S

4001

WATERSTOP

NOT TO SCALE

S

4005

SEALANT

NOT TO SCALE

S


4007

EXPANSION JOINT

NOT TO SCALE


S

4012





DETAIL NOTES:

1. THIS DETAIL TO BE USED WHEN CALLED FOR ON THE DRAWINGS OR WHEN NO OTHER DETAIL IS SPECIFIED.
2. CUT NORMAL REINFORCING 2" CLEAR OF OPENING.
3. DIAGONAL BARS TO BE PLACED:
 - AT CENTERLINE OF WALL OR SLAB WHERE SINGLE MAT OF REINFORCEMENT IS PROVIDED.
 - AT EACH FACE OF WALL OR SLAB WHERE TWO MATS OF REINFORCEMENT ARE PROVIDED.
- NO ADDITIONAL REINFORCING REQUIRED FOR OPENINGS SMALLER THAN 8".



SINGLE-CURTAIN REINFORCING



DOUBLE-CURTAIN REINFORCING

REINFORCING NOTES:

1. SEE INDIVIDUAL STRUCTURE FOR REINFORCING.
2. DETAIL IS TYPICAL AT ALL CONCRETE CORNERS AND INTERSECTIONS UNLESS SHOWN OTHERWISE.

DIAGONAL REINFORCEMENT AT CIRCULAR OPENINGS

NOT TO SCALE

S


4030

WALL REINFORCING AT CORNERS AND JUNCTIONS

NOT TO SCALE

S

4039



CONCRETE WEIR

NOT TO SCALE

S

4043

90% REVIEW

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

SAGE WELL II REPLACEMENT
JBLM WASHINGTON

STRUCTURAL
SAGE WELL II
GENERAL STRUCTURAL
DETAILS - 1

DRAWING NO.
GS-03

SHEET 48 OF 60


DATE: DECEMBER 2023
PROJECT NUMBER 427-22-03

DESIGN
DESIGN S. COHEN
DRAWN P. BAXTER

CHECKED
APPROVED S. COHEN

VERIFY SCALE
BAR IS ONE INCH ON
ORIGINAL DRAWING


NO DATE REV BY DESCRIPTION



FOOTING DETAIL

NOT TO SCALE


S
4051



FOOTING DETAIL

NOT TO SCALE


S
4052



FOOTING DETAIL

NOT TO SCALE


S
4053



FOOTING DETAIL

NOT TO SCALE


S
4061



PIPE ENCASEMENT END

NOT TO SCALE


S
4107



PIPE ENCASEMENT END

NOT TO SCALE


S
4108




PIPE ENCASEMENT UNDER STRUCTURES

NOT TO SCALE


S
4110



TYPE A



TYPE B



TYPE C

EQUIPMENT PAD DETAILS

NOT TO SCALE

S
4113

EQUIPMENT PAD NOTES






- PAD SIZE SHALL BE MINIMUM INDICATED OR AS SHOWN ON THE DRAWINGS. VERIFY ALL PAD SIZE REQUIREMENTS WITH EQUIPMENT SHOP DRAWINGS OF ACTUAL EQUIPMENT FURNISHED AND OBTAIN ENGINEER'S APPROVAL OF FINAL DIMENSIONS.
- THE SIZE, NUMBER, TYPE, LOCATION, AND THREAD PROJECTION OF THE ANCHOR BOLTS SHALL BE DETERMINED BY THE EQUIPMENT MANUFACTURER, AND SHALL BE AS APPROVED BY THE ENGINEER. ANCHOR BOLTS SHALL BE HELD IN POSITION WITH TEMPLATES MATCHING THE EQUIPMENT BASE PLATE, WHILE PAD IS BEING POURED.
- INSTALL EQUIPMENT BASES LEVEL UNLESS SPECIFIED OTHERWISE.
- WEDGES OR SHIMS SHALL BE USED TO SUPPORT THE BASE WHILE THE NON-SHRINK GROUT IS PLACED. TEMPORARY LEVELING NUTS SHALL BE BACKED OFF. IF LEFT IN PLACE, THE WEDGES AND SHIMS SHALL NOT BE EXPOSED TO VIEW.
- HEIGHT OF PADS SHALL BE MINIMUM REQUIRED FOR ANCHOR BOLT CLEARANCE. COORDINATE ANCHOR BOLT LENGTH WITH EQUIPMENT MANUFACTURER.

90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY			
NO.	DATE	REV. BY	DESCRIPTION

SAGE WELL II REPLACEMENT JBLM WASHINGTON			
DESIGN	REVIEW	CHECKED	APPROVED
DESIGN S. COHEN	REVIEW S. COHEN	CHECKED S. COHEN	APPROVED S. COHEN
DRAWN P. BAXTER			

STRUCTURAL SAGE WELL II GENERAL STRUCTURAL DETAILS - 2	
DATE: DECEMBER 2023	PROJECT NUMBER: 427-22-03



1. GRATING DEPTH "1" AS NOTED ON DRAWINGS.
2. ALL EDGES AND OPENINGS ARE TO BE BANDED.
3. WEIGHT OF INDIVIDUAL GRATING SECTION SHALL NOT EXCEED 80 LBS.
4. METAL BEARING BARS ARE TO BE DEPTH "1"x $\frac{3}{16}$ " @ $1\frac{1}{16}$ " OC. CROSS BARS ARE TO BE AT 4" OC.
5. PROVIDE A MINIMUM OF 4 CLIPS PER GRATING PANEL AND LOCATE APPROXIMATELY 4" FROM PANEL CORNERS. MAXIMUM SPACING OF CLIPS IS 3'-0".
6. MATERIALS:
 - ALUMINUM GRATING - USE ALUMINUM ANGLE SUPPORTS AND STAINLESS STEEL BOLTS AND CLIPS.
 - GALVANIZED STEEL GRATING - USE GALVANIZED STEEL SUPPORTS, BOLTS, AND CLIPS. HOT-DIP GALVANIZE AFTER FABRICATION.
 - STAINLESS STEEL GRATING - USE 316 STAINLESS STEEL ANGLE SUPPORTS, BOLTS, AND CLIPS.

METAL GRATING

NOT TO SCALE

S

4416

DETAIL NOTES:

1. UNLESS OTHERWISE NOTED ON THE DRAWINGS, ALL GRATING IS FIBERGLASS.
2. GRATING DEPTH "T" AS NOTED ON DRAWINGS.
3. WEIGHT OF INDIVIDUAL GRATING SECTION SHALL NOT EXCEED 80 LBS.
4. BEARING BARS ARE "I" BARS TO BE DEPTH "1"x0.6" @ 1½" OC. TIE BARS ARE TO BE AT 6" OC MAXIMUM.
5. PROVIDE A MINIMUM OF 4 CLIPS PER GRATING PANEL AND LOCATE APPROXIMATELY 4" FROM PANEL CORNERS. MAXIMUM SPACING OF CLIPS IS 3'-0".
6. MATERIALS:
FRP GRATING - USE PULTRUDED FRP GRATING WITH FRP ANGLE SUPPORTS AND CLIPS AND STAINLESS STEEL BOLTS.


FIBERGLASS GRATING

NOT TO SCALE

S


4420

FLUID ABBREVIATION	FUNCTION	PIPING MATERIAL (SEE SCHEDULE AT RIGHT)				FIELD TEST REQUIREMENTS (SEE NOTE 3 AND NOTE 4)			PIPING MATERIAL SCHEDULE (SEE NOTE 4 AND GENERAL NOTE AT RIGHT)												
		EXPPOSED PIPING (SEE NOTE 14)		BURIED PIPING (SEE NOTE 13)		MINIMUM TEST PRESSURE PSI	TEST MEDIUM	LEAKAGE ALLOWANCE (SEE NOTE 2)	GROUP NO.	PIPE (SEE NOTE 13)	FITTINGS	VALVES, 6 INCHES & SMALLER, SEE NOTE 1, NOTE 11 & NOTE 16)									
		2" DIA & SMALLER	2 ½" DIA & LARGER	2" DIA & SMALLER	2 ½" DIA & LARGER																
A	AERATION	1,16,18	5,11,16,18	1,16,18	5,11,16,18	25	AIR	(A) (D)		STEEL, ASTM A53, SCHEDULE 40, BLACK WELDED.	2 1/2 INCH AND SMALLER, MALLEABLE IRON, ANSI B16.3, THREADED, BANDED, BLACK, 150 PSI OR STEEL, ANSI B16.9, BUTT-WELDED, 3 INCH AND LARGER, CAST IRON, ANSI B16.1, 125 PSI FLANGED OR MECHANICAL COUPLINGS.	BRONZE, THREADED, GATE, CRANE NO. 428 UB OR STOCKHAM B-105, GLOBE, CRANE NO. 14 1/2 P OR STOCKHAM B-29, CHECK, CRANE NO. 37 OR STOCKHAM B-319, STEEL, LUBRICATED PLUG, ROCKWELL FIG. 142 OR 143 OR POWELL FIG 2200 OR 2201,									
AC	ACTVATED CARBON	16	16	16	16	125	WATER	(A)		STEEL, ASTM A53, SCHEDULE 40 WELDED, GALVANIZED.	2 1/2 INCH AND SMALLER, MALLEABLE IRON, ANSI B16.3, THREADED, BANDED, GALZURIK 118S OR HOMESTEAD 1512. BALL, JENKINS NO. 900T, JAMESBURY FIG. 351 3 INCH AND LARGER, ECCENTRIC PLUG-SYNTHETIC RUBBER FACED, DEZURIK 118F OR KEYSTONE 1552 OR 1532 EWG. GATE, AWWA C500. BUTTERFLY, AWWA, FLANGED.	2 1/2 INCH AND SMALLER, ECCENTRIC PLUG, SYNTHETIC RUBBER, FACED, GALZURIK 118S OR HOMESTEAD 1512. BALL, JENKINS NO. 900T, JAMESBURY FIG. 351 3 INCH AND LARGER, ECCENTRIC PLUG-SYNTHETIC RUBBER FACED, DEZURIK 118F OR KEYSTONE 1552 OR 1532 EWG. GATE, AWWA C500. BUTTERFLY, AWWA, FLANGED.									
AS	ACTVATED SILICA	6, 16	6, 16	6, 16	6, 16	125	WATER	(A)													
AW	FILTER AIR WASH	16	16	16	16	25	AIR	(A)													
BR	BRINE SOLUTION	16	16	---	---	125	WATER	(A)													
BW	FILTER BACKWASH	---	8	---	8	75	WATER	(A)													
CAW	CHANNEL AGITATION WATER	16	16	16	16	25	WATER	(A)													
CD	CHEMICAL DRAIN AND VENT	13,17,23	13,17,23	13,17,23	13,17,23	NOTE 7	---	---													
CL	CHLORINE (GAS OR LIQUID STATE)	10	---	10	---	300	DRY AIR	(A) (D)													
CLS	CHLORINE SOLUTION	14,16	14,16	16	16	125	WATER	(A)													
CLV	CHLORINE GAS UNDER VACUUM	20	20	20	20	15 IN. Hg	VACUUM	(A) (E)													
CS	CAUSTIC SODA	6	6	6	6	125	WATER	(A)													
CT	CALCIUM THIOSULFATE	16, 29	16,29,31	16,29,31	16,29,31	125	WATER	(A)													
CV	CHLORINATOR VENT & DETECTION LINE	16	16	16	16	NOTE 8	---	---													
CWR	CHILLED WATER RETURN	1*24*	1*	1*24*	1*	125	WATER	(A)													
CWS	CHILLED WATER SUPPLY	1*24*	1*	1*24*	1*	125	WATER	(A)													
DR	DRAIN	2,16	8,11,12	2,16	8,11,27,55,56	15,NOTE7	WATER	(A)													
DW	DEMIMERALIZED WATER	16,18	16,18	16,18	16,18	125	WATER	(A)													
EE	ENGINEER EXHAUST	14*	14*	14	14	NOTE 8	---	---													
EWR	ENGINEER COOLING WATER RETURN	1*	1*	1*	1*	125	WATER	(A)													
EWS	ENGINEER COOLING WATER SUPPLY	1*	1*	1*	1*	125	WATER	(A)													
FC	FERRIC CHLORIDE	16	16	16	16	125	WATER	(A)													
FI	FILTER INFLEUNT	---	8	---	8	NOTE 6	WATER	(A)													
FOR	FUEL OIL RETURN	9	9	9	9	125	AIR	(A) (D)													
FOS	FUEL OIL SUPPLY	9	9	9	9	125	AIR	(A) (D)													
FSP	FIRE PROTECTION SPRINKLER SYSTEM	NOTE 10	NOTE 10	NOTE 10	NOTE 10	NOTE 9	WATER	---													
FW	FINISHED WATER	2, 24	8	2, 24	8, 28	25	WATER	2, 24(A) 28(B)													
HF	HYDROFLUOSILICIC ACID	16	16	16	16	125	WATER	(A)													
HR	HEATING WATER RETURN	1*	1*	1*	1*	125	WATER	(A)													
HS	HEATING WATER SUPPLY	1*	1*	1*	1*	125	WATER	(A)													
HWR	DOMESTIC HOT WATER RETURN	24*	2*	24*	2*	125	WATER	(A)													
HWS	DOMESTIC HOT WATER SUPPLY	24*	2*	24*	2*	125	WATER	(A)													
IA	INSTRUMENT AIR	24	2	24	2	125	AIR	(A) (D)													
LA	LIQUID ALUM	16	16	16	16	125	WATER	(A)													
LO	LUBE OIL	9	9	9	9	125	AIR	(A) (D)													
LPG	LIQUEFIED PETROLEUM GAS	3	3	3	3	NOTE 7	AIR	---													
LS	LIME SLURRY	NOTE 15	NOTE 15	NOTE 15	NOTE 15	NOTE 8	---	---													
LSP	LANDSCAPING SPRINKLER SYSTEM	2,16	2,16	2,16	2,16	NOTE 7	---	---													
NG	NATURAL GAS	9	9	9	9	NOTE 7	AIR	---													
OF	OVERFLOW	2,16	8	16	8	25	WATER	(A)													
PA	PLANT AIR	7	7	7	7	300	AIR	(A) (D)													
PD	PLANT DRAIN	2	8,12	2	8,12,22,28	NOTE 6	WATER	2,8(A) 12,28(B)22(C)													
PEA	POLYMER - ANIONIC	16	16	16	16	125	WATER	(A)													
PEC	POLYMER - CATIONIC	16	16	16	16	125	WATER	(A)													
PEN	POLYMER - NONIONIC	16	16	16	16	125	WATER	(A)													
PO	PLANT OVERFLOW	2	8	2	8,28	NOTE 6	WATER	2, 8(A) 28(B)													
PP	POTASSIUM PERMANGANATE	6,14,16	6,14,16	6,14,16	6,14,16	125	WATER	(A)													
PW	POTABLE WATER	2,16,24	2,8	2,16,24	2,8,11,19,36	125	WATER	2,11,24(A) 19(B)													
RW	RAW WATER	2	8	2	8,28	125	WATER	2, 8(A) 28(B)													
RWL	RAINWATER LEADER	4,12	4,12	12	12	NOTE 7	---	---													
SA	SAMPLE LINE (SEE LIGHT AT RIGHT)	16,18,24	---	16,18,24	---	125	WATER	(A)													
SC	SPARE CHEMICAL	16	16	16	16	125	WATER	(A)													
SD	SANITARY DRAIN AND VENT	4,12	12	12	12,21	NOTE 7	---	---													
SDR	STORM DRAIN	---	8	---	22,27,28,56	NOTE 6	WATER	8(A) 28(B) 22(C)													
SH	SODIUM HYPOCHLORITE	16,29,30,31	16,29,30,31	16,29,30,31	16,29,30,31	125	WATER	(A)													
SI	SODIUM SILICATE	6, 16	6, 16	6, 16	6, 16	125	WATER	(A)													
SL	SLUDGE	16,18	16,18	16,18	12,16,18	50	WATER	16, 18(A) 12(B)													
SLT	SALT	---	---	---	---	25	AIR	(A) (D)													
SLV	SLEEVE	2,16,24,29	2, 16, 29	2,16,24,29	2, 16, 29	NOTE 7	---	---													
SPD	SUMP DISCHARGE	2	26	2	26	50	WATER	(A)													
SS	SANITARY SEWER	---	12	---	12,21	NOTE 7	---	---													
SU	STRUCTURE UNDERDRAIN	---	---	16,21	16,21	---	NO TEXT REQ'D	---													
SUC	STRUCTURE UNDERDRAIN COLLECTOR	---	12	---	12,21	NOTE 6	WATER	(C)													
SW	FILTER SURFACE WASHWATER	14,16,18	8,14,15,16,18	2,16,18	2,8,15,16,18	125	WATER	(A)													
TW	TEMPERED WATER	16	16	---	---	125	WATER	(A)													
UW	UTILITY WATER (NON-POTABLE WATER)	2,24	2,11	2,24	2,11,19	125	WATER	2,11,24(A) 19(B)													
V	VENT	16,24,29	2,16,29	16,24,29	2,16,29	15 IN. Hg	VACUUM	(A) (E)													
WLO	WASTE LUBE OIL	9	9	9	9	50	AIR	(A) (D)													
WW	FILTER WASTE WASHWATER	---	8	---	8	NOTE 6	WATER	(A)													
(* SEE NOTE 5)																					
LIST OF SAMPLE LINES																					
PIPE DESIGNATION	SAMPLE POINT																				
TYPICAL PIPE DESIGNATION:																					
<div><div>2" UW (24)</div><div>MATERIAL GROUP NUMBER (SEE NOTE 12)</div><div>PIPE DIAMETER</div><div>FLUID ABBREVIATION</div></div>																					




SCALE: NTS

M
3138




SCALE: NTS

M
3143



SCALE: NTS

M
3149




SCALE: NTS

M
3167




M
3183




SCALE: NTS

M
3301



SCALE: NTS

M
3307



DIMENSION TABLE					
PIPE SIZE	A	B (SEE NOTE 3)	C HOLE DIAMETER	D FLAT BAR SIZE	LOAD RATING LBS *
¾"	5½"	2½"	⅞"	⅜"x1¼"	300
1"	6¼"	2¾"	⅞"	⅜"x1¼"	300
1¼"	6½"	2¾"	⅞"	⅜"x1¼"	300
1½"	6½"	3"	⅞"	⅜"x1¼"	300
2"	8½"	3½"	⅞"	¼"x1¼"	500
2½"	8½"	3½"	⅞"	¼"x1¼"	500
3"	9½"	3¾"	⅞"	¼"x1¼"	500
3½"	10½"	4"	⅞"	¼"x1¼"	500
4"	10½"	4¼"	⅞"	¼"x1¼"	600
5"	11¾"	4¾"	⅞"	¼"x1¼"	600
6"	14¾"	5½"	⅞"	⅜"x1¼"	850
8"	16¾"	6½"	⅞"	⅜"x1¼"	850


* SAFETY FACTOR OF 5

- NOTES:
- WHERE SUBMERGED, OR WHERE SHOWN ON DRAWINGS, PIPE CLAMP, ANCHOR, SHIELD, NUTS, AND LOCKWASHERS TO BE TYPE 316 STAINLESS STEEL.
 - WHEN USED WITH PVC OR FIBERGLASS PIPE, PROVIDE STEEL SHIELD AROUND PIPE AT CLAMP, WITH LOOSE FIT, WRAP COPPER TUBES WITH 2" STRIP OF RUBBER FABRIC.
 - FOR FLANGED PIPING, INCREASE 'B' DIMENSION AS REQUIRED.

PIPE CLAMP FOR INDIVIDUAL PIPES

SCALE: NTS

M
3372



DIMENSION TABLE					
PIPE SIZE	A	B	C	D	
				MIN	MAX
2½"	2½"	1½"	9"	8"	11½"
3"	2½"	1½"	9"	8¼"	11¾"
3½"	2½"	1½"	9"	8½"	12"
4"	3"	2½"	9"	10¼"	14"
6"	3"	2½"	9"	11½"	15¼"
8"	3"	2½"	9"	13½"	16½"
10"	3"	2½"	9"	14½"	18¼"
12"	3"	2½"	9"	15½"	19¾"
14"	4"	3"	11"	18½"	20¾"
16"	4"	3"	11"	19½"	22¼"
18"	6"	3½"	13½"	21¼"	24"
20"	6"	3½"	13½"	23¼"	25½"
24"	6"	4"	13½"	26½"	28¼"
30"	6"	4"	13½"	29½"	31½"
32"	6"	4"	13½"	30½"	32¾"
36"	6"	4"	13½"	32½"	34¾"

- NOTE:
- ENTIRE UNIT SHALL BE GALVANIZED AFTER FABRICATION.
 - PROVIDE HALF ROUND RIGID INSULATION AND INSULATION PROTECTION SHIELD, SIMILAR TO ANVIL FIGURE 167 OR ELCEN FIGURE 219, WHERE PIPING IS INSULATED.
 - PROVIDE NEOPRENE WAFFLE ISOLATION PAD, SIMILAR TO MASON TYPE "W" OR KORFUND WHEN PIPING IS ISOLATED OR SUPPORT IS ADJACENT TO MECHANICAL EQUIPMENT.
 - FOR BASE, HEIGHT AND FLANGE DIMENSIONS, SEE TABLE.

ADJUSTABLE PIPE SUPPORT WITH OR WITHOUT U-BOLT

SCALE: NTS

M
3389

90% REVIEW

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

SAGE WELL II REPLACEMENT
JBLM WASHINGTON

GENERAL MECHANICAL DETAILS

GENERAL MECHANICAL
DETAILS - 02

DRAWING NO.
GM-03

SHEET 54 OF 60


DATE: DECEMBER 2023
PROJECT NUMBER 427-22-03

DESIGN
J. OLDHAM
DRAWN
R. GARCIA


REVIEW
R. ROCHA
CHECKED
J. OLDHAM

VERIFY SCALE
BAR IS ONE INCH ON
ORIGINAL DRAWING

NO. DATE REV. BY DESCRIPTION REVISIONS



1
GH-01



2
GH-01

NOT FOR CONSTRUCTION
FOR REVIEW ONLY

REVISIONS						
	NO.	DATE	REV. BY	DESCRIPTION		

SAGE WELL II REPLACEMENT

DESIGN <u>L. RANKIN</u>	REVIEW <u>CHECKED L. RANKIN</u>	VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING ■■■■■
DRAWN <u>J. WILSON</u>	APPROVED <u>L. RANKIN</u>	

GENERAL HVAC DETAILS

DATE: DECEMBER 2023


RAWING NO.

GH-01

SHEET 55 OF 60




NOTES:
1. MOUNT PANEL OR INDICATION TRANSMITTER AT ABOUT 4' TO 5' ABOVE FINISHED FLOOR UNLESS OTHERWISE SPECIFIED IN DRAWINGS.




TYPICAL PANEL MOUNTING DETAIL ON WALL
SCALE: NTS

E 5001



COPPER GROUNDING
CABLE CONNECTION
COMPRESSION CONNECTION
SCALE: NTS

E 5002




KEY NOTES:

- ① GROUND ROD TO GROUND GRID CROSS CONNECTOR. SIZE FOR ROD AND CABLE PER MANUFACTURERS GUIDELINES.


GROUND ROD
COMPRESSION INSTALLATION
SCALE: NTS

E 5003




GROUND ROD AND WELL
SCALE: NTS

E 5004




SERVICE AND
EQUIPMENT GROUNDING DETAIL
SCALE: NTS

E 5005



DUCT BANK
SCALE: NTS

E 5010



CONDUIT PENETRATION THRU
WALL OR SLAB
SCALE: NTS

E 5012

90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY			
NO.	DATE	REV. BY	DESCRIPTION

VERIFY SCALE
BAR IS ONE INCH ON ORIGINAL DRAWING

REVIEW
CHECKED D. YOUNGSTROM
APPROVED D. YOUNGSTROM


DESIGN
DESIGN J. LAKE
DRAWN J. LAKE

GENERAL ELECTRICAL DETAILS - 1
DATE: DECEMBER 2023
PROJECT NUMBER 427-22-03

DRAWING NO.
GE-01

KEY NOTES:

- ① GROUND FLOW METER PRIMARY AS REQUIRED BY MANUFACTURER.
- ② CABLE BY VENDOR OR RECOMMENDED BY VENDOR.



TYPICAL FLOW METER SCHEMATIC

SCALE: NTS

E 5585


NOT USED

SCALE: NTS

E 50XX

KEY NOTES:



- ① 20 AMP SIMPLEX RECEPTACLE FOR TRANSFER PUMP.
- ② TRANSFER PUMP RELAY SHALL BE MOTOR DUTY RATED FOR THE CHLORINE TRANSFER PUMP LOAD.
- ③ DAY TANK HIGH LEVEL SWITCH.
- ④ COORDINATE SELECTION OF TIME DELAY RELAY WITH ACTUATOR OPERATING TIME (APPROXIMATELY 10 SECONDS).



TRANSFER PUMP CONTROL DIAGRAM

SCALE: NTS


E 5601



DOSING PUMPS CONTROL PANEL AND OUTLET

NOTES:

- A. METERING PUMPS MOUNTED IN LOCATIONS SHOWN ON THE ELECTRICAL PLANS.
- B. LABEL ALL PUMP CONTROL STATIONS AND DEDICATED RECEPTACLES. COORDINATE WITH AW-JBLM ELECTRICIAN FOR LABELING CRITERIA.



CHEMICAL PUMPS WIRING DIAGRAM

SCALE: NTS

E 5602

90% REVIEW

NOT FOR CONSTRUCTION FOR REVIEW ONLY		REVISIONS	
NO.	DATE	REV. BY	DESCRIPTION







SAGE WELL II REPLACEMENT		VERIFY SCALE	
AMERICAN WATER (P4-460MVA2-00003)		BAR IS ONE INCH ON ORIGINAL DRAWING	
JBLM WASHINGTON			

DESIGN		REVIEW	
DESIGN J. LAKE		CHECKED D. YOUNGSTROM	
DRAW J. LAKE		APPROVED D. YOUNGSTROM	

GENERAL ELECTRICAL DETAILS - 3		PROJECT NUMBER	
		427-22-03	
		DATE: DECEMBER 2023	

DRAWING NO.		PROJECT NUMBER	
GE-03		427-22-03	
		DATE: DECEMBER 2023	

SHEET		OF	
59		60	



AMERICAN WATER Military Services Joint Base Lewis-McChord

BOWEN COLLINS ASSOCIATES

NOT FOR CONSTRUCTION FOR REVIEW ONLY

VERIFICATION SCALE

SAGE WELL II REPLACEMENT JBLM WASHINGTON

DESIGN J. LAKE

REVIEW D. YOUNGSTROM

CHECKED D. YOUNGSTROM

APPROVED D. YOUNGSTROM

GENERAL ELECTRICAL DETAILS - 4

DATE: DECEMBER 2023

PROJECT NUMBER 427-22-03

DRAWING NO. GE-04

SHEET 60 OF 60